



Known for excellence.
Built on trust.

GEOTECHNICAL
ENVIRONMENTAL
ECOLOGICAL
WATER
CONSTRUCTION
MANAGEMENT

17975 West Sarah Lane
Suite 100
Brookfield, WI 53045
T: 262.754.2560
F: 262.923.7758
www.gza.com

March 29, 2022

Mr. and Mrs. Jon and Sharon Braun
980 Lincoln Drive West
West Bend, Wisconsin 53095-4725

Re: Results of Sub-Slab and Indoor Air Testing
980 Lincoln Drive West
West Bend, Wisconsin

Dear Mr. and Mrs. Braun:

On behalf of Continental VI Fund Limited Partnership (Continental), GZA GeoEnvironmental, Inc. (GZA) thanks you for allowing us access to conduct the testing in the home on your property in February 2022. As further described below, the results of vapor testing we conducted for chemicals that could be associated with the former Mr. Bob's One Hour Dry Cleaning that once operated at 1025 South Main Street (former Decorah Shopping Center) were found to be within allowable State levels.

Sub-Slab Soil Vapor and Indoor Air Sampling and Analyses

GZA collected two indoor air samples from the basement and first floor levels of your home at 980 Lincoln Drive West and an outside air background sample over a 24-hour period from February 11 to 12, 2022. The indoor air and outdoor air background samples were collected in 6-liter, evacuated SUMMA[®] vacuum canisters over a 24-hour sampling period.

GZA also collected two air samples from beneath the slab (referred to as sub-slab soil vapor samples) of the home on February 12, 2022, after completion of the indoor air sampling. The sub-slab soil vapor samples were collected in 1-liter, evacuated SUMMA[®] vacuum canisters through sampling ports GZA installed through the concrete floor slab.

The samples were submitted under chain-of-custody to Pace[®] Analytical Services, LLC of Minneapolis, Minnesota for analysis. The indoor and background air samples and sub-slab soil vapor samples were analyzed for the historical cleaning agent associated with operations at the former Mr. Bob's One Hour Dry Cleaning, tetrachloroethene (PCE) and related chemicals to which PCE degrades in the environment consisting of trichloroethene (TCE), cis- and trans-1,2-dichloroethene (cis- and trans-1,2-DCE), and vinyl chloride. The analyses were conducted in accordance with United States Environmental Protection Agency (USEPA) Method TO-15. The analytical report for the sub-slab and indoor air samples is attached.

Sub-Slab Sample Results

Of the five chemicals included for analysis, PCE was detected in the two sub-slab vapor samples, and TCE was detected in one of the two sub-slab samples. PCE was detected at concentrations of 24.4 micrograms per cubic meter ($\mu\text{g}/\text{m}^3$) and 309 $\mu\text{g}/\text{m}^3$ in the sub-slab vapor samples. The higher of the two reported concentrations is less than 25% of the Wisconsin Department of Natural Resources (WDNR) allowable residential sub-slab screening level of 1,400 $\mu\text{g}/\text{m}^3$.

TCE was detected in the one sub-slab sample at a concentration of 1.6 $\mu\text{g}/\text{m}^3$, which is less than 5% the WDNR's allowable residential sub-slab screening level of 70 $\mu\text{g}/\text{m}^3$. The WDNR has



established the sub-slab screening levels at concentrations below which indoor air quality is not expected to be adversely affected.

Indoor Air Sample Results

Of the five chemicals included for analysis, there were no chemicals detected in the indoor air samples. In summary, based on the testing we conducted, chemicals related to the former Mr. Bob's One Hour Dry Cleaning operation are not having an adverse effect on the indoor air in your home.

Future Sampling

The WDNR is requesting two additional rounds of confirmation indoor air and sub-slab testing. Therefore, we will contact you in two to three months to schedule a follow-up sampling round.

Questions

If you have questions, please call Bernie at (262) 424-2045 or John at (262) 424-2042 at GZA. You may also contact Mr. John Feeney of the WDNR (920-893-8523), if you have any questions related to the work conducted; or Mr. Curtis Hedman of the Wisconsin Department of Health Services (WDHS) (608-266-6677), if you have any health-related questions or concerns associated with the results.

On behalf of Continental, GZA thanks you for your cooperation.

Very truly yours,

GZA GeoEnvironmental, Inc.

Bernard G. Fenelon, P.G.
Senior Consultant
Hydrogeologist

John C. Osborne, P.G.
Senior Principal
Hydrogeologist

J:\156300to156399\156364 Continental WB\01 Source Area Vapor Int Eval\Correspondence\Results Letters\
2022 03 29 FINAL 156364.01 980 Lincoln Dr W Braun First Round SS and IAQ Results Letter.docx

Attachment: Laboratory Analytical Report

- c: Mr. Eric E. Thom, Continental VI Fund Limited Partnership
- Mr. John Feeney, WDNR
- Mr. Curtis Hedman, WDHS

March 15, 2022

Bernard Fenelon
GZA GeoEnvironmental
20900 Swenson Drive
Suite 150
Waukesha, WI 53186

RE: Project: 20.0156364.01 CONTINENTAL-WEST
Pace Project No.: 10597605

Dear Bernard Fenelon:

Enclosed are the analytical results for sample(s) received by the laboratory on February 15, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Minneapolis

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Matt Ray
matt.ray@pacelabs.com
(612)607-1700
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: 20.0156364.01 CONTINENTAL-WEST

Pace Project No.: 10597605

Pace Analytical Services, LLC - Minneapolis MN

1700 Elm Street SE, Minneapolis, MN 55414
1800 Elm Street SE, Minneapolis, MN 55414--Satellite Air Lab

A2LA Certification #: 2926.01*
Alabama Certification #: 40770
Alaska Contaminated Sites Certification #: 17-009*
Alaska DW Certification #: MN00064
Arizona Certification #: AZ0014*
Arkansas DW Certification #: MN00064
Arkansas WW Certification #: 88-0680
California Certification #: 2929
Colorado Certification #: MN00064
Connecticut Certification #: PH-0256
EPA Region 8 Tribal Water Systems+Wyoming DW Certification #: via MN 027-053-137
Florida Certification #: E87605*
Georgia Certification #: 959
Hawaii Certification #: MN00064
Idaho Certification #: MN00064
Illinois Certification #: 200011
Indiana Certification #: C-MN-01
Iowa Certification #: 368
Kansas Certification #: E-10167
Kentucky DW Certification #: 90062
Kentucky WW Certification #: 90062
Louisiana DEQ Certification #: AI-03086*
Louisiana DW Certification #: MN00064
Maine Certification #: MN00064*
Maryland Certification #: 322
Michigan Certification #: 9909
Minnesota Certification #: 027-053-137*
Minnesota Dept of Ag Approval: via MN 027-053-137
Minnesota Petrofund Registration #: 1240*
Mississippi Certification #: MN00064

Missouri Certification #: 10100
Montana Certification #: CERT0092
Nebraska Certification #: NE-OS-18-06
Nevada Certification #: MN00064
New Hampshire Certification #: 2081*
New Jersey Certification #: MN002
New York Certification #: 11647*
North Carolina DW Certification #: 27700
North Carolina WW Certification #: 530
North Dakota Certification #: R-036
Ohio DW Certification #: 41244
Ohio VAP Certification (1700) #: CL101
Ohio VAP Certification (1800) #: CL110*
Oklahoma Certification #: 9507*
Oregon Primary Certification #: MN300001
Oregon Secondary Certification #: MN200001*
Pennsylvania Certification #: 68-00563*
Puerto Rico Certification #: MN00064
South Carolina Certification #:74003001
Tennessee Certification #: TN02818
Texas Certification #: T104704192*
Utah Certification #: MN00064*
Vermont Certification #: VT-027053137
Virginia Certification #: 460163*
Washington Certification #: C486*
West Virginia DEP Certification #: 382
West Virginia DW Certification #: 9952 C
Wisconsin Certification #: 999407970
Wyoming UST Certification #: via A2LA 2926.01
USDA Permit #: P330-19-00208
Please Note: Applicable air certifications are denoted with an asterisk ().

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: 20.0156364.01 CONTINENTAL-WEST

Pace Project No.: 10597605

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10597605001	980 LINCOLN-DRIVE WEST 1st FLO	Air	02/12/22 09:38	02/15/22 10:07
10597605002	980 LINCOLN-DRIVE WEST BASEMEN	Air	02/12/22 09:35	02/15/22 10:07
10597605003	980 LINCOLN-DRIVE WEST BACKGRO	Air	02/12/22 09:40	02/15/22 10:07
10597605004	980 LINCOLN DRIVE WEST SOUTH S	Air	02/12/22 10:23	02/15/22 10:07
10597605005	980 LINCOLN DRIVE WEST NORTH S	Air	02/12/22 10:41	02/15/22 10:07
10597605006	UNUSED PACE1608	Air		02/15/22 10:07
10597605007	UNUSED PACE2508	Air		02/15/22 10:07

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: 20.0156364.01 CONTINENTAL-WEST

Pace Project No.: 10597605

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10597605001	980 LINCOLN-DRIVE WEST 1st FLO	TO-15	GT	5	PASI-M
10597605002	980 LINCOLN-DRIVE WEST BASEMEN	TO-15	GT	5	PASI-M
10597605003	980 LINCOLN-DRIVE WEST BACKGRO	TO-15	GT	5	PASI-M
10597605004	980 LINCOLN DRIVE WEST SOUTH S	TO-15	GT	5	PASI-M
10597605005	980 LINCOLN DRIVE WEST NORTH S	TO-15	GT	5	PASI-M

PASI-M = Pace Analytical Services - Minneapolis

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SUMMARY OF DETECTION

Project: 20.0156364.01 CONTINENTAL-WEST
Pace Project No.: 10597605

Lab Sample ID Method	Client Sample ID Parameters	Result	Units	Report Limit	Analyzed	Qualifiers
10597605004	980 LINCOLN DRIVE WEST SOUTH S					
TO-15	Tetrachloroethene	24.4	ug/m3	0.94	02/22/22 23:58	
10597605005	980 LINCOLN DRIVE WEST NORTH S					
TO-15	Tetrachloroethene	309	ug/m3	0.97	02/23/22 00:33	
TO-15	Trichloroethene	1.6	ug/m3	0.77	02/23/22 00:33	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

PROJECT NARRATIVE

Project: 20.0156364.01 CONTINENTAL-WEST

Pace Project No.: 10597605

Method: TO-15

Description: TO15 MSV AIR

Client: GZA GeoEnvironmental

Date: March 15, 2022

General Information:

5 samples were analyzed for TO-15 by Pace Analytical Services Minneapolis. All samples were received in acceptable condition with any exceptions noted below or on the chain-of custody and/or the sample condition upon receipt form (SCUR) attached at the end of this report.

Hold Time:

The samples were analyzed within the method required hold times with any exceptions noted below.

Initial Calibrations (including MS Tune as applicable):

All criteria were within method requirements with any exceptions noted below.

Continuing Calibration:

All criteria were within method requirements with any exceptions noted below.

Internal Standards:

All internal standards were within QC limits with any exceptions noted below.

Method Blank:

All analytes were below the report limit in the method blank, where applicable, with any exceptions noted below.

Laboratory Control Spike:

All laboratory control spike compounds were within QC limits with any exceptions noted below.

Duplicate Sample:

All duplicate sample results were within method acceptance criteria with any exceptions noted below.

Additional Comments:

This data package has been reviewed for quality and completeness and is approved for release.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 20.0156364.01 CONTINENTAL-WEST

Pace Project No.: 10597605

Sample: 980 LINCOLN-DRIVE WEST 1st FLO **Lab ID: 10597605001** Collected: 02/12/22 09:38 Received: 02/15/22 10:07 Matrix: Air

Parameters	Results	Units	LOQ	LOD	DF	Prepared	Analyzed	CAS No.	Qual
TO15 MSV AIR									
Analytical Method: TO-15									
Pace Analytical Services - Minneapolis									
cis-1,2-Dichloroethene	ND	ug/m3	1.2	0.30	1.52		02/22/22 20:40	156-59-2	
trans-1,2-Dichloroethene	ND	ug/m3	1.2	0.26	1.52		02/22/22 20:40	156-60-5	
Tetrachloroethene	ND	ug/m3	1.0	0.44	1.52		02/22/22 20:40	127-18-4	
Trichloroethene	ND	ug/m3	0.83	0.30	1.52		02/22/22 20:40	79-01-6	
Vinyl chloride	ND	ug/m3	0.40	0.13	1.52		02/22/22 20:40	75-01-4	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 20.0156364.01 CONTINENTAL-WEST

Pace Project No.: 10597605

Sample: 980 LINCOLN-DRIVE WEST Lab ID: 10597605002 Collected: 02/12/22 09:35 Received: 02/15/22 10:07 Matrix: Air
BASEMEN

Parameters	Results	Units	LOQ	LOD	DF	Prepared	Analyzed	CAS No.	Qual
TO15 MSV AIR									
Analytical Method: TO-15									
Pace Analytical Services - Minneapolis									
cis-1,2-Dichloroethene	ND	ug/m3	1.2	0.29	1.49		02/22/22 21:15	156-59-2	
trans-1,2-Dichloroethene	ND	ug/m3	1.2	0.25	1.49		02/22/22 21:15	156-60-5	
Tetrachloroethene	ND	ug/m3	1.0	0.44	1.49		02/22/22 21:15	127-18-4	
Trichloroethene	ND	ug/m3	0.81	0.29	1.49		02/22/22 21:15	79-01-6	
Vinyl chloride	ND	ug/m3	0.39	0.13	1.49		02/22/22 21:15	75-01-4	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 20.0156364.01 CONTINENTAL-WEST

Pace Project No.: 10597605

Sample: 980 LINCOLN-DRIVE WEST **Lab ID:** 10597605003 Collected: 02/12/22 09:40 Received: 02/15/22 10:07 Matrix: Air
BACKGRO

Parameters	Results	Units	LOQ	LOD	DF	Prepared	Analyzed	CAS No.	Qual
TO15 MSV AIR									
Analytical Method: TO-15									
Pace Analytical Services - Minneapolis									
cis-1,2-Dichloroethene	ND	ug/m3	1.1	0.27	1.41		02/22/22 23:24	156-59-2	
trans-1,2-Dichloroethene	ND	ug/m3	1.1	0.24	1.41		02/22/22 23:24	156-60-5	
Tetrachloroethene	ND	ug/m3	1.9	0.79	2.69		02/24/22 06:58	127-18-4	
Trichloroethene	ND	ug/m3	0.77	0.28	1.41		02/22/22 23:24	79-01-6	
Vinyl chloride	ND	ug/m3	0.37	0.12	1.41		02/22/22 23:24	75-01-4	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 20.0156364.01 CONTINENTAL-WEST

Pace Project No.: 10597605

Sample: 980 LINCOLN DRIVE WEST SOUTH S **Lab ID: 10597605004** Collected: 02/12/22 10:23 Received: 02/15/22 10:07 Matrix: Air

Parameters	Results	Units	LOQ	LOD	DF	Prepared	Analyzed	CAS No.	Qual
TO15 MSV AIR									
Analytical Method: TO-15									
Pace Analytical Services - Minneapolis									
cis-1,2-Dichloroethene	ND	ug/m3	1.1	0.27	1.36		02/22/22 23:58	156-59-2	
trans-1,2-Dichloroethene	ND	ug/m3	1.1	0.23	1.36		02/22/22 23:58	156-60-5	
Tetrachloroethene	24.4	ug/m3	0.94	0.40	1.36		02/22/22 23:58	127-18-4	
Trichloroethene	ND	ug/m3	0.74	0.27	1.36		02/22/22 23:58	79-01-6	
Vinyl chloride	ND	ug/m3	0.35	0.12	1.36		02/22/22 23:58	75-01-4	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: 20.0156364.01 CONTINENTAL-WEST

Pace Project No.: 10597605

Sample: 980 LINCOLN DRIVE WEST **Lab ID:** 10597605005 Collected: 02/12/22 10:41 Received: 02/15/22 10:07 Matrix: Air
NORTH S

Parameters	Results	Units	LOQ	LOD	DF	Prepared	Analyzed	CAS No.	Qual
TO15 MSV AIR		Analytical Method: TO-15 Pace Analytical Services - Minneapolis							
cis-1,2-Dichloroethene	ND	ug/m3	1.1	0.27	1.41		02/23/22 00:33	156-59-2	
trans-1,2-Dichloroethene	ND	ug/m3	1.1	0.24	1.41		02/23/22 00:33	156-60-5	
Tetrachloroethene	309	ug/m3	0.97	0.41	1.41		02/23/22 00:33	127-18-4	
Trichloroethene	1.6	ug/m3	0.77	0.28	1.41		02/23/22 00:33	79-01-6	
Vinyl chloride	ND	ug/m3	0.37	0.12	1.41		02/23/22 00:33	75-01-4	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: 20.0156364.01 CONTINENTAL-WEST
Pace Project No.: 10597605

QC Batch: 799957 Analysis Method: TO-15
QC Batch Method: TO-15 Analysis Description: TO15 MSV AIR Low Level
Laboratory: Pace Analytical Services - Minneapolis
Associated Lab Samples: 10597605001, 10597605002, 10597605003, 10597605004, 10597605005

METHOD BLANK: 4249300 Matrix: Air
Associated Lab Samples: 10597605001, 10597605002, 10597605003, 10597605004, 10597605005

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
cis-1,2-Dichloroethene	ug/m3	ND	0.40	02/22/22 08:45	
Tetrachloroethene	ug/m3	ND	0.34	02/22/22 08:45	
trans-1,2-Dichloroethene	ug/m3	ND	0.40	02/22/22 08:45	
Trichloroethene	ug/m3	ND	0.27	02/22/22 08:45	
Vinyl chloride	ug/m3	ND	0.13	02/22/22 08:45	

LABORATORY CONTROL SAMPLE: 4249301

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
cis-1,2-Dichloroethene	ug/m3	43.4	51.7	119	70-136	
Tetrachloroethene	ug/m3	73.4	80.7	110	70-134	
trans-1,2-Dichloroethene	ug/m3	43.6	54.7	126	70-134	
Trichloroethene	ug/m3	58.4	66.7	114	70-134	
Vinyl chloride	ug/m3	28	34.9	124	70-132	

SAMPLE DUPLICATE: 4250436

Parameter	Units	10597635025 Result	Dup Result	RPD	Max RPD	Qualifiers
cis-1,2-Dichloroethene	ug/m3	ND	ND		25	
Tetrachloroethene	ug/m3	45.3	48.3	6	25	
trans-1,2-Dichloroethene	ug/m3	ND	ND		25	
Trichloroethene	ug/m3	ND	ND		25	
Vinyl chloride	ug/m3	ND	ND		25	

SAMPLE DUPLICATE: 4250437

Parameter	Units	10597635027 Result	Dup Result	RPD	Max RPD	Qualifiers
cis-1,2-Dichloroethene	ug/m3	ND	ND		25	
Tetrachloroethene	ug/m3	25.9	23.4	10	25	
trans-1,2-Dichloroethene	ug/m3	ND	ND		25	
Trichloroethene	ug/m3	ND	ND		25	
Vinyl chloride	ug/m3	ND	ND		25	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: 20.0156364.01 CONTINENTAL-WEST

Pace Project No.: 10597605

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above LOD.

J - Estimated concentration at or above the LOD and below the LOQ.

LOD - Limit of Detection adjusted for dilution factor, percent moisture, initial weight and final volume.

LOQ - Limit of Quantitation adjusted for dilution factor, percent moisture, initial weight and final volume.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected at or above the adjusted LOD.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: 20.0156364.01 CONTINENTAL-WEST

Pace Project No.: 10597605

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10597605001	980 LINCOLN-DRIVE WEST 1st FLO	TO-15	799957		
10597605002	980 LINCOLN-DRIVE WEST BASEMEN	TO-15	799957		
10597605003	980 LINCOLN-DRIVE WEST BACKGRO	TO-15	799957		
10597605004	980 LINCOLN DRIVE WEST SOUTH S	TO-15	799957		
10597605005	980 LINCOLN DRIVE WEST NORTH S	TO-15	799957		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



AIR: CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

55658

Page: 1 of 1

Section A Required Client Information:	Section B Required Project Information:	Section C Invoice Information:	Program <input type="checkbox"/> UST <input type="checkbox"/> Superfund <input type="checkbox"/> Emissions <input type="checkbox"/> Clean Air Act <input type="checkbox"/> Voluntary Clean Up <input type="checkbox"/> Dry Clean <input type="checkbox"/> RCRA <input type="checkbox"/> Other
Company: <u>GZA GILSON ENVIRONMENTAL INC.</u>	Report To: <u>GZA</u>	Attention: <u>GZA</u>	
Address: <u>17475 W. SPARROW LAKE STE 100 BROOKFIELD, WI 53045</u>	Copy To:	Company Name:	
Email To: <u>BERNARD.FEJERON@GZA.COM</u>	Purchase Order No.:	Address:	
Phone: <u>262-754-2560</u> Fax:	Project Name: <u>CONTINENTAL - WEST BEND</u>	Pace Quote Reference:	Location of Sampling by State <u>WI</u> Reporting Units ug/m ³ ___ mg/m ³ ___ PPBV ___ PPMV ___ Other ___
Requested Due Date/TAT: <u>NORMAN</u>	Project Number: <u>72.0156364.01</u>	Pace Profile #: <u>39827</u>	Report Level II ___ III ___ IV ___ Other ___

ITEM #	'Section D Required Client Information AIR SAMPLE ID Sample IDs MUST BE UNIQUE	Valid Media Codes MEDIA CODE	PID Reading (Client only)	COLLECTED				Canister Pressure (Initial Field - in Hg)	Canister Pressure (Final Field - in Hg)	Summa Can Number	Flow Control Number	Method:	Pace Lab ID							
				COMPOSITE START		COMPOSITE - END/GRAB								PM10	3C - Fixed Gas (%)	TO-14 BTEX	TO-14M (Merhang)	TO-15 Full List VOCs	TO-15 Short List BTEX	TO-15 Short List Chlorinated
				DATE	TIME	DATE	TIME													
1	980 LINCOLN DRIVE WEST 1 ST FLOOR IA	6LL		2/11/22	0938	2/12/22	938	-30	-5	2840	1379	X	001							
2	980 LINCOLN DRIVE WEST BASEMENT IA	6LL		2/11/22	0943		935	-30	-2	1080	1850	X	002							
3	980 LINCOLN DRIVE WEST BACKGROUND IA	6LL		2/11/22	0951		940	-30	-4	1265	0849	X	003							
4	980 LINCOLN DRIVE WEST SOUTH SS	11C		2/12/22	1009		1023	-28	-1	3041	1496	X	004							
5	980 LINCOLN DRIVE WEST NORTH SS	11C			1028		1041	-30	-3	1339	3099	X	005							

Comments: PLEASE ANALYZE: PCE; TCE; VC; CIS AND TRANS 1,2 DCE

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS			
[Signature]	2/12/22	1200	PER FED BR			Temp in °C	Received on Ice	Custody Sealed Cooler	Samples Intact
				2-14-22	9:49				
				2-15-22	10:07				

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER:
 SIGNATURE of SAMPLER: _____ DATE Signed (MM / DD / YY)

WO#: 10597605



10597605

Air Sample Condition Upon Receipt Client Name: **GZA** Project #: **WO#: 10597605**
 Courier: FedEx UPS USPS Client
 Pace Speedee Commercial
 Tracking Number: **975384483744, 81572887948** See Exception
 Custody Seal on Cooler/Box Present? Yes No
 Seals Intact? Yes No
 Packing Material: Bubble Wrap Bubble Bags Foam
 None Tin Can Other: _____
 Date & Initials of Person Examining Contents: **2-15-22 MJ**

Chain of Custody Present?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		1.
Chain of Custody Filled Out?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		2.
Chain of Custody Relinquished?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		3.
Sampler Name and/or Signature on COC?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		5.
Short Hold Time Analysis (<72 hr)?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		6.
Rush Turn Around Time Requested?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		7.
Sufficient Volume?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		8.
Correct Containers Used? (Tedlar bags not acceptable container for TO-15 or APH)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		9.
-Pace Containers Used?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Containers Intact? (visual inspection/no leaks when pressurized)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		10.
Media: <u>Air Can</u> Airbag				11. Individually Certified Cans? Y <u>N</u> (list which samples)
Is sufficient information available to reconcile samples to the COC?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		12.
Do cans need to be pressurized? (DO NOT PRESSURIZE 3C or ASTM 1946!!!)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		13.

Gauge #: 10AIR26 10AIR34 10AIR35 10AIR17 10AIR47 10AIR48

Canisters					Canisters				
Sample Number	Can ID	Flow Controller	Initial Pressure	Final Pressure	Sample Number	Can ID	Flow Controller	Initial Pressure	Final Pressure
1st floor	2840	1379	-3.5	+5					
Basement	1080	1850	-3	↓					
Background	1265	849	-1.5	↓					
South	3041	1496	-0.5	+10					
North	1339	3099	-1.5	+10					
Unused	1608	1411	-28	-					
"	2508	3202	-28	-					

CLIENT NOTIFICATION/RESOLUTION Field Data Required? Yes No
 Person Contacted: _____ Date/Time: _____
 Comments/Resolution: _____

Project Manager Review: Matt Ray Date: 02/16/22
 Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNR Certification Office (i.e., out of hold, incorrect preservative, out of temp, incorrect containers).