From: Ken Shimko <kshimko.meridianenv@gmail.com>

Sent: Thursday, December 12, 2019 9:02 AM

To: Stoltz, Carrie R - DNR

Subject: Change order - Jump River - electrical disconnect for new well Attachments: Change Order - Install Electrical Disconnect for new well.pdf

Hi Carrie.

Enclosed is Change Order to install electrical disconnect for new well at the Country Store in Jump River. This is similar to what we did for the Keepers well.

Kenneth Shimko, PG Meridian Environmental Consulting, LLC 2711 North Elco Road Fall Creek, Wisconsin 54742 (715)832-6608 (office) (715)579-0723 (cell)

Email: kshimko.meridianenv@gmail.com



Meridian Environmental Consulting, LLC

December 12, 2019

Carrie Stoltz Wisconsin Department of Natural Resources 107 Sutliff Avenue Rhinelander, Wisconsin 54501

Subject:

Change Order:

Install Electrical Disconnect for New Well at Country Store (8891

Bridge Road)

Site:

Jim's Bar

W14764 Highway 73 Jump River, Wisconsin PECFA No. 54433-9769-64 DNR BRRTS No. 03-61-000116

Meridian No. 05F781

Scope of Work

The new well will be connected to the current water supply through the Store floor. This requires a disconnect be installed by a licensed electrician adjacent to the entrance point.

The original plan was to connect to the existing well's water line adjacent to the existing well. However, the site owner requests the new connection inside the Store to avoid freezing the water line.

Cost

Cost Estimate attached.

Sincerely,

MERIDIAN ENVIRONMENTAL CONSULTING, LLC

Kenneth Shimko, PG Project Manager



Estimate

Date	Estimate #	
12/11/2019	1215	

Meridian Environmental Consulting, LLC 2711 North Elco Road Fall Creek, WI 54742

Doug Stanek	ug Stanek		P.O. No.	
715-314-0392				
Item	Description	Qty	Rate	Total
Well	Hook up well at jump river gas station -surface mount conduit from electrical panel to separate room where pressure tank is located with a service disconnect for the well		758.29	758.29
		Subtotal		\$758.2
		Sales Tax (5.5%)		\$41.7
		Total		\$800.0