



FILE COPY

ENVIRONMENTAL & REGULATORY SERVICES  
101 West Pleasant Street, Suite 205  
Milwaukee, Wisconsin 53212  
Fax: (414) 220-5374  
[www.commerce.state.wi.us](http://www.commerce.state.wi.us)  
**Tommy G. Thompson, Governor**  
**Brenda J. Blanchard, Secretary**

April 13, 1999

Ms. Liz Stueck-Mullane  
Wisconsin Electric Power Company  
333 West Everett Street  
Milwaukee, WI 53201

**RE: COMMERCE # 53158-2208-00**  
**Pleasant Prairie Power Plant-Locomotive Refueling Area,**  
**8000 95<sup>th</sup> Street, Pleasant Prairie**

**Underground Storage Tank Piping Replacement/Upgrade**

**Case Closure**

Dear Ms. Stueck-Mullane:

On March 12, 1999, the Wisconsin Department of Natural Resources (WDNR) transferred the referenced case to the Wisconsin Department of Commerce for regulatory oversight. The Department has reviewed the case file to determine if closure is appropriate.

Using the standards established in NR 700, the Department has determined that this site was investigated to a level protective of the environment and human health. Therefore, the Department considers this site to meet environmental standards and that no further action is necessary.

This site is now listed as "closed" on the Commerce database. If, in the future, site conditions indicate that any remaining contamination poses a threat, the need for further remediation would be determined and required if necessary.

Thank you for your efforts in the protection of Wisconsin's environment. If you have any questions, feel free to contact me at (414) 220-5376.

Sincerely,

Linda M. Michalets  
Hydrogeologist  
Site Review Section

cc: Mr. Kenneth W. Yass, STS Consultants, Ltd.  
Commerce electronic file



State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES

Tommy G. Thompson, Governor  
George E. Meyer, Secretary  
Gloria L. McCutcheon, Regional Director

Southeast Region Headquarters  
2300 N. Dr. Martin Luther King, Jr. Drive  
PO Box 12436  
Milwaukee, Wisconsin 53212-0436  
Telephone 414-263-8500  
FAX 414-263-8606  
TDD 414-263-8713

RECEIVED

MAR 19 1999

PECFA SITE REVIEW  
MILWAUKEE OFFICE

BRRTS#: 03-30-215807  
Facility ID#: 230006260  
BRR/LUST: LUST

March 12, 1999

Ms. Liz Stueck-Mullane  
Wisconsin Electric  
333 West Everett Stret  
Milwaukee, WI 53201

SUBJECT: Reported Contamination at the Pleasant Prairie Power Plant Facility/Locomotive Refueling  
Area *8000 95TH STREET, PLEASANT PRAIRIE*

Dear Ms. Stueck-Mullane:

On 2/17/99, you notified the Department that fuel oil which leaked from an underground storage tank piping system caused soil contamination at the site described above.

Based on information submitted to the Wisconsin Department of Natural Resources (WDNR), we believe you are responsible for restoring the environment at the referenced site under Section 292, Wisconsin Stats., known as the hazardous substances spills law.

However, the Wisconsin Department of Commerce is responsible for governmental oversight of environmental cleanup activities at properties contaminated by petroleum storage systems when contamination has not impacted groundwater above state preventive action limits.

Since groundwater is not known to be impacted above these limits, your case file has been transferred to Commerce. Please refer questions concerning your site to Commerce at the following address:

Wisconsin Department of Commerce  
101 W. Pleasant St.  
Suite 205  
Milwaukee WI 53212

CONTACT

Nancy Kochis	414-220-5372
Jennifer Skinner	414-220-5373
Greg Michaels	414-220-5375
Linda Michalets	414-220-5376

To speed processing at Commerce, please refer to the BRRTS number shown in the upper right corner of this letter.

Sincerely,

Pat Chung  
Program Specialist  
Remediation and Redevelopment  
414-263-8688

cc: file



TRANSFER TO 23 DM

WISCONSIN ELECTRIC Co.

FID # 230006260 BRRTS # 0330215807 INITIALS

3/10/99 DCOM

SITE RANKING

- High priority (DNR CASE)
  - Presence of a hazardous substance other than petroleum from a petroleum product storage tank system.
  - Contamination to an area of exceptional environmental value where the discharge would pose a greater than normal threat.
  - Confirmed groundwater contamination where any compound detected is equal to or greater than an established enforcement standard.

- Medium priority (COMM CASE)
  - No evidence of contamination by a hazardous substance other than the petroleum product, which was discharged from the petroleum storage tank system; and
  - No confirmed groundwater contamination at or above the enforcement standard.

- Low priority (COMM CASE)
  - only petroleum contamination and no threat to groundwater, and
  - No evidence of a hazardous substance other than the petroleum product discharged from the petroleum product storage tank system.

CLOSED 4/13/99 Umm

Unknown

IMPACTS (p=potential; k= known)

- fire/explosion threat
- contaminated private wells (# \_\_\_\_\_)
- contaminated public well
- groundwater contamination
- soil contamination
- surface water contacts
- free product
- storm sewer contamination
- sanitary sewer contamination
- air contamination
- direct contact
- concrete/asphalt
- contained/recovered
- other: \_\_\_\_\_

SUBSTANCES

	#tanks, containers	size
<input type="checkbox"/> leaded gas	_____	_____
<input type="checkbox"/> unleaded gas	_____	_____
<input checked="" type="checkbox"/> diesel	_____	_____
<input checked="" type="checkbox"/> fuel oil	_____	PIPING
<input type="checkbox"/> unknown hydrocbrn	_____	_____
<input type="checkbox"/> waste oil	_____	_____
<input type="checkbox"/> metals	_____	_____
<input type="checkbox"/> RCRA haz waste	_____	_____
<input type="checkbox"/> VOCs	_____	_____
<input type="checkbox"/> Chlorinated Solvent	_____	_____
<input type="checkbox"/> PCBs	_____	_____
<input type="checkbox"/> foundry sand	_____	_____
<input type="checkbox"/> misc. fill	_____	_____
<input type="checkbox"/> pesticides	_____	_____
<input type="checkbox"/> leachate	_____	_____
<input type="checkbox"/> PAHs/SVOCs	_____	_____
<input type="checkbox"/> oil and grease	_____	_____
<input type="checkbox"/> other	_____	_____


FEDERAL ELIGIBILITY

YES  NO  UNKNOWN

- ^  Tanks 110 gallons or more qualify, unless they are
  - ^  Farm and residential tanks of 1,100 gallons or less, used for storing motor fuel for non-commercial purposes OR
  - ^  Used to store heating oil for consumptive use on premises where stored OR
  - ^  Closed properly prior to 12/22/88

**Wisconsin Electric Power Company**

333 West Everett Street  
Milwaukee, Wisconsin 53203



Underground Storage Tank  
Piping Replacement Report

**RECEIVED**

**MAR 19 1999**

PECFA SITE REVIEW  
MILWAUKEE OFFICE

**Wisconsin Electric**

**Locomotive Refueling Area**

Pleasant Prairie Power Plant  
8000 95th Street  
Pleasant Prairie, Wisconsin

STS Project No. 85863XA

January 27, 1999





January 27, 1999

Ms. Liz Stueck-Mullane  
Wisconsin Electric  
333 West Everett Street  
Milwaukee, Wisconsin 53201

Re: Underground Storage Tank Piping Replacement Report for the Wisconsin Electric Pleasant Prairie Power Plant facility (Locomotive Refueling Area) Located in Pleasant Prairie, Wisconsin -- STS Project No. 85863XA

Dear Liz:

STS Consultants Ltd. is pleased to submit this Underground Storage Tank Piping Replacement Report for the above-referenced site. The report contains summaries of the information collected during the piping replacement.

We appreciate the opportunity to be of service to you. Please contact us at (414) 359-3030 if you have any questions or comments regarding this report or this project.

Sincerely,

STS CONSULTANTS LTD.

A handwritten signature in cursive script that reads "Ken W. Yass".

Kenneth W. Yass, E.I.T., CHMM  
Project Engineer

A handwritten signature in cursive script that reads "Tom Kroeger / KWY".

Thomas W. Kroeger  
Principal Scientist

Attachments

©STS Consultants Ltd., January 1999

**TABLE OF CONTENTS**

**Page No.**

**EXECUTIVE SUMMARY**

**1.0 INTRODUCTION..... 1**

**2.0 PURPOSE AND SCOPE OF WORK ..... 1**

    2.1 Purpose of Work ..... 1

    2.2 Project Team ..... 1

**3.0 SITE LOCATION AND BACKGROUND INFORMATION ..... 1**

    Figure 1 - Site Location Diagram ..... 2

**4.0 PIPING REPLACEMENT PROCEDURES ..... 3**

    4.1 Surplus Product Management ..... 3

    4.2 Piping Replacement ..... 3

    4.3 Sludge Management..... 3

    4.4 Piping Disposal ..... 3

**5.0 FIELD OBSERVATIONS AND SOIL SAMPLING..... 3**

    5.1 Field Observations ..... 3

    5.2 Soil Sampling and Field Screening Results ..... 3

    Figure 2 - Soil Sampling Locations ..... 4

**6.0 SOIL SAMPLING LABORATORY RESULTS ..... 5**

    Table 1 - Soil Sampling Results - Piping Replacements ..... 6

**7.0 PROJECT SUMMARY..... 7**

**8.0 RECOMMENDATIONS ..... 7**

**9.0 LIMITATIONS OF INVESTIGATION ..... 8**

**APPENDICES**

- Appendix A - Involved Parties List
- Appendix B - Piping Replacement Checklist and Installation Form
- Appendix C - Laboratory Analytical Reports and Chain-of-Custody Form

## EXECUTIVE SUMMARY

Wisconsin Electric (WE) retained STS Consultants, Ltd. (STS) to perform a site assessment following the replacement of buried piping for one underground storage tank (UST) holding diesel fuel for refueling locomotives at WE's Pleasant Prairie Power Plant facility. The assessment was performed to determine if diesel range organics (DRO) were released into the environment. STS prepared this report to summarize field activities and observations, and the results of independent laboratory analysis for soil samples collected during the assessment.

U.S. Petroleum Equipment and Environmental Services (U.S. Petroleum) replaced the piping with flexible piping. Prior to replacement, the product in the piping was drained back to the USTs. U.S. Petroleum then removed the piping and disposed of it on site for recycling where it was rendered useless for all but scrap.

STS inspected the piping excavation on October 22, 1998 for any evidence of a release. No odors or discolored soil were noted in the piping excavation. Native soil noted beneath the piping was clayey sand and gravel. The piping excavation backfill was sand and gravel. Water was encountered in the UST cavity at approximately 5 feet below ground surface during piping replacement. No sheen or discoloration was noted on the water.

Two soil samples were collected from native soil in the piping excavation from depths 4.5 feet below grade. The samples were submitted for laboratory analysis of DRO. DRO was present in at concentrations of 8.35 mg/kg and 10.4 mg/kg in the two soil samples.

No physical evidence of a release (odors, soil staining or elevated PID readings) were noted in the backfill of the piping trench. Analytical results report DRO soil concentrations at or below 10 mg/kg; as such, it does not appear that a leak occurred from the piping. No further work is recommend at this time for the locomotive refueling area. A copy of this report must be submitted to the Wisconsin Department of Natural Resources in Madison, Wisconsin.

**UNDERGROUND STORAGE TANK PIPING REPLACEMENT REPORT  
WISCONSIN ELECTRIC PLEASANT PRAIRIE POWER PLANT  
LOCOMOTIVE REFUELING AREA  
PLEASANT PRAIRIE, WISCONSIN**

**1.0 INTRODUCTION**

Wisconsin Electric (WE) retained STS Consultants, Ltd. (STS) to perform a site assessment following the replacement of buried piping which connected one underground storage tank (UST) to a dispenser island at WE's Pleasant Prairie Power Plant in Pleasant Prairie, Wisconsin. The piping and tank is used for refueling locomotives used at the facility. STS prepared this report to document the personnel and companies involved with the project, disposal of the piping, surplus product and sludge, geologic and hydrogeologic conditions, soil sample analytical results, and project conclusions.

**2.0 PURPOSE AND SCOPE OF WORK**

**2.1 Purpose of Work**

The purpose of the site assessment was to assess soil quality within the piping excavation to determine if diesel range organics (DRO) were released from the piping into the environment.


**2.2 Project Team**

The contractors and personnel involved with the project are listed in Appendix A.

**3.0 SITE LOCATION AND BACKGROUND INFORMATION**

The Pleasant Prairie Power Plant is located in a rural area of The Village of Pleasant Prairie. The site is located in the southwest 1/4 of the southeast 1/4 of Section 16, Township 1 North, Range 22 East, Kenosha County, Wisconsin (Figure 1). Specifically, the site is located at 8000 95<sup>th</sup> Street, Pleasant Prairie, Wisconsin.





SOURCE: USGS PLEASANT PRAIRIE, WISCONSIN QUADRANGLE - 1958, REVISED 1971



**SITE LOCATION MAP**  
**PLEASANT PRAIRIE POWER PLANT**  
**8000 95<sup>TH</sup> STREET**  
**PLEASANT PRAIRIE, WISCONSIN**

DRAWN BY: dlm	DATE: 12/12/98
CHECKED BY: kwy	DATE: 12/12/98
APPROVED BY: jmt	DATE: 12/12/98
FILE NO. 85863XAig1.doc	SCALE: 1" = 2,000'
STS PROJECT NO. 5-85863XA	FIGURE NO. 1

## **4.0 PIPING REPLACEMENT PROCEDURES**

### **4.1 Surplus Product Management**

Product in the piping runs was drained back into the UST prior to piping replacement activities.

### **4.2 Piping Replacement**

The section of steel piping was replaced with flexible piping. U.S. Petroleum Equipment and Environmental Services (U.S. Petroleum) personnel broke concrete in the area of the dispenser and excavated approximately three to five feet of soil to access the piping. The piping ran from the UST approximately 18 feet east and connected to a dispenser island (see Figure 2A). The installation checklist for the new piping installation is included in Appendix B.

### **4.3 Sludge Management**

No sludge was generated from the piping upgrade.

### **4.4 Piping Disposal**

The piping was disposed of by U.S. Petroleum in an on-site recycling container and was rendered useless for all uses but scrap. Approximately 18 feet of piping was disposed of for recycling.


## **5.0 FIELD OBSERVATIONS AND SOIL SAMPLING**

### **5.1 Field Observations**

During removal and upgrade activities no staining or obvious petroleum odors were noted in the soil. The piping was observed to be in good condition with no corrosion or perforations noted. Water was observed in the cavity at approximately 5 feet below ground surface. No discoloration or sheen was noted on the water. The checklist for piping replacement is included in Appendix B.

### **5.2 Soil Sampling and Field Screening Results**

Soil samples were collected at locations depicted on Figure 2A. Samples were collected from the excavation side walls at the approximate depth of the former piping grade, 4.5 feet below ground surface.



**LEGEND**

▲ S-1 PIPING REPLACEMENT SOIL SAMPLING LOCATION



STS Consultants Ltd.  
Consulting Engineers

SOIL SAMPLING LOCATIONS  
LOCOMOTIVE REFUELING AREA  
WISCONSIN ELECTRIC  
PLEASANT PRAIRIE POWER PLANT  
PLEASANT PRAIRIE, WISCONSIN

DRAWN BY	SNL	12/7/98
CHECKED BY	KWY	12/7/98
APPROVED BY	TMK	12/7/98
CADFILE	G55863001	SCALE N.T.S.
STS PROJECT NO.	85863XA	FIGURE NO. 2A

Wisconsin Electric  
P4 - Locomotive Refueling Area  
STS Project No. 85863XA  
January 27, 1999

A Photoionization Detector (PID) was used to screen the soil sample for the presence of volatile organic compounds by means of headspace analysis. The PID was equipped with a 10.6 eV lamp and was calibrated in the field. Prior to headspace analysis, each soil sample was allowed to equilibrate to approximately 70°F and vigorously agitated to break-up large clumps to facilitate vapor release. The PID readings are tabulated on Table 1.

## 6.0 SOIL SAMPLING LABORATORY RESULTS

The soil samples were transported with a chain-of-custody document to U.S. Filter Analytical laboratory for DRO analysis. The DRO samples were analyzed using the Wisconsin Department of Natural Resources (WDNR) modified method specified in the "Leaking Underground Storage Tank Analytical and Quality Assurance Guidance Document (PUBL-SW-13093)". The analytical results from the soil samples are listed in Table 1.

The soil samples contained DRO at concentrations of 8.35 milligrams per kilogram (mg/kg) in S-1 and 10.4 mg/kg in S-2.

U.S. Filter Analytical Laboratory stated that the DRO results were indicative of a fuel oil/diesel. Copies of the laboratory reports are presented in Appendix C.

**Table 1**  
**Soil Sampling Results - Piping Replacements**  
**Locomotive Refueling Area**  
**Wisconsin Electric - Pleasant Prairie Power Plant**  
**STS Project No. 85863XA**

Sample No.	S-1	S-2
Sample Depth	4.5 feet below ground surface	4.5 feet below ground surface
Soil Description	Crushed stone some gravel	Crushed stone some gravel
Odor?	No	No
PID Reading (IU)	0.2	4.2
DRO, mg/kg	<b>8.35 (D1, D4)</b>	<b>10.4 (D1, D4)</b>

**NOTES:**

1. DRO - Diesel Range Organics (WI. Modified Method).
2. mg/kg - milligrams per kilogram, or parts per million.
3. Sample depths shown in feet below ground surface.
4. Field PID (IU) - Photoionization Detector result. IU - Instrument Units, similar to ppm.
5. NR 720 RCL = Residual Contaminant Level = 1) the NR 720 Table 1 generic RCL = 100 for DRO
6. **101** = NR 720 RCL exceedance
7. Samples analyzed by U.S. Filter/Enviroscan laboratory in Rothschild, WI
8. See Figure 2 for sampling locations.
9. D1-The chromatogram is characteristic for a fuel oil/diesel. (i.e. # 1 or #2 diesel, jet fuel, kerosene, aged or degraded diesel, etc.)
10. D4-The chromatogram contained significant peaks outside the DRO window.

## 7.0 PROJECT SUMMARY

The following summary is based on the observations, activities, and findings of the piping replacement and closure assessment:

- An 18-foot section of buried steel piping which connected one UST to a dispenser was replaced with flexible piping at the locomotive refueling area at WE's Pleasant Prairie Power Plant.
- Prior to replacement, surplus product was drained from the piping back to the UST.
- No sludge was generated from the piping replacement.
- Water was observed in the piping excavation at 5 feet below the ground surface.
- Physical evidence of a release (odors or soil discoloration) were not noted in the backfill or water within the piping excavation.
- STS collected two soil samples for DRO testing.
- DRO was present at concentrations of 8.35 mg/kg and 10.4 mg/kg in the samples.

## 8.0 RECOMMENDATIONS

No physical evidence of a release was noted in the backfill or on the water within the piping excavation. Although very low PID readings were recorded in the soil samples, analytical testing results report DRO soil concentrations at or below 10 mg/kg, the concentration above which the WDNR generally requires additional investigation. No further work is recommended at this time for the locomotive refueling area.

A copy of this report must be submitted to:

Ms. Julie Weber  
Wisconsin Department of Natural Resources  
Remediation and Redevelopment Program  
P.O. Box 7921  
Madison, Wisconsin 53707

## 9.0 LIMITATIONS OF INVESTIGATION

This report was prepared under constraints of cost, time, and scope and reflects a limited assessment and evaluation rather than a full, total, complete or extensive assessment and evaluation.

Our assessment was performed using the degree of care and skill ordinarily exercised, under similar circumstances, by professional consultants practicing in this or similar localities. No other warranty or guarantee, expressed or implied, is made as to the conclusions and professional advice included in this report.

The findings of this report are valid as of the present date of the assessment. However, changes in the conditions of the Property can occur with the passage of time, whether due to natural processes or the works of man on this or adjacent properties. In addition, changes in applicable or appropriate standards may occur, whether they result from legislation, from the broadening of knowledge, or from other reasons. Accordingly, the findings of this report may be invalidated wholly or partially by changes outside of our control.

The interpretations and conclusions contained in this report are based upon the result of independent laboratory tests and analyses intended to detect the presence and/or concentrations of certain chemical constituents in samples taken from the subject property. STS has no control over such testing and analysis and therefore, disclaims any responsibility for any errors and omissions arising therefrom.

This report is issued with the understanding that it is the responsibility of the owner(s) to ensure that the information and recommendations contained herein are brought to the attention of the appropriate regulatory agency(ies).

## **APPENDICES**

**Appendix A - Personnel/Contractor Identification and Certification**

**Appendix B - Piping Replacement Checklist and Installation Form**

**Appendix C - Laboratory Analytical Reports and Chain-of-Custody Form**



**APPENDIX A**

**Personnel/Contractor Identification and Certifications**

**Site Assessor -**

Mr. Kenneth Yass  
STS Consultants Ltd.  
11425 West Lake Park Drive  
Milwaukee, WI 53224  
(414) 359-3030  
Certification No. 42419

**Site Owner -**

Wisconsin Electric  
Contact: Ms. Liz Stueck-Mullane  
333 West Everett Street  
Milwaukee, WI 53202  
(414) 221-2303

**Tank Excavator, Remover and Cleaner -**

Mr. Jeff Wildenburg  
U.S. Petroleum Equipment and Env. Services  
1425 Commerce Avenue, Unit C  
Brookfield, Wisconsin 53045  
Telephone: 414-786-8742  
Remover Certification No. 42840

**On-Site DILHR Representative -**

Not applicable

**Surplus Product -**

Drained back into USTs

**Sludge Disposal Facility -**

Not applicable

**Piping Disposal Facility -**

Not applicable

**Laboratory Services -**

U.S. Filter Analytical Laboratory  
Contact: Ms. Sharon Maltbey  
301 West Military Road  
Rothschild, Wisconsin 54474  
Telephone: 800-338-7226  
WDNR Certification #737053130

**Complete one form for each site closure.**

**CHECKLIST FOR TANK CLOSURE**

**RETURN COMPLETED CHECKLIST TO:**

The information you provide may be used by other government agency programs [Privacy Law, s.15.04 (1)(m)].

**CHECK ONE:**  
 **UNDERGROUND**  
 **ABOVEGROUND**  
**FOR PORTIONS OF THE FORM THAT DO NOT APPLY, CHECK THE N/A BOX**

Wisconsin Department of Commerce  
 ERS Division  
 Bureau of Storage Tank Regulation  
 P.O. Box 7969  
 Madison, WI 53707

**A. IDENTIFICATION: (Please Print) Indicate whether closure is for:**  Tank System  Tank Only  Piping Only

1. Site Name Pleasant Prairie Power Plant 2. Owner Name Wisconsin Electric

Site Street Address (not P.O. Box) 8000 95th Street Owner Street Address 333 W. Everett Str.

City Pleasant Prairie  Village  Town of:  City Milwaukee  Village  Town of: State WI Zip Code 53203

State WI Zip Code 53142 County Kenosha County Milwaukee Telephone No. (include area code) (414) 221-1234

3. Closure Company Name (print) U.S. Petroleum Equipment Closure Company Street Address \_\_\_\_\_

Closure Company Telephone No. (include area code) \_\_\_\_\_ Closure Company City, State, Zip Code \_\_\_\_\_

4. Name of Company Performing Closure Assessment STS Consultants Ltd Assessment Company Street Address, City, State, Zip Code 11475 West Lake Park, Milwaukee, WI 53224

Telephone # (include area code) 414 359-3030 Certified Assessor Name (print) Ken Yass Assessor Signature Ken Yass Assessor Certification No. 42419

Tank ID #	Closure	Temp. Closure	Closure in Place	Tank Capacity	Contents*	Closure Assessment
1.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/> Y <input type="checkbox"/> N
2.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/> Y <input type="checkbox"/> N
3.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/> Y <input type="checkbox"/> N
4.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/> Y <input type="checkbox"/> N
5.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/> Y <input type="checkbox"/> N
6.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/> Y <input type="checkbox"/> N

\* Indicate which product by numeric code: 01-Diesel; 02-Leaded; 03-Unleaded; 04-Fuel Oil; 05-Gasohol; 06-Other; \_\_\_\_\_; 10-Premix; 11-Waste Oil; 13-Chemical (indicate the chemical name(s) or number(s) \_\_\_\_\_; 14-Kerosene; 15-Aviation.

Written notification was provided to the local agent 15 days in advance of closure date.  Y  N  NA  
 All local permits were obtained before beginning closure.  Y  N  NA

**B. TEMPORARILY OUT OF SERVICE** **Remover Verified** **Inspector Verified** **NA**

Written inspector approval of temporary closure obtained, which is effective until (provide date) \_\_\_\_\_  Y  N  NA

1. Product Removed  Y  N  NA  NA

a. Product lines drained into tank (or other container) and resulting liquid removed, AND \_\_\_\_\_  Y  N  NA  NA

b. All product removed to bottom of suction line, OR \_\_\_\_\_  Y  N  NA  NA

c. All product removed to within 1" of bottom. \_\_\_\_\_  Y  N  NA  NA

2. Fill pipe, gauge pipe, tank truck vapor recovery fittings, and vapor return lines capped. \_\_\_\_\_  Y  N  NA  NA

3. All product lines at the islands or pumps located elsewhere are removed and capped, OR \_\_\_\_\_  Y  N  NA  NA

4. Dispensers/pumps left in place but locked and power disconnected. \_\_\_\_\_  Y  N  NA  NA

5. Vent lines left open. \_\_\_\_\_  Y  N  NA  NA

6. Inventory form filed indicating temporary closure. \_\_\_\_\_  Y  N  NA  NA

**C. CLOSURE BY REMOVAL**

1. Product from piping drained into tank (or other container). \_\_\_\_\_  Y  N  NA  NA

2. Piping disconnected from tank and removed. \_\_\_\_\_  Y  N  NA  NA

3. All liquid and residue removed from tank using explosion proof pumps or hand pumps. \_\_\_\_\_  Y  N  NA  NA

4. All pump motors and suction hoses bonded to tank or otherwise grounded. \_\_\_\_\_  Y  N  NA  NA

5. Fill pipes, gauge pipes, vapor recovery connections, submersible pumps and other fixtures removed. \_\_\_\_\_  Y  N  NA  NA

**NOTE: DROP TUBE SHOULD NOT BE REMOVED IF THE TANK IS TO BE PURGED THROUGH THE USE OF AN EDUCTOR.**

6. Vent lines left connected until tanks purged. \_\_\_\_\_  Y  N  NA  NA

7. Tank openings temporarily plugged so vapors exit through vent. \_\_\_\_\_  Y  N  NA  NA

8. Tank atmosphere reduced to 10% of the lower flammable range (LEL) - see Section F. \_\_\_\_\_  Y  N  NA  NA

9. Tank removed from excavation after PURGING/INERTING; placed on level ground and blocked to prevent movement. \_\_\_\_\_  Y  N  NA  NA

10. Tank cleaned before being removed from site. \_\_\_\_\_  Y  N  NA  NA

**CLOSURE BY REMOVAL (continued)**

	Remover Verified	Inspector Verified	NA
11. Tank labeled in 2" high letters after removal but before being moved from site. ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
<b>NOTE: COMPLETE TANK LABELING SHOULD INCLUDE WARNING AGAINST REUSE; FORMER CONTENTS; VAPOR STATE; VAPOR FREEING TREATMENT; DATE.</b>			
12. Tank vent hole (1/8" in uppermost part of tank) installed prior to moving the tank from site. ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
13. Inventory form ERS-7437 filed by owner with the Department of Commerce indicating closure by removal.	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
14. Site security is provided while the excavation is open. ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>

**D. CLOSURE IN PLACE**

**NOTE: CLOSURES IN PLACE ARE ONLY ALLOWED WITH THE PRIOR WRITTEN APPROVAL OF THE DEPARTMENT OF COMMERCE OR LOCAL AGENT.**

1. Product from piping drained into tank (or other container). ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
2. Piping disconnected from tank and removed. ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
3. All liquid and residue removed from tank using explosion proof pumps or hand pumps. ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
4. All pump motors and suction hoses bonded to tank or otherwise grounded. ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
5. Fill pipes, gauge pipes, vapor recovery connections, submersible pumps and other fixtures removed. ...	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
<b>NOTE: DROP TUBE SHOULD NOT BE REMOVED IF THE TANK IS TO BE PURGED THROUGH THE USE OF AN EDUCTOR - EDUCTOR OUTPUT 12 FT. ABOVE GRADE.</b>			
6. Vent lines left connected until tanks purged. ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
7. Tank openings temporarily plugged so vapors exit through vent. ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
8. Tank atmosphere reduced to 10% of the lower flammable range (LEL) see Section F. ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
9. Tank properly cleaned to remove all sludge and residue. ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
10. Solid inert material (sand, cyclone boiler slag, pea gravel recommended) introduced and tank filled. ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
11. Vent line disconnected or removed. ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
12. Inventory form filed by owner with the Department of Commerce indicating closure in place. ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>

**E. CLOSURE ASSESSMENTS**

**NOTE: DETERMINE IF A CLOSURE ASSESSMENT IS REQUIRED BY REFERRING TO ILHR 10.**

1. Individual conducting the assessment has a closure assessment plan (written) which is used as the basis for their work on the site. ....	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
2. Do points of obvious contamination exist? ....	<input type="checkbox"/> Y <input checked="" type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
3. Are there strong odors in the soils? ....	<input type="checkbox"/> Y <input checked="" type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
4. Was a field screening instrument used to pre-screen soil sample locations? ....	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
5. Was a closure assessment omitted because of obvious contamination? ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6. Was the DNR notified of suspected or obvious contamination? ....	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Agency, office and person contacted: _____			
7. Contamination suspected because of: <input type="checkbox"/> Odor <input type="checkbox"/> Soil Staining <input type="checkbox"/> Free Product <input type="checkbox"/> Sheen on Groundwater <input type="checkbox"/> Field Instrument Test			

**F. METHOD OF ACHIEVING 10% LEVEL DESCRIPTION**

Eductor Or Diffused Air Blower

Eductor driven by compressed air, bonded and drop tube left in place; vapors discharged minimum of 12 feet above ground.  
Diffused air blower bonded and drop tube removed. Air pressure not exceeding 5 psig.

Dry Ice

Dry Ice introduced at 1.5 pounds per 100 gallons of tank capacity. Dry ice crushed and distributed over the greatest possible tank area.  
Dry ice evaporated before proceeding.

Inert Gas (CO<sub>2</sub> or N<sub>2</sub>) **NOTE: INERT GASSES PRODUCE AN OXYGEN DEFICIENT ATMOSPHERE. THE TANK MAY NOT BE ENTERED IN THIS STATE WITHOUT SPECIAL EQUIPMENT.**

Gas introduced through a single opening at a point near the bottom of the tank at the end of the tank opposite the vent.  
Gas introduced under low pressure not to exceed 5 psig to reduce static electricity. Gas introducing device grounded.

Tank atmosphere monitored for flammable or combustible vapor levels.

Calibrate combustible gas indicator. Drop tube removed prior to checking atmosphere. Tank space monitored at bottom, middle and upper portion of tank. Readings of 10% or less of the lower flammable range (LEL) obtained before removing tank from ground.

**G. NOTE SPECIFIC PROBLEMS OR NONCOMPLIANCE ISSUES BELOW**

**H. REMOVER/CLEANER INFORMATION**

Remover Name (print) \_\_\_\_\_

Remover Signature \_\_\_\_\_

Remover Certification No. \_\_\_\_\_

Date Signed \_\_\_\_\_

**INSPECTOR INFORMATION**

Inspector Name (print) \_\_\_\_\_

Inspector Signature \_\_\_\_\_

Inspector Certification No. \_\_\_\_\_

FDID # For Location Where Inspection Performed \_\_\_\_\_

Inspector Telephone Number \_\_\_\_\_

Date Signed \_\_\_\_\_

**TANK INVENTORY FORM ERS-7437 SIGNED BY THE OWNER MUST BE SUBMITTED WITH EACH CLOSURE CHECKLIST**

**DEPT OF COMMERCE/BUREAU OF STORAGE TANK REGULATION**

CHECKLIST FOR UNDERGROUND TANK INSTALLATION

Return Completed Checklist To: Wisconsin Department of Commerce ERS Division Bureau of Storage Tank Regulation P. O. Box 7837 Madison, WI 53707-7837

Reg Obj #: For Office Use Only 300402159

Complete one form for each tank and related piping.

The information you provide may be used for secondary purposes [Privacy Law, s.15.04(1)(m)].

This checklist covers

- installation of: [ ] Tank; [X] Piping; [ ] Vapor Recovery; [X] Spill Containment; [X] Overfill Protection; [ ] Leak Detection; [ ] Corrosion Protection; [ ] Automated Fueling (key-card-code); [ ] Lining

A. IDENTIFICATION: (Please Print)

1. Installation Name: Pleasant Prairie Power Plant; 2. Owner Name: Wisconsin Electric Power; Installation Street Address: 8000 95th St; Owner Street Address: 333 W. Everett St; City: Pleasant Prairie; City: Milwaukee; State: WI; Zip Code: 53201; County: Kenosha; County: Milwaukee; Telephone No.: (414) 947-5314; 3. Installation Company Name: U.S. Petroleum Equipment; Installation Company Street Address: 1425 Commerce Ave, Unit C; State: WI; Zip Code: 53045; Company Telephone No.: (414) 786-8742; Certified Installer Name: JEFF WILDENBERG; Installer Certification No.: 42840

B. PLAN APPROVAL

- 1. Plans have been submitted and approved. [X]
2. State plan number/LPO plan number is: 183895
3. Tank Capacity: 10,000 gallons. Tank contents, if known: OFF ROAD DIESEL

C. TANK CONSTRUCTION

- 1. Tank is new and carries UL or other national testing label. [ ]
2. Tank is used, but has been recertified to meet the EPA new tank standard. [ ]
3. Tank is corrosion protected ([ ] cathodically protected steel, [X] fiberglass or [ ] composite tank) and matches the equipment listed in the plan review. [ ]
4. Test stations have been installed for monitoring cathodic protection on the tank. [ ]
5. Gasoline and other Class I flammable tank vents discharge at least 12 feet above ground level, discharge only upward, and do not terminate under eaves or near a building opening. [ ]
6. Fuel oil, diesel or other Class II or III A liquid storage tank vents are at least 4 feet above ground level. [X]
7. Overfill protection device is installed and matches plan submittal. [X]
8. Spill containment device installed. [X]

D. TANK HANDLING AND TESTING

- 1. Tank was lifted using lifting lugs, no chains or slings were placed around the tank shell. [ ]
2. Tank coating was inspected and any damage to the coating repaired. [ ]
3. Preinstallation test of single wall tank conducted by pressurizing tank with 3-5 psi air pressure, soaping all surfaces, seams, and fittings and inspecting for bubbles. [ ]
or
Preinstallation test of double-walled tank: pressurize inner tank to a maximum of 5 psi, seal inner tank and disconnect external air supply, monitor for one hour. After one hour, pressurize the interstitial space with a maximum 5 psi air from the inner tank and use a second gauge for monitoring the pressure. Soap all surfaces, seams and fittings and inspect for bubbles. [ ]
4. Tank tested after backfilling through precision test, approved tank gauge or interstitial monitor. [ ]
5. Tank gauge or interstitial monitor verified as operative. [ ]

E. TANK SITE AND BACKFILL

- 1. Tank located a minimum of 3 feet from property lines and 1 foot from buildings. [ ]
2. Tank is spaced a minimum of 2 feet from any other tank. [ ]
3. Backfill for steel or fiberglass clad steel tank is clean, washed, well granulated sand, crushed rock, or pea gravel no larger than 3/4 inch. [ ]
4. Backfill for fiberglass tank is pea gravel naturally round with minimum diameter of 1/8 inch and maximum size of 3/4 inch or crushed rock or gravel between 1/8 and 1/2 inch in size. [ ]
5. Minimum of 1 foot of backfill extended beyond perimeter of tank. [ ]
6. Minimum of 1 foot of compacted backfill in bottom of excavation. (If hold down pads are used, bedding may be reduced to 6 inches.) [ ]
7. Bottom hold down pads used. [ ]
a. Fiberglass tank with 1 foot of compacted backfill over top of pad. [ ]
b. Steel tank with 6 inches of compacted backfill over top of pad. [ ]
8. Backfill material placed over tank to a depth of at least 1 foot. [ ]

**TANK SITE AND BACKFILL (continued)**

Installer Verified    Inspector Verified    NA

- 9. Backfill compaction is adequate to securely and evenly support the tank and prevent movement/settlement.
- 10. Excavation is in a bog, swampy area or landfill and a filter fabric was used to prevent the migration of the backfill material.
- 11. Tank in area of vehicle traffic, 3 feet of earth cover or 18 inches of earth plus 6 inches of reinforced concrete or 8 inches of asphalt.
- 12. Tank in area not subject to traffic, a minimum of 2 feet of earth or 1 foot of earth plus 4 inches of reinforced concrete or 6 inches of asphalt.

**F. TANK ANCHORAGE**

- 1. Installation is in an area of high water table or subject to flooding and tank is anchored.   
  - a. Anchor straps for fiberglass tank were nonmetallic and were placed according to manufacturer's specifications.
  - b. Anchor straps for steel tank were either nonmetallic or electrically isolated from the tank structure. (All metal fittings are protected from corrosion.)
  - c. Mid anchoring with non conductive material between tank and concrete.

**G. PIPING (Indicate whether piping is Fiberglass; Steel; or Flexible; then check one of the types below before proceeding to answer 1-15).**

- Pipe installation is vapor recovery pipe only.
- Pressurized piping with  auto shutoff,  alarm or  flow restrictor.
- Suction piping with check valve at tank.  Suction piping with check valve at pump and inspectable.
- 1. Piping is sloped back to tank (1/8 inch per foot).
- 2. Piping is evenly and adequately supported by at least 6 inches of backfill bedding.
- 3. Piping trench provides at least 18 inches of compacted backfill and paving on top of piping.
- 4. Pipes are separated by at least twice the pipe diameter.
- 5. Pipes are separated from the trench excavation sidewalls by at least 6 inches.
- 6. Piping inspected for damage to pipe or coating.
- 7. Metal piping is at least schedule 40 black steel or galvanized pipe, and is wrapped or coated.
- 8. Fittings and couplings are extra-heavy malleable iron screw-type, Schedule 40 or better.
- 9. Piping was isolated from the tank and dispenser and tested at 150% of operating pressure of the system (but not less than 50 psi) for 1 hour prior to and after backfilling.
- 10. Secondary containment piping was tested for tightness before it was covered, enclosed or placed in use. For rigid secondary piping test at 10 psi.     
For flexible secondary piping, test at manufacturers' recommendation: 5 psi.
- 11. After backfilling, piping was isolated from the tank and dispenser and precision tested at 110% of operating pressure but not less than 50 psi for 1 hour.
- 12. Piping was isolated from the tank and dispenser and tested through another approved means prior to and after backfilling. Indicate method(s) prior \_\_\_\_\_ after \_\_\_\_\_
- 13. Metal piping protected from corrosion by  cathodic protection or  operational impressed current
- 14. Test stations have been installed for monitoring cathodic protection on piping.
- 15. Flexible connectors are used at the top of tank, between tank and vent pipe, below the dispenser and also where less than 4 feet of run exists between changes in direction with fiberglass piping.
- 16. Dispensers, pumps, check valves, etc., not cathodically protected are electrically isolated from metallic piping.

**H. PRIMARY LEAK DETECTION (Check which applies under both TANK and PIPING)**

- 1. Tank
  - Tightness testing and inventory control     Automatic tank gauging     Vapor monitoring     Groundwater monitoring
  - Interstitial monitoring     Manual tank gauging (only for tanks of 1,000 gallons or less)
- 2. Piping (pressurized or suction with check valve at tank) Pipe installation is:  single wall,  double walled.
  - Tightness testing     Automatic line leak detectors     Vapor monitoring
  - Groundwater monitoring     Interstitial monitoring

**I. INSPECTOR INFORMATION**

Inspection Dates: \_\_\_\_\_

Inspector Signature: \_\_\_\_\_ Inspector #: \_\_\_\_\_ Local Operator #: \_\_\_\_\_

Date Signed: \_\_\_\_\_ Fire department providing coverage: \_\_\_\_\_ FDID #: \_\_\_\_\_

**J. INSTALLER CERTIFICATION**

I certify that the tank and related piping was installed according to the manufacturers' instructions and comply with one of the following standards:  API 1615,  PEI RP100 or  ANSI B31.4.

Installer Signature: Triff Wilber Date Signed: 12-3-98

TANK INVENTORY FORMERS-7437 SIGNED BY THE OWNER MUST BE SUBMITTED WITH EACH INSTALLATION CHECKLIST.

Reg Obj #: 300400160

# UNDERGROUND

## FLAMMABLE/COMBUSTIBLE LIQUID STORAGE TANK INVENTORY

Information Required By Section 101.142, Wis. Stats.

Send Completed Form To:  
Department of Commerce  
Bureau of Storage Tank Regulation  
P.O. Box 7837  
Madison, WI 53707-7837

Underground tanks in Wisconsin that have stored or currently store petroleum or regulated substances must be registered. A separate form is needed for each tank. Send each completed form to the agency designated in the top right corner. Have you previously registered this tank by submitting a form?  Yes  No If yes, are you correcting/updating information only?  Yes  No Personal information you provide may be used for secondary purposes. [Privacy Law, s. 15.04 (1)(m)]

<input type="checkbox"/> In Use <input type="checkbox"/> Newly Installed <input type="checkbox"/> Abandoned with Product <input type="checkbox"/> Abandoned without Product (empty)		<input type="checkbox"/> Closed - Tank Removed <input type="checkbox"/> Closed - Filled with Inert Materials <input type="checkbox"/> Temporary Out of Service - Provide Date: _____ <input type="checkbox"/> Abandon with Water		<input type="checkbox"/> Ownership Change (Indicate new owner name in block 2) <input type="checkbox"/> Fire Department providing fire coverage where tank is located: <input type="checkbox"/> City <input checked="" type="checkbox"/> Village <input type="checkbox"/> Town of <u>Pleasant Prairie</u>	
--	--	---	--	--	--

**A. IDENTIFICATION (Please Print)**

1. Tank Site Name <u>Pleasant Prairie Power Plant</u>		Site Address <u>8000 95th Street</u>		Site Telephone Number <u>( )</u>	
<input type="checkbox"/> City	<input checked="" type="checkbox"/> Village	<input type="checkbox"/> Town of:	State <u>WI</u>	Zip Code <u>53142</u>	County <u>Kenosha</u>
2. Tank Owner Name <u>Wisconsin Electric</u>		Mailing Address <u>333 W. Everett St</u>		Telephone Number <u>(414) 947-5316</u>	
<input checked="" type="checkbox"/> City	<input type="checkbox"/> Village	<input type="checkbox"/> Town of:	State <u>WI</u>	Zip Code <u>53201</u>	County <u>Milwaukee</u>
3. Previous Name		Previous site address if different than #1			
Site ID #: <u>154767</u>		Facility ID #: <u>154767</u>		Customer ID #: <u>382951</u>	

**C. 4. Tank Age (age or date installed):** \_\_\_\_\_ **5. Tank Capacity (gallons):** \_\_\_\_\_

**D. LAND OWNER TYPE (check one)**

<input type="checkbox"/> County	<input type="checkbox"/> Federal Leased	<input type="checkbox"/> Federal Owned	<input type="checkbox"/> Municipal	<input type="checkbox"/> Other Government
<input type="checkbox"/> Private	<input type="checkbox"/> State	<input type="checkbox"/> Tribal Nation		

**E. OCCUPANCY TYPE (check one)**

<input type="checkbox"/> Gas/Retail Sales	<input type="checkbox"/> Bulk Storage	<input checked="" type="checkbox"/> Utility	<input type="checkbox"/> Mercantile/Commercial	<input type="checkbox"/> Industrial	<input type="checkbox"/> School	<input type="checkbox"/> Residential
<input type="checkbox"/> Agricultural	<input type="checkbox"/> Backup or Emergency Generator	<input type="checkbox"/> Other (Specify):				

**F. Tank Construction:**

<input type="checkbox"/> Bare Steel	<input type="checkbox"/> Coated Steel	<input type="checkbox"/> Unknown	<input type="checkbox"/> Cathodic Protection	Overfill Protection? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
<input type="checkbox"/> Fiberglass	<input type="checkbox"/> Steel - Fiberglass Reinforced Plastic Composite		<input type="checkbox"/> Sacrificial Anodes	Spill Containment? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
<input checked="" type="checkbox"/> Lined (Date):	<input type="checkbox"/> Other (specify):		<input type="checkbox"/> Impressed Current	Tank Double Walled? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
			<input type="checkbox"/> N/A	

**G. Primary Tank leak detection method:**

<input type="checkbox"/> Inventory control and tightness testing	<input checked="" type="checkbox"/> Automatic tank gauging <u>G-Ibarco EM</u>	<input type="checkbox"/> Groundwater monitoring
<input type="checkbox"/> Manual tank gauging (only for tanks of 1,000 gallons or less)	<input type="checkbox"/> Interstitial monitoring	<input type="checkbox"/> Vapor monitoring
	<input type="checkbox"/> Statistical Inventory Reconciliation (SIR)	<input type="checkbox"/> Unknown

**Piping Construction:**

<input type="checkbox"/> Bare Steel	<input checked="" type="checkbox"/> Coated Steel	<input type="checkbox"/> Unknown	<input type="checkbox"/> Cathodic Protection	Pipe Double Walled? <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No
<input type="checkbox"/> Fiberglass	<input checked="" type="checkbox"/> Flexible	<input type="checkbox"/> N/A	<input type="checkbox"/> Sacrificial Anodes	<u>APT</u> <u>FRP</u>
<input checked="" type="checkbox"/> Other (specify): <u>#1/Vent</u>	<u>#2+3</u>		<input type="checkbox"/> Impressed Current	
			<input type="checkbox"/> N/A	

**Primary Piping System Type:**  Pressurized piping with 588 p.w.  A. auto shutoff;  B. alarm or  C. flow restrictor  Unknown  Not needed if waste oil

Suction piping with check valve at tank  Suction piping with check valve at pump and inspectable

**J. Piping Leak Detection Method: (used if pressurized or check valve at tank):**

<input type="checkbox"/> Groundwater monitoring	<input type="checkbox"/> Vapor monitoring	<input type="checkbox"/> Interstitial monitoring	<input type="checkbox"/> Not required <u>X3</u>	<input type="checkbox"/> Electronic line leak monitor	<input type="checkbox"/> Unknown
---	---	--	---	---	----------------------------------

**Vapor Recovery/Stage II CARB #:** \_\_\_\_\_  Fiberglass  Other (specify): NA  Flexible  Operational - Provide Date (mo/day/yr):

**TANK CONTENTS (Current, or previous product if tank now empty)**

<input checked="" type="checkbox"/> Diesel	<input type="checkbox"/> Leaded	<input type="checkbox"/> Unleaded	<input type="checkbox"/> Fuel Oil	<input type="checkbox"/> Gasohol
<input type="checkbox"/> Other (Specify):	<input type="checkbox"/> Empty	<input type="checkbox"/> Sand/Gravel/Slurry*	<input type="checkbox"/> Unknown*	<input type="checkbox"/> Premix
<input type="checkbox"/> Waste/Used Motor Oil	<input type="checkbox"/> Chemical _____	<input type="checkbox"/> Kerosene	<input type="checkbox"/> Aviation	<input type="checkbox"/> Hazardous Waste*

(Indicate chemical name and number)

If chosen, this tank is NOT PECFA eligible.

If Tank Closed, Abandoned or Out of Service, give date (mo/day/yr):

Geo Latitude: \_\_\_\_\_ Geo Longitude: \_\_\_\_\_

Has a site assessment been completed (see reverse side for details)  
 Yes  No

**Owner or Operator Name (please print):** Liz Mullane

Indicate whether:  
 Owner or  Operator

**Owner or Operator Signature:** Liz Mullane

Date Signed: 11/16/98

Note: Refer to comments on reverse side of form.

6-7437 (R. 04/98)  
\* Existing PLD (2+3)



ENVIROSCAN SERVICES  
301 WEST MILITARY ROAD  
ROTHSCHILD, WI 54474

TELEPHONE 715-359-7226  
FACSIMILE 715-355-3221

D4-

*Locomotive  
Refueling  
Area*

November 4, 1998

STS Consultants Ltd.  
11425 W. Lake Park Dr.  
Milwaukee, WI 53224

Attn: Ken Yass

Re: 85863XA

Please find enclosed the analytical results for the samples received October 29, 1998.

The chain of custody document is enclosed.

If you have any questions about the results, please call. Thank you for using US Filter/Enviroscan for your analytical needs.

Sincerely,

US Filter/Enviroscan

Dominic J. Bush  
Senior Analytical Chemist



STS Consultants Ltd.  
11425 W. Lake Park Dr.  
Milwaukee, WI 53224

CUST NUMBER: 85863XA  
SAMPLED BY: Client  
DATE REC'D: 10/29/98  
REPORT DATE: 11/04/98  
PREPARED BY: DJB  
REVIEWED BY: *H.M.*

Attn: Ken Yass

	<u>Units</u>	<u>Reporting Limit</u>	<u>S-1 10/22/98</u>	<u>Qualifiers</u>	<u>Date Analyzed</u>	<u>By</u>
<u>MOSA21-2</u>						
Total Solids	%	-	92.0		11/02/98	LMW
<u>WI DNR</u>						
Soil Diesel Range Organics	mg/kg	5.4	8.35	D1 D4	11/02/98	DJB
Soil Org Ext - DRO		-	COMP		11/02/98	CKV

Analytical No.: 53520

	<u>Units</u>	<u>Reporting Limit</u>	<u>S-2 10/22/98</u>	<u>Qualifiers</u>	<u>Date Analyzed</u>	<u>By</u>
<u>MOSA21-2</u>						
Total Solids	%	-	92.6		11/02/98	LMW
<u>WI DNR</u>						
Soil Diesel Range Organics	mg/kg	5.4	10.4	D1 D4	11/02/98	DJB
Soil Org Ext - DRO		-	COMP		11/02/98	CKV

Analytical No.: 53521


Results calculated on a dry weight basis.

**Qualifier Descriptions**


- D1 The chromatogram is characteristic for a fuel oil/diesel. (i.e. #1 or #2 Diesel, jet fuel, kerosene, aged or degraded diesel, etc.)
- D4 The chromatogram contained significant peaks outside the DRO window.



Data file: USER\$DISK3:[CHROM.SEMI.GC7B]13DROZ148  
 Report: 787299  
 Required: 2-NOV-1998 21:10:00  
 Time range: 0.00-26.20  
 Vert. scale/offset: 1.0/0



Data file: USER\$DISK3:[CHROM.SEMI.GC7B]13DROZ149  
 Report: 787313  
 Acquired: 2-NOV-1998 21:44:22  
 Time range: 0.00-26.20  
 Vert. scale/offset: 1.0/0



# CHAIN OF CUSTODY RECORD

No 27272



Contact Person Ken Yass  
 Phone No. 414-359-3030 Office Milwaukee  
 Project No. 85863XA PO No. \_\_\_\_\_  
 Project Name WE-P4 Piping

Special Handling Request	
<input type="checkbox"/>	Rush
<input type="checkbox"/>	Verbal
<input type="checkbox"/>	Other

RECORD NUMBER \_\_\_\_\_ THROUGH \_\_\_\_\_

Laboratory \_\_\_\_\_  
 Contact Person \_\_\_\_\_  
 Phone No. \_\_\_\_\_  
 Results Due \_\_\_\_\_

Sample I.D.	Date	Time	Grab	Composite	No. of Containers	Sample Type (Water, soil, air, sludge, etc.)	Preservation		Field Data				Analysis Request	Comments on Sample (Include Major Contaminants)
							Y	N	PID/FID		PH	Special Cond.		
									Ambient	Sample				
S-1	10/22		X		2	Soil	X		18053	520		DRO	Sildro	
S-2	10/22		X		2	"	X		18053	521		DRO		

Collected by: <u>Ken W. Yass</u>	Date <u>10/22/98</u>	Time	Delivery by:	Date	Time
Received by:	Date	Time	Relinquished by:	Date	Time
Received by:	Date	Time	Relinquished by:	Date	Time
Received by:	Date	Time	Relinquished by:	Date	Time
Received for lab by: <u>Susan M. Anders</u>	Date <u>10-29-98</u>	Time <u>9:35</u>	Relinquished by:	Date	Time

Laboratory Comments Only: Seals Intact Upon Receipt?  Yes  No  N/A on ice

Final Disposition:	Comments (Weather Conditions, Precautions, Hazards):
	<u>Samples on Ice</u>
	<u>STSmil</u> <u>6662</u> <u>210253</u> <u>11.12</u>

Distribution: Original and Green - Laboratory Yellow - As needed Pink - Transporter Goldenrod - STS Project File  
 Instructions to Laboratory: Forward completed original to STS with analytical results. Retain green copy.



Wisconsin Electric  
231 W. Michigan  
P.O. Box 2046  
Milwaukee, WI 53201-2046  
Phone 414 221-2345

February 12, 1999

Tank Response Unit-SW/3  
**DEPARTMENT OF NATURAL RESOURCES**  
P.O. Box 7921  
Madison, WI 53707



**RE: CLEAN CLOSURE ASSESSMENT REPORTS**  
**Pleasant Prairie Power Plant, Kenosha WI**  
**Point Beach Nuclear Plant, Two Creeks, WI**

To Tank Response Unit:

Enclosed, please find one copy of the following reports:

- Piping Replacement Report, Locomotive Refueling Area, January 27, 1999
- UST Site Assessment, Point Beach Nuclear Plant, January 27, 1999

Both reports show no contamination from the respective removals of tank and/or piping.

If you have any questions, please feel free to contact me at 414-221-4853.

Sincerely,

A handwritten signature in cursive that reads 'Liz Stueck-Mullane'.  
Liz Stueck-Mullane  
Senior Environmental Specialist

enclosures

cc: Larry Gauthier-PBNP w/enclosure  
Peter Zingelman-PPPP w/out enclosure