

June 16, 2020 – Phone Conference with Josie Schultz (DNR), Jim Walden (DNR vapor expert), Paul Killian (GEI Consultants), Jason Sladky (City of Green Bay Plumbing inspector)

- City of Green Bay able to bring televising truck to the site and dye different drains to see where sanitary laterals go to.
 - o They should be able to perform this within 2 weeks
 - o Will work with Paul Killian on this – provided his email and phone number to Jason Sladky
- Believe all sumps discharge to the sanitary sewer
- Northwest sump runs frequently
- 48-inch sump is located beneath the stairs in the basement
- Paul Killian to sample sump water
- Two sumps along east wall appear to be dry, and are sanitary ejector pits
- Paul Killian planning to perform HVAC audit for air exchange and handling on all tenant spaces
- Blower fan for piping runs beneath the slab-on-grade portion of the building is no longer running
 - o Bad bearings on the fan
 - o Paul said should be fixed by the end of next week
- Jason Sladky said Jim's Music had approximately 10 people in the store when he did a site visit a couple weeks ago
 - o Employees working in the basement
 - o Looked like they were preparing to accept music lessons.
- South portion of basement is wet – probably contributing to vapor issue