



Barron County Highway Dept.  
Jerry Pich  
250 N 7<sup>th</sup> Street  
Barron, WI. 54812

Subject: GIS Registry Site Well Approval for Bents Motors 1872 Hwy 63 Comstock, WI.

Dear Mr. Pich:

On July 11, 2018, I received an application to construct a well at your GIS listed property (description above). The residual contamination at the site was Petroleum Volatile Organic Compound concentrations above the Maximum Contaminant Level from fuel storage tanks on the property. The following is the written approval to allow the construction of a water supply well at 1872 Hwy 63 Comstock, WI.

The Department of Natural Resources has received and reviewed your request to drill a well on a GIS listed property. The Department is authorized by Wisconsin Statute chapters 280 and 281 to have general supervision and control over the waters of the state and to establish and enforce standards and rules for obtaining drinking water and protecting public health against polluted water supplies. Wisconsin Administrative Code ch. NR 812, is adopted pursuant to that authority.

Wis. Admin. Code ch. NR NR812.10(2), requires a DNR approval to construct a well on a GIS listed property.

According to the information you supplied, the property in question is located in the SE1/4 of the NE1/4 of Section 34, T35N, R14E, Comstock, Barron County.

A review of the well construction reports and documents in the GIS files indicate that residual soil and groundwater contamination is present across the property. A Department-approval does not guarantee acceptable water quality or quantity.

Approval is hereby granted for the construction of a water supply well on the above-described property, but subject to the following conditions.

1. That the well is located in the location shown on the site map submitted with the application.
2. That the well is constructed with steel well casing that terminates in bedrock. The anticipated depth to sandstone bedrock is between 140 and 170 feet below ground surface.
3. That a water sample is collected after the well is completed and submitted to a laboratory for Volatile Organic Compound analysis.
4. That all future property owners be given a copy of this approval prior to the time of the property transfer.

This approval is granted based on information provided to the Department by the well owner and a licensed well driller or pump installer. The information provided to the Department is assumed to be accurate and this approval is granted based on that information. This approval is not intended nor should it be deemed as a guarantee that the well and pump installation are in compliance with the Wisconsin Well and Pump Installation Code, Wis.

Admin. Code ch. NR 812, nor does it guarantee that the system will produce acceptable water quality or quantity. This approval is for the specific code provision or provisions identified above.

Failure to comply with any term or conditions of this approval voids the approval. You are also responsible for acting in compliance with all other applicable statutory and administrative code requirements.


#### NOTICE OF APPEAL RIGHTS

If you believe that you have a right to challenge this decision, you should know that the Wisconsin statutes and administrative rules establish time periods within which requests to review Department decisions must be filed. For judicial review of a decision pursuant to sections 227.52 and 227.53, Wis. Stats., you have 30 days after the decision is mailed, or otherwise served by the department, to file your petition with the appropriate circuit court and serve the petition on the department. Such a petition for judicial review must name the DNR as the respondent.

To request a contested case hearing pursuant to section 227.42, Wis. Stats., you have 30 days after the decision is mailed, or otherwise served by the department, to serve a petition for hearing on the Secretary of the DNR. All requests for contested case hearings must be made in accordance with section NR 2.05(5), Wis. Adm. Code, and served on the Secretary in accordance with section NR 2.03, Wis. Adm. Code. The filing of a request for a contested case hearing does not extend the 30-day period for filing a petition for judicial review.

If you have any questions, please feel free to call me at 715-416-3331 or email me at [Jacob.sedivy@wisconsin.gov](mailto:Jacob.sedivy@wisconsin.gov)

Sincerely,

A handwritten signature in black ink that reads "Jacob Sedivy". The signature is written in a cursive, flowing style.

Jacob Sedivy  
Water Supply Specialist