



---

444 21<sup>st</sup> Street South · La Crosse, Wisconsin · 54601

June 17, 2019

Ms. Linda Michaelets  
Wisconsin Department of Natural Resources  
2300 North Dr. Martin Luther King Drive  
Milwaukee, WI 53212

Subject: Milwaukee Plating, Inc.  
1434 North 4<sup>th</sup> Street  
Milwaukee, WI 53212  
BRRTS No. 03-41-000762  
PECFA No. 53212-3888-34

Dear Linda:

Attached is a photo of the sump located in the lowest level of the Milwaukee Plating Facility at the above mentioned address. The photo was taken on June 11, 2019.

The sump is surrounded by the concrete floor with a lip that extends about 2 inches above the surrounding floor slab. The sump crock is constructed of concrete. The sump is covered with two pieces of concrete that fit together and fit inside the top of the sump crock.

I was told by the plant manager, that the sump is often if not always dry as water does not accumulate in the crock. At the time of the visit it was dry to the bottom which is about 24 inches below the lowest floor slab elevation.

We hope this photograph and description enable you to properly evaluate the potential concerns over this feature.

If you have any questions, I can be reached at 414-916-1413.

Regards,

William F Kralj PE

Attachment – Sump Pump Photo

ATTACHMENT A - PHOTO

Photo 1: Sump Pump – Milwaukee Plating

