



State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES

Tommy G. Thompson, Governor
George E. Meyer, Secretary
William H. Smith, Regional Director

Northern Region Headquarters
810 W. Maple Street
Spooner, Wisconsin 54801
Telephone 715-635-2101
FAX 715-635-4105
TDD 715-635-4001

September 9, 1999

Kelly Grimes
Mac Lake Tavern
N10202 Hwy K
Trego, WI 54888

Subject: Water Sample Results – PWS # 86605035

Dear Ms. Grimes:

On August 23, 1999, I collected a water sample from the well serving the above facility. The sample was analyzed for the presence of Volatile Organic Compounds (VOC's). VOC's are common components of solvents, cleaners, degreasers, and fuels.

I have enclosed a copy of the lab results. At the time of sampling, there were no detects of any of the compounds that were analyzed. Your water therefore meets state and federal drinking water standards for VOC's.

If you have any questions regarding the enclosed results, please contact me at 715/635-4054.

Sincerely,

Nadene Cable
Drinking Water & Groundwater Specialist

cc: Public Water Section - DG/2
Jamie Dunn - Spooner