

## **Jorgensen, Theadora O - DNR**

---

**From:** David Storey <rctinc@outlook.com>  
**Sent:** Tuesday, March 5, 2019 10:44 AM  
**To:** Egan, Alice M - DNR  
**Cc:** raghuom@gmail.com  
**Subject:** Re: Part A and Photos for Bayside Service, 310 East Brown Deer Road, Bayside

The tanks were in excellent condition as all sti P3 tanks are when removed; all that I've seen anyway. I forwarded the pictures to Raghu, but I'll include them in this message as well.





VAPOR  
FREE



Lan  
Ton

3  
SECTION

5/30/18



VAPOR  
FREE

5/30/18







Let me know if you need anything else.

Thanks,

David  
RCT Petroleum  
414.248.7748

On Mar 5, 2019, at 10:27 AM, Egan, Alice M - DNR <[Alice.Egan@wisconsin.gov](mailto:Alice.Egan@wisconsin.gov)> wrote:

Hi David,

Thank you for Part A. Several pictures of the tanks would be helpful to see the condition of the tanks.

Alice

---

**From:** David Storey <[rctinc@outlook.com](mailto:rctinc@outlook.com)>  
**Sent:** Tuesday, March 5, 2019 9:52 AM  
**To:** Raghu B Singh  
**Cc:** Egan, Alice M - DNR  
**Subject:** RE: Part A and Photos for Bayside Service, 310 East Brown Deer Road, Bayside

Please see part A attached.

What pictures do you require? I may have to send them each in a separate email if they turn out to be too big to send all at once.

Thanks,

David

---

**From:** Raghu B Singh <[raghuom@gmail.com](mailto:raghuom@gmail.com)>  
**Sent:** Monday, March 4, 2019 11:19:25 AM  
**To:** [rctinc@outlook.com](mailto:rctinc@outlook.com)  
**Cc:** [Alice.Egan@wisconsin.gov](mailto:Alice.Egan@wisconsin.gov)  
**Subject:** Part A and Photos for Bayside Service, 310 East Brown Deer Road, Bayside


Good Morning Dave:

As discussed with you and petroleum inspector, I sent Part B to the inspector and you.

Please email Part A and Photos to Alice of the WDNR.

Thank you

Raghu



Wisconsin Department of Agriculture, Trade and Consumer Protection  
 Bureau of Weights and Measures  
 P.O. Box 7837, Madison, WI 53707-7837  
 (608) 224-4942

Wis. Admin. Code §ATCP 93.560

FOR OFFICE USE ONLY
---------------------

# TANK SYSTEM SERVICE AND CLOSURE ASSESSMENT REPORT

Personal information you provide may be used for purposes other than that for which it was originally collected (s. 15.04(1)(m) Wis. Stats.).

Complete One Form for Each System Service Event

FOR PORTIONS OF THE FORM THAT DO NOT APPLY, CHECK THE 'N/A' BOX

CHECK ONE:  UNDERGROUND  ABOVEGROUND

## Part A - To be completed by contractor performing repair or closure

A. TYPE OF SERVICE  CLOSURE  REPAIR/UPGRADE  CHANGE-IN-SERVICE

Indicate portion of system being serviced if a repair, upgrade or change-in-service is being performed

Remote fill  Tank  Piping  Transition/containment sump  Spill bucket  Dispenser

## B. IDENTIFICATION

### OWNER INFORMATION

OWNER NAME <i>Bayside Service</i>	CONTACT NAME <i>Oscar Moncada</i>	TITLE <i>owner</i>
MAILING ADDRESS <i>310 E Brown Deer Road</i>	<input type="checkbox"/> CITY <input type="checkbox"/> TOWN <input checked="" type="checkbox"/> VILLAGE <i>Bayside</i>	STATE ZIP <i>WI 53217</i>
TELEPHONE: <i>(262) 617 2174</i>	E-MAIL <i>oscarmotorcars@yahoo.com</i>	

### SITE INFORMATION

FACILITY NAME <i>Bayside Service</i>		
SITE ADDRESS (Not PO Box) <i>310 E Brown Deer Road</i>	<input type="checkbox"/> CITY <input type="checkbox"/> TOWN <input checked="" type="checkbox"/> VILLAGE <i>Bayside</i>	STATE ZIP <i>WI 53217</i>

### SERVICE CONTRACTOR INFORMATION

PRIMARY SERVICE CONTRACTOR Section A Above <i>RCT Petroleum</i>	TELEPHONE: ( ) -	CELL: <i>414 248 7748</i>
STREET ADDRESS <i>3845 W. Forest Home Ave</i>	<input checked="" type="checkbox"/> CITY <input type="checkbox"/> TOWN <input type="checkbox"/> VILLAGE <i>Milwaukee</i>	STATE ZIP <i>WI 53215</i>

## C. TANK SYSTEM DETAIL (Complete for all service activities)

a	b	c	d	e	f	g	h	
Tank ID #	Type of Closure <sup>1</sup>	Tank Material of Construction	Piping Material of Construction	Tank Capacity (gallons)	Contents <sup>2</sup>	Release - System Integrity Compromised (e.g. holes, cracks, loose connection, etc)?	If "Yes" to "g", Then Specify Source and Cause of Release <sup>3</sup>	
							Source of Release <sup>3</sup>	Cause of Release <sup>4</sup>
<i>295530</i>	<i>P</i>	<i>Coated Steel</i>	<i>FG</i>	<i>8000</i>	<i>UG</i>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
<i>295531</i>	<i>P</i>	<i>Coated steel</i>	<i>FG</i>	<i>4000</i>	<i>UG</i>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
<i>295532</i>	<i>P</i>	<i>Coated steel</i>	<i>Copper</i>	<i>550</i>	<i>FO</i>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
<i>483969</i>	<i>P</i>	<i>Steel</i>	<i>Copper</i>	<i>550</i>	<i>WO</i>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
						<input type="checkbox"/> Yes <input type="checkbox"/> No		
						<input type="checkbox"/> Yes <input type="checkbox"/> No		

- Indicate type of closure: P = Permanent, TOS = Temporarily Out-of-Service, CIP = Closure In-Place
- Indicate type of product: DL = Diesel, LG = Leaded Gasoline, UG = Unleaded Gasoline, FO = Fuel Oil, GH = Gasohol, AF = Aviation Fuel, K = Kerosene, PX = Premix, WO = Waste/Used Motor Oil, FCHZW = Flammable/Combustible Hazardous Waste, OC = Other Chemical (indicate the chemical name(s))
- CAS number(s):
- Source of release: T = tank, P = piping, D = dispenser, STP = submersible turbine pump, DP = delivery problem, O = other, UNK = Unknown
- Cause of release: S = spill, O = overflow, POMD = physical or mechanical damage, C = corrosion, IP = installation problem, O = other, UNK = Unknown
- Has release been reported to the Department of Natural Resources?  Yes  No  Release not evident at this time



**D. CLOSURES (Check applicable box at right in response to all statements in section D)**

Written notification was provided to the local agent 5 days in advance of closure date.  Yes  No

All local permits were obtained before beginning closure.  Yes  No  NA

UST Form TR-WM-137 or  AST Form TR-WM-118 filed by owner with the DATCP indicating closure.  Yes  No  NA

**NOTE: TANK INVENTORY FORM TR-WM-137 or TR-WM-118 SIGNED BY THE OWNER MUST BE SUBMITTED WITH EACH CLOSURE or CHANGE-IN-SERVICE CHECKLIST**

**D.1  TEMPORARILY OUT-OF-SERVICE**

	Remover Verified	Inspector Verified	Inspector Not Present	NA
1. Product removed.				
a. Product lines drained into tank (or other container) and liquid removed, and	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
b. All product removed to bottom of suction line, OR	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
c. All product removed to within 1" of bottom.	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
2. Fill pipe, gauge pipe, tank truck vapor recovery fittings, and vapor return lines capped.	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
3. All product lines at the islands or pumps located elsewhere are removed and capped, OR	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
4. Dispensers/pumps left in place but locked and power disconnected.	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
5. Vent lines left open.	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
6. Inventory form filed indicating temporarily out-of-service (TOS) closure.	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>

**D.2.  CLOSURE BY REMOVAL OR IN-PLACE**

1. General Requirements	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
a. Product from piping drained into tank (or other container).	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
b. Piping disconnected from tank and removed.	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
c. All liquid and residue removed from tank using explosion-proof pumps or hand pumps.	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
d. All pump motors and suction hoses bonded to tank or otherwise grounded.	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
e. Fill pipes, gauge pipes, vapor recovery connections, submersible pumps and other fixtures removed.	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
f. Vent lines left connected until tanks purged.	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
g. Tank openings temporarily plugged so vapors exit through vent.	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
h. Tank atmosphere reduced to 10% of the lower flammable range (LEL) - see Section E.	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>

2. Specific Closure-by-Removal Requirements				
a. Tank removed from excavation after PURGING/INERTING; placed on level ground and blocked to prevent movement.	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
b. Tank cleaned before being removed from site.	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
c. Tank labeled in full compliance with API 1604 after removal but before being moved from site.	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>

**NOTE: COMPLETE TANK LABELING SHOULD INCLUDE WARNING AGAINST REUSE; FORMER CONTENTS; VAPOR STATE; VAPOR FREEING TREATMENT; MONTH/DAY/YEAR OF REMOVAL**

d. Tank vent hole (1/8" in uppermost part of tank) installed prior to moving the tank from site.	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
e. Site security is provided while the excavation is open.	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
3. Specific Closure-In-Place Requirements	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>

**NOTE: CLOSURES IN-PLACE ARE ONLY ALLOWED WITH THE PRIOR WRITTEN APPROVAL OF THE DEPARTMENT OF AGRICULTURE, TRADE AND CONSUMER PROTECTION (DATCP) OR LOCAL AGENT.**

a. Tank properly cleaned to remove all sludge and residue.	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
b. Solid inert material (sand, cyclone boiler slag, or pea gravel recommended) introduced and tank filled.	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
c. Vent line disconnected or removed.	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>
d. Inventory form filed by owner with the DATCP indicating closure in-place.	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/> Y <input type="checkbox"/> N	<input type="checkbox"/>	<input type="checkbox"/>

**E.  REPAIR, UPGRADE OR CHANGE-IN-SERVICE**

Written notification was provided to the local agent 5 days in advance of service date.  Y  N  NA

All local permits were obtained before beginning service.  Y  N  NA

Form TR-WM-137 or 0 TR-WM-118 filed by owner with the DATCP indicating change-in-service.  Y  N  NA

**F. METHOD OF VAPOR FREEING OF TANK**

Displacement of vapors by eductor or diffused air blower.

Eductor driven by compressed air, bonded and drop tube left in place; vapors discharged minimum of 12 feet above ground.

Inert gas using dry ice or liquid carbon dioxide.

Inert gas using CO2 or N2 **NOTE: INERT GASSES PRODUCE AN OXYGEN DEFICIENT ATMOSPHERE. LEL METERS MAY NOT FUNCTION ACCURATELY. THE TANK MAY NOT BE ENTERED IN THIS STATE WITHOUT SPECIAL EQUIPMENT.**

Gas introduced through a single opening at a point near the bottom of the tank at the end of the tank opposite the vent.

Gas introduced under low pressure not to exceed 5 psig to reduce static electricity. Gas introducing device grounded.

Readings of 10% or less of the lower flammable range (LEL) or <5% oxygen obtained before removing tank from ground.

Tank atmosphere monitored for flammable or combustible vapor levels prior to and during cleaning and cutting.

Calibrate combustible gas indicator and/or oxygen meter prior to use. Drop tube removed prior to checking atmosphere. Tank space monitored at bottom, middle and upper portion of tank.


G. REMOVER/CLEANER INFORMATION

David Storey		466386	31 MAY 18
REMOVER/CLEANER NAME (PRINT):	REMOVER/CLEANER SIGNATURE	CERTIFICATION NO	DATE SIGNED

I attest that the procedures and information which I have provided as the tank closure contractor are correct and comply with ATCP 93.

Company expected to perform soil contamination assessment

H. INSPECTOR INFORMATION

Biera		71655	
INSPECTOR NAME (PRINT):	INSPECTOR SIGNATURE	INSPECTOR CERTIFICATION NO	LPO AGENCY #

4008		268 227 4227	5/31/18
FDID # FOR LOCATION WHERE INSPECTION PERFORMED		INSPECTOR TELEPHONE NUMBER	DATE SIGNED

INSPECTOR NOTES:

X Dierce & Safe Sult. Con  
 X Remove 305T / 1 AST  
 See Email for Alisha Ref Additional Tank  
 Pipings



Wisconsin Department of Agriculture, Trade and Consumer Protection  
 Bureau of Weights and Measures  
 PO Box 7837 Madison, WI 53707-7837  
 (608) 224-4942

FOR OFFICE USE ONLY

TDID#:  
 Reg Obj #:  
 Wis. Admin. Code §ATCP 93.140

### UNDERGROUND FLAMMABLE/COMBUSTIBLE/HAZARDOUS LIQUID STORAGE TANK REGISTRATION

Personal information you provide may be used for purposes other than that for which it was originally collected (s. 15.04(1)(m) Wis. Stats.).

Underground tanks in Wisconsin that have stored or currently store petroleum or regulated substances must be registered. A separate form is needed for each tank. Send each completed form to the agency designated above. Have you previously registered this tank by submitting a form?  Yes  No

If yes, are you correcting/updating information only?  Yes  No

This registration applies to a tank status that is (check one):

- In Use  
 Newly Installed  
 Abandoned with Product  
 Abandoned with Product  
 Abandoned with Product (empty)  
 Abandon with Water  
 Closed - Tank Removed  
 Closed - Filled with Inert Materials  
 Ownership Change (Indicate new owner name in block 2 - attach deed)  
 Temporarily Out of Service - Provide Date:

Fire Dept. providing fire coverage where tank is located:  CITY  TOWN  VILLAGE 4008 BAYSIDE PUBLIC SAFE

<b>IDENTIFICATION (Please Print)</b>			
1. TANK SITE NAME BAYSIDE SERVICE LLC		COUNTY MILWAUKEE	PHONE (262) 617 - 2174
SITE STREET ADDRESS 310 E BROWN DEER RD		<input type="checkbox"/> CITY <input checked="" type="checkbox"/> VILLAGE <input type="checkbox"/> TOWN OF: BAYSIDE	STATE ZIP WI 53217
2. TANK OWNER LEGAL NAME BAYSIDE SERVICE LLC		COUNTY MILWAUKEE	PHONE: Check <input checked="" type="checkbox"/> CELL or <input type="checkbox"/> LAND (262) 617 - 2174
MAILING ADDRESS 310 E BROWN DEER RD		<input type="checkbox"/> CITY <input checked="" type="checkbox"/> VILLAGE <input type="checkbox"/> TOWN OF: BAYSIDE	STATE ZIP WI 53217
3. PROPERTY OWNER NAME (if different from Tank Owner Legal Name #2)		COUNTY (if different from County #2)	
PROPERTY OWNER ADDRESS (if different from Site Street Address #1)		<input type="checkbox"/> CITY <input type="checkbox"/> VILLAGE <input type="checkbox"/> TOWN OF:	STATE ZIP WI
4. CLASS A NAME	DOB	CERTIFICATION: (Attach certificate)	
5. CLASS B NAME	DOB	CERTIFICATION: (Attach certificate)	

SITE ID: FACILITY ID # 83776 CUSTOMER ID # 1142915

Tank Capacity (gallons): 550 Tank Age (age or date installed): 10/01/1990 Vehicle fueling:  Yes  No

LAND OWNER TYPE (check one) Refer to back

County  State  Federal Leased  Federal Owned  Tribal Nation  Municipal  Other Government  Private

OCCUPANCY TYPE (check one) Refer to back

Retail Fuel Sales  Mercantile/Commercial  Industrial  Residential  School  Utility  Government Fleet  
 Agricultural (crop or livestock production)  Backup or Emergency Generator  Other (specify):

TANK CONSTRUCTION:

Bare Steel  Coated Steel  Steel - Fiberglass Reinforced Plastic Composite  
 Fiberglass  Unknown  Other (specify):  Lined (date):

Overfill Protection?  Yes  No  
 Spill Containment?  Yes  No  
 Tank Double Walled?  Yes  No

TANK CATHODIC PROTECTION:  Sacrificial Anodes  Impressed Current  N/A

PRIMARY TANK LEAK DETECTION METHOD:  Automatic tank gauging  Interstitial monitoring ⇒ Electronic  Yes  No  Inventory control and tightness testing

Manual tank gauging (only for tanks of 1,000 gallons or less)  Statistical Inventory Reconciliation (SIR)  Unknown

PIPING CONSTRUCTION:  Single Wall  Double Wall:

Bare Steel  Coated Steel  Fiberglass  Flexible  Copper  Unknown  N/A  Other:

PIPING CATHODIC PROTECTION:  Sacrificial Anodes  Impressed Current  N/A

PRIMARY PIPING SYSTEM TYPE:  Pressurized piping with ⇒  A. Pump auto shutoff - ELLD  B. Flow restrictor - MLLD  Unknown

Suction piping with check valve at tank  Suction piping with check valve at pump and inspectable  Not needed if waste oil

PIPING LEAK DETECTION METHOD:  Interstitial monitoring ⇒ Electronic  Yes  No ⇒ Sump or cable sensor  Yes  No

Tightness testing  Electronic line monitor - ELLD  SIR  Not required  Unknown

TANK CONTENTS (Current, or previous product (if tank now empty))

Bio-Diesel: \_\_\_ %  Aviation  Premix  Fuel Oil  Kerosene  New Oil  Gas-ethanol blend: \_\_\_ %  Diesel  
 Waste/Used Motor Oil ⇒  Used for Heating  Hazardous Waste/Interface\*  Empty\*  Sand/Gravel/Slurry\*  Unknown  
 Other (specify):  Chemical\* Name CAS#

\* NOT PECFA eligible. Geo Latitude: Geo Longitude:

If Tank Closed, Abandoned or Out of Service: Has a site assessment been completed? (see reverse side for details)  Yes  No

TANK OWNER LEGAL NAME (please print) TANK OWNER E-MAIL

Oscar A. Moncaga OSCAR.MONCAGA@YAHOO.COM

TANK OWNER SIGNATURE (Note: By signing, signer is accepting legal and financial responsibility for the storage tank system.) DATE:

Oscar A. Moncaga 29MAY18

Note: Refer to comments on reverse side of form.



Wisconsin Department of Agriculture, Trade and Consumer Protection  
Bureau of Weights and Measures  
PO Box 7837 Madison, WI 53707-7837  
(608) 224-4942

FOR OFFICE USE ONLY  
TDID#:  
Reg Obj #:  
Wis. Admin. Code §ATCP 93.140

### UNDERGROUND FLAMMABLE/COMBUSTIBLE/HAZARDOUS LIQUID STORAGE TANK REGISTRATION

Personal information you provide may be used for purposes other than that for which it was originally collected (s. 15.04(1)(m) Wis. Stats.).

Underground tanks in Wisconsin that have stored or currently store petroleum or regulated substances must be registered. A separate form is needed for each tank. Send each completed form to the agency designated above. Have you previously registered this tank by submitting a form?  Yes  No

If yes, are you correcting/updating information only?  Yes  No

This registration applies to a tank status that is (check one):  
 In Use  Abandoned with Product (empty)  Closed - Filled with Inert Materials  
 Newly Installed  Abandon with Water  Ownership Change (Indicate new owner name in block 2 - attach deed)  
 Abandoned with Product  Closed - Tank Removed  Temporarily Out of Service - Provide Date:  
Fire Dept. providing fire coverage where tank is located:  CITY  TOWN  VILLAGE 4008 BAYSIDE PUBLIC SAFE

IDENTIFICATION (Please Print)

1. TANK SITE NAME BAYSIDE SERVICE LLC	COUNTY MILWAUKEE	PHONE (262) 617-2174
SITE STREET ADDRESS 310 E BROWN DEER RD	<input type="checkbox"/> CITY <input checked="" type="checkbox"/> VILLAGE <input type="checkbox"/> TOWN OF: BAYSIDE	STATE ZIP WI 53217
2. TANK OWNER LEGAL NAME BAYSIDE SERVICE LLC	COUNTY MILWAUKEE	PHONE: Check <input checked="" type="checkbox"/> CELL or <input type="checkbox"/> LAND (262) 617-2174
MAILING ADDRESS 310 E BROWN DEER RD	<input type="checkbox"/> CITY <input checked="" type="checkbox"/> VILLAGE <input type="checkbox"/> TOWN OF: BAYSIDE	STATE ZIP WI 53217
3. PROPERTY OWNER NAME (if different from Tank Owner Legal Name #2)	COUNTY (if different from County #2)	
PROPERTY OWNER ADDRESS (if different from Site Street Address #1)	<input type="checkbox"/> CITY <input type="checkbox"/> VILLAGE <input type="checkbox"/> TOWN OF:	STATE ZIP WI
4. CLASS A NAME	DOB	CERTIFICATION: (Attach certificate)
5. CLASS B NAME	DOB	CERTIFICATION: (Attach certificate)

SITE ID: FACILITY ID # 83776 CUSTOMER ID # 1142915  
Tank Capacity (gallons): 8000 Tank Age (age or date installed): 10/01/1990 Vehicle fueling:  Yes  No

LAND OWNER TYPE (check one) Refer to back  
 County  State  Federal Leased  Federal Owned  Tribal Nation  Municipal  Other Government  Private

OCCUPANCY TYPE (check one) Refer to back  
 Retail Fuel Sales  Mercantile/Commercial  Industrial  Residential  School  Utility  Government Fleet  
 Agricultural (crop or livestock production)  Backup or Emergency Generator  Other (specify):

TANK CONSTRUCTION:  
 Bare Steel  Coated Steel  Steel - Fiberglass Reinforced Plastic Composite  
 Fiberglass  Unknown  Other (specify):  Lined (date):  
Overfill Protection?  Yes  No  
Spill Containment?  Yes  No  
Tank Double Walled?  Yes  No

TANK CATHODIC PROTECTION:  Sacrificial Anodes  Impressed Current  N/A

PRIMARY TANK LEAK DETECTION METHOD:  Automatic tank gauging  Interstitial monitoring  Electronic  Yes  No  Inventory control and tightness testing  
 Manual tank gauging (only for tanks of 1,000 gallons or less)  Statistical Inventory Reconciliation (SIR)  Unknown

PIPING CONSTRUCTION:  Single Wall  Double Wall:  
 Bare Steel  Coated Steel  Fiberglass  Flexible  Copper  Unknown  N/A  Other:

PIPING CATHODIC PROTECTION:  Sacrificial Anodes  Impressed Current  N/A

PRIMARY PIPING SYSTEM TYPE:  Pressurized piping with  A. Pump auto shutoff - ELLD  B. Flow restrictor - MLLD  Unknown  
 Suction piping with check valve at tank  Suction piping with check valve at pump and inspectable  Not needed if waste oil

PIPING LEAK DETECTION METHOD:  Interstitial monitoring  Electronic  Yes  No  Sump or cable sensor  Yes  No  
 Tightness testing  Electronic line monitor - ELLD  SIR  Not required  Unknown

TANK CONTENTS (Current, or previous product (if tank now empty))  Leaded  Unleaded  Gas-ethanol blend: 10%  Diesel  
 Bio-Diesel: %  Aviation  Premix  Fuel Oil  Kerosene  New Oil  New oil - Flash point less than 200°F  
 Waste/Used Motor Oil  Used for Heating  Hazardous Waste/Interface\*  Empty\*  Sand/Gravel/Slurry\*  Unknown  
 Other (specify):  Chemical\* Name CAS#

\* NOT PECFA eligible. Geo Latitude: Geo Longitude:

If Tank Closed, Abandoned or Out of Service: Has a site assessment been completed? (see reverse side for details)  Yes  No

TANK OWNER LEGAL NAME (please print) OSCAR A. MONCMA TANK OWNER E-MAIL OSCAR.MONCMA@YAHOO.COM

TANK OWNER SIGNATURE (Note: By signing, signer is accepting legal and financial responsibility for the storage tank system.) DATE: 29MAY18

Note: Refer to comments on reverse side of form.



Wisconsin Department of Agriculture, Trade and Consumer Protection
Bureau of Weights and Measures
PO Box 7837 Madison, WI 53707-7837
(608) 224-4942

FOR OFFICE USE ONLY
TDID#:
Reg Obj #:
Wis. Admin. Code SATCP 93.140

UNDERGROUND FLAMMABLE/COMBUSTIBLE/HAZARDOUS LIQUID STORAGE TANK REGISTRATION

Personal information you provide may be used for purposes other than that for which it was originally collected (s. 15.04(1)(m) Wis. Stats.).
Underground tanks in Wisconsin that have stored or currently store petroleum or regulated substances must be registered. A separate form is needed for each tank. Send each completed form to the agency designated above. Have you previously registered this tank by submitting a form? [ ] Yes [X] No

If yes, are you correcting/updating information only? [ ] Yes [ ] No

This registration applies to a tank status that is (check one):

- [ ] In Use [ ] Abandoned with Product (empty) [ ] Closed - Filled with Inert Materials
[ ] Newly Installed [ ] Abandon with Water [ ] Ownership Change (Indicate new owner name in block 2 - attach deed)
[ ] Abandoned with Product [X] Closed - Tank Removed [ ] Temporarily Out of Service - Provide Date:
Fire Dept. providing fire coverage where tank is located: [ ] CITY [ ] TOWN [X] VILLAGE 4008 BAYSIDE PUBLIC SAFE

IDENTIFICATION (Please Print)

1. TANK SITE NAME: BAYSIDE SERVICE LLC, COUNTY: MILWAUKEE, PHONE: (262) 617-2174
SITE STREET ADDRESS: 310 E BROWN DEER RD, CITY: BAYSIDE, STATE: WI, ZIP: 53217
2. TANK OWNER LEGAL NAME: BAYSIDE SERVICE LLC, COUNTY: MILWAUKEE, PHONE: (262) 617-2174
MAILING ADDRESS: 310 E BROWN DEER RD, CITY: BAYSIDE, STATE: WI, ZIP: 53217
3. PROPERTY OWNER NAME: (if different from Tank Owner Legal Name #2)
PROPERTY OWNER ADDRESS: (if different from Site Street Address #1)
4. CLASS A NAME, DOB, CERTIFICATION: (Attach certificate)
5. CLASS B NAME, DOB, CERTIFICATION: (Attach certificate)

SITE ID: FACILITY ID # 83776 CUSTOMER ID # 1142915
Tank Capacity (gallons): 4000 Tank Age (age or date installed): 10/01/1990 Vehicle fueling: [X] Yes [ ] No

LAND OWNER TYPE (check one) Refer to back: [ ] County [ ] State [ ] Federal Leased [ ] Federal Owned [ ] Tribal Nation [ ] Municipal [ ] Other Government [X] Private

OCCUPANCY TYPE (check one) Refer to back: [X] Retail Fuel Sales [ ] Mercantile/Commercial [ ] Industrial [ ] Residential [ ] School [ ] Utility [ ] Government Fleet
[ ] Agricultural (crop or livestock production) [ ] Backup or Emergency Generator [ ] Other (specify):

TANK CONSTRUCTION: [ ] Bare Steel [X] Coated Steel [ ] Steel - Fiberglass Reinforced Plastic Composite [ ] Fiberglass [ ] Unknown [ ] Other (specify): [ ] Lined (date):
Overfill Protection? [X] Yes [ ] No
Spill Containment? [X] Yes [ ] No
Tank Double Walled? [ ] Yes [X] No

TANK CATHODIC PROTECTION: [X] Sacrificial Anodes [ ] Impressed Current [ ] N/A

PRIMARY TANK LEAK DETECTION METHOD: [ ] Automatic tank gauging [ ] Interstitial monitoring [ ] Electronic [ ] Yes [ ] No [ ] Inventory control and tightness testing
[ ] Manual tank gauging (only for tanks of 1,000 gallons or less) [ ] Statistical Inventory Reconciliation (SIR) [X] Unknown

PIPING CONSTRUCTION: [X] Single Wall [ ] Double Wall: [ ] Bare Steel [ ] Coated Steel [X] Fiberglass [ ] Flexible [ ] Copper [ ] Unknown [ ] N/A [ ] Other:

PIPING CATHODIC PROTECTION: [ ] Sacrificial Anodes [ ] Impressed Current [X] N/A

PRIMARY PIPING SYSTEM TYPE: [ ] Pressurized piping with [ ] A. Pump auto shutoff - ELLD [ ] B. Flow restrictor - MLLD [X] Unknown
[ ] Suction piping with check valve at tank [ ] Suction piping with check valve at pump and inspectable [ ] Not needed if waste oil

PIPING LEAK DETECTION METHOD: [ ] Interstitial monitoring [ ] Electronic [ ] Yes [ ] No [ ] Sump or cable sensor [ ] Yes [ ] No
[ ] Tightness testing [ ] Electronic line monitor - ELLD [ ] SIR [ ] Not required [X] Unknown

TANK CONTENTS (Current, or previous product (if tank now empty)) [ ] Leaded [X] Unleaded [X] Gas-ethanol blend: 0% [ ] Diesel
[ ] Bio-Diesel: % [ ] Aviation [ ] Premix [ ] Fuel Oil [ ] Kerosene [ ] New Oil [ ] New oil - Flash point less than 200°F
[ ] Waste/Used Motor Oil [ ] Used for Heating [ ] Hazardous Waste/Interface\* [ ] Empty\* [ ] Sand/Grave/Slurry\* [ ] Unknown
[ ] Other (specify): [ ] Chemical\* Name CAS#

\* NOT PECFA eligible. Geo Latitude: Geo Longitude:

If Tank Closed, Abandoned or Out of Service: Has a site assessment been completed? (see reverse side for details) [ ] Yes [ ] No

TANK OWNER LEGAL NAME (please print) OSCAR A. MONJANA TANK OWNER E-MAIL OSCAR.MOTORCARS@YAMOO.COM

TANK OWNER SIGNATURE (Note: By signing, signer is accepting legal and financial responsibility for the storage tank system.) DATE: 29MAY18

Note: Refer to comments on reverse side of form.



Wisconsin Department of Agriculture, Trade and Consumer Protection
Bureau of Weights and Measures
PO Box 7837 Madison, WI 53707-7837
(608) 224-4942

FOR OFFICE USE ONLY
TDID#:
Reg Obj #:
Wis. Admin. Code §ATCP 93.140

UNDERGROUND FLAMMABLE/COMBUSTIBLE/HAZARDOUS LIQUID STORAGE TANK REGISTRATION

Personal information you provide may be used for purposes other than that for which it was originally collected (s. 15.04(1)(m) Wis. Stats.)
Underground tanks in Wisconsin that have stored or currently store petroleum or regulated substances must be registered. A separate form is needed for each tank. Send each completed form to the agency designated above. Have you previously registered this tank by submitting a form? [ ] Yes [X] No
If yes, are you correcting/updating information only? [ ] Yes [ ] No

This registration applies to a tank status that is (check one):
[ ] In Use [ ] Abandoned with Product (empty) [ ] Closed - Filled with Inert Materials
[ ] Newly Installed [ ] Abandon with Water [ ] Ownership Change (Indicate new owner name in block 2 - attach deed)
[ ] Abandoned with Product [ ] Closed - Tank Removed [ ] Temporarily Out of Service - Provide Date:
Fire Dept. providing fire coverage where tank is located: [ ] CITY [ ] TOWN [X] VILLAGE 4008 BAYSIDE PUBLIC SAFE

IDENTIFICATION (Please Print)
1. TANK SITE NAME: BAYSIDE SERVICE LLC, COUNTY: MILWAUKEE, PHONE: (262) 617-2174
2. TANK OWNER LEGAL NAME: BAYSIDE SERVICE LLC, COUNTY: MILWAUKEE, PHONE: (262) 617-2174
3. PROPERTY OWNER NAME: (if different from Tank Owner Legal Name #2)
4. CLASS A NAME, DOB, CERTIFICATION: (Attach certificate)
5. CLASS B NAME, DOB, CERTIFICATION: (Attach certificate)

SITE ID: FACILITY ID # 83776 CUSTOMER ID # 1142915
Tank Capacity (gallons): 550 Tank Age (age or date installed): 12/04/1997 Vehicle fueling: [X] Yes [ ] No

LAND OWNER TYPE (check one) Refer to back
[ ] County [ ] State [ ] Federal Leased [ ] Federal Owned [ ] Tribal Nation [ ] Municipal [ ] Other Government [X] Private

OCCUPANCY TYPE (check one) Refer to back
[X] Retail Fuel Sales [ ] Mercantile/Commercial [ ] Industrial [ ] Residential [ ] School [ ] Utility [ ] Government Fleet
[ ] Agricultural (crop or livestock production) [ ] Backup or Emergency Generator [ ] Other (specify):

TANK CONSTRUCTION:
[X] Bare Steel [ ] Coated Steel [ ] Steel - Fiberglass Reinforced Plastic Composite
[ ] Fiberglass [ ] Unknown [ ] Other (specify): [ ] Lined (date):
Overfill Protection? [X] Yes [ ] No
Spill Containment? [X] Yes [ ] No
Tank Double Walled? [ ] Yes [X] No

TANK CATHODIC PROTECTION: [ ] Sacrificial Anodes [ ] Impressed Current [X] N/A

PRIMARY TANK LEAK DETECTION METHOD: [ ] Automatic tank gauging [ ] Interstitial monitoring [ ] Electronic [ ] Yes [ ] No [ ] Inventory control and tightness testing
[ ] Manual tank gauging (only for tanks of 1,000 gallons or less) [ ] Statistical Inventory Reconciliation (SIR) [X] Unknown

PIPING CONSTRUCTION: [ ] Single Wall [ ] Double Wall:
[ ] Bare Steel [ ] Coated Steel [ ] Fiberglass [ ] Flexible [ ] Copper [ ] Unknown [X] N/A [ ] Other:

PIPING CATHODIC PROTECTION: [ ] Sacrificial Anodes [ ] Impressed Current [X] N/A

PRIMARY PIPING SYSTEM TYPE: [ ] Pressurized piping with [ ] A. Pump auto shutoff - ELLD [ ] B. Flow restrictor - MLLD [X] Unknown
[ ] Suction piping with check valve at tank [ ] Suction piping with check valve at pump and inspectable [X] Not needed if waste oil

PIPING LEAK DETECTION METHOD: [ ] Interstitial monitoring [ ] Electronic [ ] Yes [ ] No [ ] Sump or cable sensor [ ] Yes [ ] No
[ ] Tightness testing [ ] Electronic line monitor - ELLD [ ] SIR [X] Not required [ ] Unknown

TANK CONTENTS (Current, or previous product (if tank now empty))
[ ] Bio-Diesel: % [ ] Aviation [ ] Premix [ ] Fuel Oil [ ] Kerosene [ ] New Oil [ ] Gas-ethanol blend: % [ ] Diesel
[X] Waste/Used Motor Oil [ ] Used for Heating [ ] Hazardous Waste/Interface\* [ ] Empty\* [ ] Sand/Gravel/Slurry\* [ ] Unknown
[ ] Other (specify): [ ] Chemical\* Name CAS#

\* NOT PECFA eligible. Geo Latitude: Geo Longitude:

If Tank Closed, Abandoned or Out of Service: Has a site assessment been completed? (see reverse side for details) [ ] Yes [ ] No

TANK OWNER LEGAL NAME (please print) OSCAR A. MONAGA TANK OWNER E-MAIL OSCAR.MOTOCARS@YANOGA.COM

TANK OWNER SIGNATURE (Note: By signing, signer is accepting legal and financial responsibility for the storage tank system.) DATE: 29MAY18

Note: Refer to comments on reverse side of form.

**Part B**  
**Form TR-WM-140**

Part B - To be completed by environmental professional - Submit original Part B to the WDNR along with a copy of Part A

I. TANK-SYSTEM SITE ASSESSMENT (TSSA)

SITE NAME - Note: SITE NAME and address MUST MATCH with Part A Section 1.

Bayside Service, LLC

SITE ADDRESS (Not PO Box)

310 East Brown Deer Road

CITY TOWN VILLAGE Bayside

STATE WI

ZIP 53217

To determine if a TSSA is required, see ATCP 93 and section II part B of ASSESSMENT AND REPORTING OF SUSPECTED AND OBVIOUS RELEASES FROM UNDERGROUND AND ABOVEGROUND STORAGE TANK SYSTEMS.

If a TSSA is required, then follow the procedures detailed in ASSESSMENT AND REPORTING OF SUSPECTED AND OBVIOUS RELEASES FROM UNDERGROUND AND ABOVEGROUND STORAGE TANK SYSTEMS

1. Site Information

a. Has there been a previously documented release at this site? [X] Y [ ] N

If yes, provide the DATCP # 83776

or DNR BRRT's # 03-41-001030

b. Number of active tanks at facility prior to completion of current services: USTs Three ASTs One

(NOTE 1: Do not include previously closed systems or system components.)

c. Excavation/trench dimensions (in feet). (Photos must be provided.)

EXCAVATION/TRENCH #	LENGTH	WIDTH	DEPTH
Tank	~ 24'	~ 24'	~ 14'
Pump and Pipe	~ 31' + 20'	~ 31' + 20'	~ 4'

(Please see the figure)

2. Visual Excavation/Trench Inspection (Photos must be provided for "Yes" responses, except item b.)

Do any of the following conditions exist in or about the excavation(s)?

- a. Stained soils: [X] Yes [ ] No
- b. Petroleum odor: [X] Yes [ ] No
- c. Water in excavation/trench: [X] Yes [ ] No
- d. Free product in the excavation/trench: [ ] Yes [X] No
- e. Sheen or free product on water: [ ] Yes [X] No

3. Geology/Hydrogeology

a. Depth to groundwater Approximately 2.2 feet

b. Indicate type of geology? Fill consisting of silt, sand, and gravel in tank. Silty clay in Pump and pipe area

4. Receptors

- a. Water supply well(s) within 250 feet of the facility? [ ] Yes [X] No If yes, specify:
- b. Surface water(s) within 1000 feet of the facility? [ ] Yes [X] No If yes, specify:

5. Sampling

- a. Follow the procedures detailed in ASSESSMENT AND REPORTING OF SUSPECTED AND OBVIOUS RELEASES FROM UNDERGROUND AND ABOVEGROUND STORAGE TANK SYSTEMS.
- b. Complete Tables 1 and 2 as appropriate. (Attach chain-of-custody and laboratory analytical reports.)
- c. Attach a detailed map of site features and sample locations.

J. NOTE RELEVANT OBSERVATIONS, SPECIFIC PROBLEMS OR CONCERNS BELOW

Heavy petroleum persists in the areas of pumps and piping.

There is no contamination in the tank area.

Depth to water was approximately 2.2 feet below grade.

Benzene in the water after removal was detected at 40 ppb.

Benzene was not detected in the pre-excavation water (LO. 22 ppb).

Note: A revised cap maintenance plan, excluding tank area, must be revised. Please include pump and piping. Exclude tank area.



TABLE 1 SOIL FIELD SCREENING & GRO/DRO LABORATORY ANALYTICAL RESULTS-FOR PETROLEUM PRODUCTS

Sample ID #	Sample Location & Soil/Geologic Description	Sample Collection Method				Depth Below Tank/Piping (feet)	Field Screening Result (ppm)	GRO (mg/kg)	DRO (mg/kg)
		Grab	Shelby Tube	Direct Push	Split Spoon				
EW-1, 2'	Fill - S-S-G	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tank - 2ft	BK	N/A	N/A
EW-2, 2'	Fill - S-S-G	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tank - 2ft	BK	N/A	N/A
EW-3, 2'	Fill - S-S-G	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tank - 2ft	BK	N/A	N/A
WW-1, 2'	Fill - S-S-G	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tank - 2ft	160	N/A	N/A
WW-2, 2'	Fill - S-S-G	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tank - 2ft	190	N/A	N/A
WW-3, 2'	Fill - S-S-G	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tank - 2ft	140	N/A	N/A
NW-1, 2'	Fill - S-S-G	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tank - 2ft	100	N/A	N/A
NW-2, 2'	Fill - S-S-G	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tank - 2ft	BK	N/A	N/A
NW-3, 2'	Fill - S-S-G	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tank - 2ft	BK	N/A	N/A
SW-1, 2'	Fill - S-S-G	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tank - 2ft	860	N/A	N/A
SW-2, 2'	Fill - S-S-G	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tank - 2ft	460	N/A	N/A
SW-3, 2'	Fill - S-S-G	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tank - 2ft	700	N/A	N/A
Pump-1, 4'	Silty clay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pump - 4'	1000	N/A	N/A
Pump-2, 4'	Silty clay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pump - 4'	1800	N/A	N/A

TABLE 2 SOIL LABORATORY ANALYTICAL RESULTS-FOR PETROLEUM PRODUCTS

Sample ID #	BENZENE	TOLUENE	ETHYLBENZENE	MTBE	TRIMETHYL-BENZENES (TOTAL)	XYLENES (TOTAL)	NAPHTHALENE
	ug/kg	ug/kg	ug/kg	ug/kg	ug/kg	ug/kg	ug/kg
EW-1, 2'	<25	<25	<25	<25	<50	<75	<25
EW-2, 2'	<25	<25	<25	<25	<50	<75	<25
EW-3, 2'	<25	<25	<25	<25	<50	<75	<25
WW-1, 2'	910	73	69	<25	124	183	84
WW-2, 2'	750	27.3 "J"	43 "J"	<25	83	136	61 "J"
WW-3, 2'	590	62	55	<25	83	149	75
NW-1, 2'	25.8 "J"	<25	<25	<25	<50	<75	<25
NW-2, 2'	<25	<25	<25	<25	<50	<75	<25
NW-3, 2'	<25	<25	<25	<25	<50	<75	<25
SW-1, 2'	2460	430	1070	<25	1670	1260	1300
SW-2, 2'	5700	900	3200	<250	3240	2100	1990
SW-3, 2'	1890	1960	770	<25	539	729	380
Pip-1, 4'	800	520	1240	<25	4400	4950	2540
Pip-2, 4'	85000	31400	215000	<1250	740000	1076000	74000

K. TANK-SYSTEM SITE ASSESSMENT INFORMATION

As a tank-system site assessor certified under Wis. Admin. Code section SPS 305.83, it is my opinion that there is no indication of a release of a regulated substance to the environment. *after closure*

Sampling at the site indicates there has been a release to the environment. Pursuant to Wis. Admin. Code section ATCP 93.585 (2) (a) and Wis. Stats. section 292.11 (2) (a), the owner or operator or contractor performing work under chapter ATCP 93 shall immediately report any release of a regulated substance to the Wisconsin Department of Natural Resources. Failure to do so may result in forfeitures of a minimum of \$10 and a maximum of \$5000 for each violation under Wis. Stats. Section 168.26 (5). Each day of continued violation and each tank are treated as separate offenses. *No investigation or report from the previous closed release.*

RAGHU B. SINGH

Raghu B. Singh

401225

TANK-SYSTEM SITE ASSESSOR NAME (PRINT):

TANK-SYSTEM SITE ASSESSOR SIGNATURE

CERTIFICATION NO.

622853-0712

07/31/2018

OM Enterprises, Inc

TANK-SYSTEM SITE ASSESSOR TELEPHONE NUMBER

DATE SIGNED

COMPANY NAME TSPR # 468 219

TABLE 1 SOIL FIELD SCREENING & GRO/DRO LABORATORY ANALYTICAL RESULTS-FOR PETROLEUM PRODUCTS

Sample ID #	Sample Location & Soil/Geologic Description	Sample Collection Method				Depth Below Tank/Piping (feet)	Field Screening Result (ppm)	GRO (mg/kg)	DRO (mg/kg)
		Grab	Shelby Tube	Direct Push	Split Spoon				
Pipe-1, 4'	Silty clay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pipe - 4 ft.	400	N/A	N/A
Pipe-3, 4'	Silty clay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pipe - 4 ft.	390	N/A	N/A
Pipe-3, 4'	Silty clay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pipe - 4 ft.	800	N/A	N/A
Bottom, 14'	Silty clay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tank Bottom-14'	950		
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				

TABLE 2 SOIL LABORATORY ANALYTICAL RESULTS-FOR PETROLEUM PRODUCTS

Sample ID #	BENZENE	TOLUENE	ETHYLBENZENE	MTBE	TRIMETHYL - BENZENES (TOTAL)	XYLENES (TOTAL)	NAPHTHALENE
	ug/kg	ug/kg	ug/kg	ug/kg	ug/kg	ug/kg	ug/kg
Pipe-1, 4'	830	191	1550	< 25	6960	7920	1270
Pipe-2, 4'	410	101	520	< 25	1630	2400	400
Pipe-3, 4'	63000	14900	196000	< 1250	777000	950000	85000
Bottom, 14'	3130	380	2760	< 25	2420	3150	1240

K. TANK-SYSTEM SITE ASSESSMENT INFORMATION

As a tank-system site assessor certified under Wis. Admin. Code section SPS 305.83, it is my opinion that there is no indication of a release of a regulated substance to the environment. *after closure.*


Sampling at the site indicates there has been a release to the environment. Pursuant to Wis. Admin. Code section ATCP 93.585 (2) (a) and Wis. Stats. section 292.11 (2) (a), the owner or operator or contractor performing work under chapter ATCP 93 shall immediately report any release of a regulated substance to the Wisconsin Department of Natural Resources. Failure to do so may result in forfeitures of a minimum of \$10 and a maximum of \$5000 for each violation under Wis. Stats. Section 168.26 (5). Each day of continued violation and each tank are treated as separate offenses. *No inventory on file*

RAGHU B. SINGH *Raghu B. Singh* 401225  
TANK-SYSTEM SITE ASSESSOR NAME (PRINT): TANK-SYSTEM SITE ASSESSOR SIGNATURE CERTIFICATION NO.

(262)853-0712 07/31/2018 Om Enterprises, Inc.  
TANK-SYSTEM SITE ASSESSOR TELEPHONE NUMBER DATE SIGNED COMPANY NAME TSEF # 468219

**Figure 1**  
**Site Layout and TSSA Soil Sampling Locations**

Residence



**NOTE:**

Tank	Length (feet)	Diameter (feet)
A	7	4
B	15	7
C	21	8

DTW at, during, and after removal: ~ 2,2 feet

- E denotes East
- W denotes West
- N denotes North
- S denotes South
- T denotes Tank

East Brown Deer Road

**Figure 1: Site Layout and TSSA Soil Sampling Locations**

<p><b>Site</b> Bayside Service 310 E Brown Deer Road Bayside, WI 53217 BRRTS # 03-41-001030 Simplified Bid # 83776</p>	<p><b>State Contact</b> WDNR P. O. Box 7921 Madison, WI 53707</p>	<p><b>Tank Remover</b> RCT Petroleum, Inc. 3845 W Forest Home Avenue Milwaukee, WI 53215</p>	<p><b>Tank-System Site Assessor</b> OM Enterprises, Inc. 124 W Scott Street Fond du Lac, WI 54935 TSSA Certification # 401225 Tank Specialty Firm # 468219</p>	<p>SCALE NOT TO SCALE</p>	<p><b>Project #</b> 3043 <b>Date</b> 7-5-2018</p>	<p><b>Legend</b> ● Soil Sampling Location</p>
--	---	--	--	-------------------------------	---	---

# **Soil Quality Test Results Excavation Soil Sampling**

## Environmental Lab, Inc.

1990 Prospect Ct. • Appleton, WI 54914  
920-830-2455 • FAX 920-733-0631

**Sample Hand**  
Rush Analysis [ ]  
(Rushes accepted only v  
 Normal

Lab I.D. #	
Account No.:	Quote No.:
Project #: 3043   Bayside Service	
Sampler: (signature) <u>Raghu B. Singh</u>	

Project (Name / Location): <u>310 E. Brown Deer Road, Bayside, WI 53217</u>	
Reports To:	Invoice To:
Company <u>Om Enterprises, Inc.</u>	Company <u>Om Enterprises, Inc.</u>
Address <u>124 W Scott Street</u>	Address <u>124 W Scott Street</u>
City State Zip <u>Fond du Lac, WI 54935</u>	City State Zip <u>Fond du Lac, WI 54935</u>
Phone <u>(262) 853 - 0712</u>	Phone <u>(262) 853 - 0712</u>
FAX	FAX

**Analysis Requested**

Lab I.D.	Sample I.D.	Collection Date	Time	Comp	Grab	Filtered Y/N	No. of Containers	Sample Type (Matrix)*	Preservation	DRO (Mod DRO Sep 95)	GRO (Mod GRO Sep 95)	LEAD	NITRATE/NITRITE	OIL & GREASE	PAH (EPA 8270)	PCB	PVOC (EPA 8021)	PVOC + NAPHTHALENE	SULFATE	TOTAL SUSPENDED SOLIDS	VOC DW (EPA 524.2)	VOC (EPA 8260)	8-PCPA METALS		
<del>SOS1706A</del>	EW-1, 2'	5/29/18	11:45		X	N/A	2	S	Meat																
B	EW-2, 2'	"	12:15		X	N/A	2	S	Meat																
C	EW-3, 2'	"	12:30		X	N/A	2	S	Meat																
D	WW-1, 2'	"	1:15		X	N/A	2	S	Meat																
E	WW-2, 2'	"	1:30		X	N/A	2	S	Meat																
F	WW-3, 2'	"	1:45		X	N/A	2	S	Meat																
G	NW-1, 2'	"	3:00		X	N/A	2	S	Meat																
H	NW-2, 2'	"	3:15		X	N/A	2	S	Meat																
I	NW-3, 2'	"	3:55		X	N/A	2	S	Meat																
J	SW-1, 2'	"	4:00		X	N/A	2	S	Meat																

Comments/Special Instructions ("Specify groundwater "GW", Drinking Water "DW", Waste Water "WW", Soil "S", Air "A", Oil, Sludge etc.):

Sample Integrity - To be completed by receiving lab. Method of Shipment: <u>Client</u> Temp. of Temp. Blank _____ °C On Ice: <input checked="" type="checkbox"/> Cooler seal intact upon receipt: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Relinquished By: (sign)	Time	Date	Received By: (sign)
	<u>Raghu B. Singh</u>	<u>1:00 PM</u>	<u>5/30/18</u>	
	Received in Laboratory By: <u>[Signature]</u>		Time: <u>1:10 PM</u>	

# Synergy Environmental Lab, INC.

1990 Prospect Ct., Appleton, WI 54914 \*P 920-830-2455 \* F 920-733-0631

RAGHU B SINGH, PH D  
OM ENTERPRISES, INC.  
124 W. SCOTT STREET  
FOND DU LAC, WI 54935

Report Date 11-Jun-18

Project Name 310 E BROWN DEER RD  
Project # 3043

Invoice # E34706

Lab Code 5034706A  
Sample ID EW-1 2'  
Sample Matrix Soil  
Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	94.2	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	< 0.025	mg/kg	0.0095	0.03	1	GRO95/8021		6/4/2018	CJR	1
Ethylbenzene	< 0.025	mg/kg	0.016	0.05	1	GRO95/8021		6/4/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.025	mg/kg	0.011	0.034	1	GRO95/8021		6/4/2018	CJR	1
Naphthalene	< 0.025	mg/kg	0.022	0.07	1	GRO95/8021		6/4/2018	CJR	1
Toluene	< 0.025	mg/kg	0.013	0.041	1	GRO95/8021		6/4/2018	CJR	1
1,2,4-Trimethylbenzene	< 0.025	mg/kg	0.019	0.06	1	GRO95/8021		6/4/2018	CJR	1
1,3,5-Trimethylbenzene	< 0.025	mg/kg	0.0096	0.031	1	GRO95/8021		6/4/2018	CJR	1
m&p-Xylene	< 0.05	mg/kg	0.013	0.042	1	GRO95/8021		6/4/2018	CJR	1
o-Xylene	< 0.025	mg/kg	0.0062	0.02	1	GRO95/8021		6/4/2018	CJR	1

## Environmental Lab, Inc.

1990 Prospect Ct. • Appleton, WI 54914  
920-830-2455 • FAX 920-733-0631

**Sample Hand**  
Rush Analysis I  
(Rushes accepted only v  
 Normal

Lab I.D. #  
Account No.:                      Quote No.:  
Project #: 3043/ Bayside Service  
Sampler: (signature) Raghu B. Singh

Project (Name / Location): 310 E. Brown Deer Road, Bayside, WI 53217  
Reports To:    Invoice To:  
Company OM Enterprises, Inc.                      Company Om Enterprises, Inc.  
Address 124 W. Scott Street                      Address 124 W. Scott Street  
City State Zip Fond du Lac, WI 54935                      City State Zip Fond du Lac, WI 54935  
Phone (262) 853-0712                      Phone (262) 853-0712  
FAX    FAX

Analysis Requested													
DRO (Mod DRO Sep 95)	GRO (Mod GRO Sep 95)	LEAD	NITRATE/NITRITE	OIL & GREASE	PAH (EPA 8270)	PCB	PVOC (EPA 8021)	PVOC + NAPHTHALENE	SULFATE	TOTAL SUSPENDED SOLIDS	VOC DW (EPA 524.2)	VOC (EPA 8260)	8-PCRA METALS

Lab I.D.	Sample I.D.	Collection Date	Time	Comp	Grab	Filtered Y/N	No. of Containers	Sample Type (Matrix)*	Preservation
<u>S034706k</u>	<u>SW-2, 2l</u>	<u>5/29/18</u>	<u>4:15</u>		X	<u>N/A</u>	<u>2</u>	<u>S</u>	<u>Meat</u>
<u>L</u>	<u>SW-3, 2l</u>	<u>"</u>	<u>4:35</u>		X	<u>N/A</u>	<u>2</u>	<u>S</u>	<u>Meat</u>
<u>M</u>	<u>Pump-1, 4l</u>	<u>"</u>	<u>4:45</u>		X	<u>N/A</u>	<u>2</u>	<u>S</u>	<u>Meat</u>
<u>N</u>	<u>Pump-2, 4l</u>	<u>"</u>	<u>5:15</u>		X	<u>N/A</u>	<u>2</u>	<u>S</u>	<u>Meat</u>
<u>O</u>	<u>Pipe-1, 4l</u>	<u>"</u>	<u>5:30</u>		X	<u>N/A</u>	<u>2</u>	<u>S</u>	<u>Meat</u>
<u>P</u>	<u>Pipe-2, 4l</u>	<u>"</u>	<u>5:45</u>		X	<u>N/A</u>	<u>2</u>	<u>S</u>	<u>Meat</u>
<u>Q</u>	<u>Pipe-3, 4l</u>	<u>"</u>	<u>6:00</u>		X	<u>N/A</u>	<u>2</u>	<u>S</u>	<u>Meat</u>
<u>R</u>	<u>Bottom, 14l</u>	<u>"</u>	<u>6:15</u>		X	<u>N/A</u>	<u>2</u>	<u>S</u>	<u>Meat</u>

Comments/Special Instructions ("Specify groundwater "GW", Drinking Water "DW", Waste Water "WW", Soil "S", Air "A", Oil, Sludge etc.)

Sample Integrity - To be completed by receiving lab.  
Method of Shipment: Client  
Temp. of Temp. Blank \_\_\_\_\_ °C On Ice: 2  
Cooler seal intact upon receipt:  Yes \_\_\_\_\_ No

Relinquished By: (sign) Raghu B. Singh                      Time 1:40                      Date 5/30/18                      Received By: (sign) \_\_\_\_\_

Received in Laboratory By: [Signature]                      Time: 1:15 PM



Project Name 310 E BROWN DEER RD  
 Project # 3043

Invoice # E34706

Lab Code 5034706B  
 Sample ID EW-2 2'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	94.3	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	< 0.025	mg/kg	0.0095	0.03	1	GRO95/8021		6/4/2018	CJR	1
Ethylbenzene	< 0.025	mg/kg	0.016	0.05	1	GRO95/8021		6/4/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.025	mg/kg	0.011	0.034	1	GRO95/8021		6/4/2018	CJR	1
Naphthalene	< 0.025	mg/kg	0.022	0.07	1	GRO95/8021		6/4/2018	CJR	1
Toluene	< 0.025	mg/kg	0.013	0.041	1	GRO95/8021		6/4/2018	CJR	1
1,2,4-Trimethylbenzene	< 0.025	mg/kg	0.019	0.06	1	GRO95/8021		6/4/2018	CJR	1
1,3,5-Trimethylbenzene	< 0.025	mg/kg	0.0096	0.031	1	GRO95/8021		6/4/2018	CJR	1
m&p-Xylene	< 0.05	mg/kg	0.013	0.042	1	GRO95/8021		6/4/2018	CJR	1
o-Xylene	< 0.025	mg/kg	0.0062	0.02	1	GRO95/8021		6/4/2018	CJR	1

Lab Code 5034706C  
 Sample ID EW-3 2'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	94.9	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	< 0.025	mg/kg	0.0095	0.03	1	GRO95/8021		6/5/2018	CJR	1
Ethylbenzene	< 0.025	mg/kg	0.016	0.05	1	GRO95/8021		6/5/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.025	mg/kg	0.011	0.034	1	GRO95/8021		6/5/2018	CJR	1
Naphthalene	< 0.025	mg/kg	0.022	0.07	1	GRO95/8021		6/5/2018	CJR	1
Toluene	< 0.025	mg/kg	0.013	0.041	1	GRO95/8021		6/5/2018	CJR	1
1,2,4-Trimethylbenzene	< 0.025	mg/kg	0.019	0.06	1	GRO95/8021		6/5/2018	CJR	1
1,3,5-Trimethylbenzene	< 0.025	mg/kg	0.0096	0.031	1	GRO95/8021		6/5/2018	CJR	1
m&p-Xylene	< 0.05	mg/kg	0.013	0.042	1	GRO95/8021		6/5/2018	CJR	1
o-Xylene	< 0.025	mg/kg	0.0062	0.02	1	GRO95/8021		6/5/2018	CJR	1

Project Name 310 E BROWN DEER RD  
 Project # 3043

Invoice # E34706

Lab Code 5034706D  
 Sample ID WW-1 2'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	82.8	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	0.91	mg/kg	0.0095	0.03	1	GRO95/8021		6/5/2018	CJR	1
Ethylbenzene	0.069	mg/kg	0.016	0.05	1	GRO95/8021		6/5/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.025	mg/kg	0.011	0.034	1	GRO95/8021		6/5/2018	CJR	1
Naphthalene	0.084	mg/kg	0.022	0.07	1	GRO95/8021		6/5/2018	CJR	1
Toluene	0.073	mg/kg	0.013	0.041	1	GRO95/8021		6/5/2018	CJR	1
1,2,4-Trimethylbenzene	0.056 "J"	mg/kg	0.019	0.06	1	GRO95/8021		6/5/2018	CJR	1
1,3,5-Trimethylbenzene	0.068	mg/kg	0.0096	0.031	1	GRO95/8021		6/5/2018	CJR	1
m&p-Xylene	0.135	mg/kg	0.013	0.042	1	GRO95/8021		6/5/2018	CJR	1
o-Xylene	0.048	mg/kg	0.0062	0.02	1	GRO95/8021		6/5/2018	CJR	1

Lab Code 5034706E  
 Sample ID WW-2 2'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	83.6	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	0.75	mg/kg	0.0095	0.03	1	GRO95/8021		6/5/2018	CJR	1
Ethylbenzene	0.043 "J"	mg/kg	0.016	0.05	1	GRO95/8021		6/5/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.025	mg/kg	0.011	0.034	1	GRO95/8021		6/5/2018	CJR	1
Naphthalene	0.061 "J"	mg/kg	0.022	0.07	1	GRO95/8021		6/5/2018	CJR	1
Toluene	0.0273 "J"	mg/kg	0.013	0.041	1	GRO95/8021		6/5/2018	CJR	1
1,2,4-Trimethylbenzene	0.034 "J"	mg/kg	0.019	0.06	1	GRO95/8021		6/5/2018	CJR	1
1,3,5-Trimethylbenzene	0.049	mg/kg	0.0096	0.031	1	GRO95/8021		6/5/2018	CJR	1
m&p-Xylene	0.099	mg/kg	0.013	0.042	1	GRO95/8021		6/5/2018	CJR	1
o-Xylene	0.037	mg/kg	0.0062	0.02	1	GRO95/8021		6/5/2018	CJR	1

Project Name 310 E BROWN DEER RD  
 Project # 3043

Invoice # E34706

Lab Code 5034706F  
 Sample ID WW-3 2'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	84.3	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	0.59	mg/kg	0.0095	0.03	1	GRO95/8021		6/5/2018	CJR	1
Ethylbenzene	0.055	mg/kg	0.016	0.05	1	GRO95/8021		6/5/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.025	mg/kg	0.011	0.034	1	GRO95/8021		6/5/2018	CJR	1
Naphthalene	0.075	mg/kg	0.022	0.07	1	GRO95/8021		6/5/2018	CJR	1
Toluene	0.062	mg/kg	0.013	0.041	1	GRO95/8021		6/5/2018	CJR	1
1,2,4-Trimethylbenzene	0.042 "J"	mg/kg	0.019	0.06	1	GRO95/8021		6/5/2018	CJR	1
1,3,5-Trimethylbenzene	0.041	mg/kg	0.0096	0.031	1	GRO95/8021		6/5/2018	CJR	1
m&p-Xylene	0.118	mg/kg	0.013	0.042	1	GRO95/8021		6/5/2018	CJR	1
o-Xylene	0.031	mg/kg	0.0062	0.02	1	GRO95/8021		6/5/2018	CJR	1

Lab Code 5034706G  
 Sample ID NW-1 2'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	77.8	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	0.0258 "J"	mg/kg	0.0095	0.03	1	GRO95/8021		6/5/2018	CJR	1
Ethylbenzene	< 0.025	mg/kg	0.016	0.05	1	GRO95/8021		6/5/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.025	mg/kg	0.011	0.034	1	GRO95/8021		6/5/2018	CJR	1
Naphthalene	< 0.025	mg/kg	0.022	0.07	1	GRO95/8021		6/5/2018	CJR	1
Toluene	< 0.025	mg/kg	0.013	0.041	1	GRO95/8021		6/5/2018	CJR	1
1,2,4-Trimethylbenzene	< 0.025	mg/kg	0.019	0.06	1	GRO95/8021		6/5/2018	CJR	1
1,3,5-Trimethylbenzene	< 0.025	mg/kg	0.0096	0.031	1	GRO95/8021		6/5/2018	CJR	1
m&p-Xylene	< 0.05	mg/kg	0.013	0.042	1	GRO95/8021		6/5/2018	CJR	1
o-Xylene	< 0.025	mg/kg	0.0062	0.02	1	GRO95/8021		6/5/2018	CJR	1

Project Name 310 E BROWN DEER RD  
 Project # 3043

Invoice # E34706

Lab Code 5034706H  
 Sample ID NW-2 2'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	85.0	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	< 0.025	mg/kg	0.0095	0.03	1	GRO95/8021		6/5/2018	CJR	1
Ethylbenzene	< 0.025	mg/kg	0.016	0.05	1	GRO95/8021		6/5/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.025	mg/kg	0.011	0.034	1	GRO95/8021		6/5/2018	CJR	1
Naphthalene	< 0.025	mg/kg	0.022	0.07	1	GRO95/8021		6/5/2018	CJR	1
Toluene	< 0.025	mg/kg	0.013	0.041	1	GRO95/8021		6/5/2018	CJR	1
1,2,4-Trimethylbenzene	< 0.025	mg/kg	0.019	0.06	1	GRO95/8021		6/5/2018	CJR	1
1,3,5-Trimethylbenzene	< 0.025	mg/kg	0.0096	0.031	1	GRO95/8021		6/5/2018	CJR	1
m&p-Xylene	< 0.05	mg/kg	0.013	0.042	1	GRO95/8021		6/5/2018	CJR	1
o-Xylene	< 0.025	mg/kg	0.0062	0.02	1	GRO95/8021		6/5/2018	CJR	1

Lab Code 5034706I  
 Sample ID NW-3 2'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	80.2	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	< 0.025	mg/kg	0.0095	0.03	1	GRO95/8021		6/5/2018	CJR	1
Ethylbenzene	< 0.025	mg/kg	0.016	0.05	1	GRO95/8021		6/5/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.025	mg/kg	0.011	0.034	1	GRO95/8021		6/5/2018	CJR	1
Naphthalene	< 0.025	mg/kg	0.022	0.07	1	GRO95/8021		6/5/2018	CJR	1
Toluene	< 0.025	mg/kg	0.013	0.041	1	GRO95/8021		6/5/2018	CJR	1
1,2,4-Trimethylbenzene	< 0.025	mg/kg	0.019	0.06	1	GRO95/8021		6/5/2018	CJR	1
1,3,5-Trimethylbenzene	< 0.025	mg/kg	0.0096	0.031	1	GRO95/8021		6/5/2018	CJR	1
m&p-Xylene	< 0.05	mg/kg	0.013	0.042	1	GRO95/8021		6/5/2018	CJR	1
o-Xylene	< 0.025	mg/kg	0.0062	0.02	1	GRO95/8021		6/5/2018	CJR	1

Project Name 310 E BROWN DEER RD  
 Project # 3043

Invoice # E34706

Lab Code 5034706J  
 Sample ID SW-1 2'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	84.0	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	2.46	mg/kg	0.095	0.3	10	GRO95/8021		6/6/2018	CJR	1
Ethylbenzene	1.07	mg/kg	0.16	0.5	10	GRO95/8021		6/6/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.25	mg/kg	0.11	0.34	10	GRO95/8021		6/6/2018	CJR	1
Naphthalene	1.3	mg/kg	0.22	0.7	10	GRO95/8021		6/6/2018	CJR	1
Toluene	0.43	mg/kg	0.13	0.41	10	GRO95/8021		6/6/2018	CJR	1
1,2,4-Trimethylbenzene	0.49 "J"	mg/kg	0.19	0.6	10	GRO95/8021		6/6/2018	CJR	1
1,3,5-Trimethylbenzene	1.18	mg/kg	0.096	0.31	10	GRO95/8021		6/6/2018	CJR	1
m&p-Xylene	0.79	mg/kg	0.13	0.42	10	GRO95/8021		6/6/2018	CJR	1
o-Xylene	0.47	mg/kg	0.062	0.2	10	GRO95/8021		6/6/2018	CJR	1

Lab Code 5034706K  
 Sample ID SW-2 2'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	82.8	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	5.7	mg/kg	0.095	0.3	10	GRO95/8021		6/6/2018	CJR	1
Ethylbenzene	3.2	mg/kg	0.16	0.5	10	GRO95/8021		6/6/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.25	mg/kg	0.11	0.34	10	GRO95/8021		6/6/2018	CJR	1
Naphthalene	1.99	mg/kg	0.22	0.7	10	GRO95/8021		6/6/2018	CJR	1
Toluene	0.90	mg/kg	0.13	0.41	10	GRO95/8021		6/6/2018	CJR	1
1,2,4-Trimethylbenzene	0.59 "J"	mg/kg	0.19	0.6	10	GRO95/8021		6/6/2018	CJR	1
1,3,5-Trimethylbenzene	2.65	mg/kg	0.096	0.31	10	GRO95/8021		6/6/2018	CJR	1
m&p-Xylene	1.44	mg/kg	0.13	0.42	10	GRO95/8021		6/6/2018	CJR	1
o-Xylene	0.66	mg/kg	0.062	0.2	10	GRO95/8021		6/6/2018	CJR	1

Project Name 310 E BROWN DEER RD  
 Project # 3043

Invoice # E34706

Lab Code 5034706L  
 Sample ID SW-3 2'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	81.6	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	1.89	mg/kg	0.0095	0.03	1	GRO95/8021		6/8/2018	CJR	1
Ethylbenzene	0.77	mg/kg	0.016	0.05	1	GRO95/8021		6/8/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.025	mg/kg	0.011	0.034	1	GRO95/8021		6/8/2018	CJR	1
Naphthalene	0.38	mg/kg	0.022	0.07	1	GRO95/8021		6/8/2018	CJR	1
Toluene	0.196	mg/kg	0.013	0.041	1	GRO95/8021		6/8/2018	CJR	1
1,2,4-Trimethylbenzene	0.169	mg/kg	0.019	0.06	1	GRO95/8021		6/8/2018	CJR	1
1,3,5-Trimethylbenzene	0.37	mg/kg	0.0096	0.031	1	GRO95/8021		6/8/2018	CJR	1
m&p-Xylene	0.52	mg/kg	0.013	0.042	1	GRO95/8021		6/8/2018	CJR	1
o-Xylene	0.209	mg/kg	0.0062	0.02	1	GRO95/8021		6/8/2018	CJR	1

Lab Code 5034706M  
 Sample ID PUMP-1 4'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	84.2	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	0.80	mg/kg	0.0095	0.03	1	GRO95/8021		6/6/2018	CJR	1
Ethylbenzene	1.24	mg/kg	0.016	0.05	1	GRO95/8021		6/6/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.025	mg/kg	0.011	0.034	1	GRO95/8021		6/6/2018	CJR	1
Naphthalene	2.54	mg/kg	0.022	0.07	1	GRO95/8021		6/6/2018	CJR	1
Toluene	0.52	mg/kg	0.013	0.041	1	GRO95/8021		6/6/2018	CJR	1
1,2,4-Trimethylbenzene	3.5	mg/kg	0.019	0.06	1	GRO95/8021		6/6/2018	CJR	1
1,3,5-Trimethylbenzene	0.90	mg/kg	0.0096	0.031	1	GRO95/8021		6/6/2018	CJR	1
m&p-Xylene	3.6	mg/kg	0.013	0.042	1	GRO95/8021		6/6/2018	CJR	1
o-Xylene	1.35	mg/kg	0.0062	0.02	1	GRO95/8021		6/6/2018	CJR	1

Project Name 310 E BROWN DEER RD  
 Project # 3043

Invoice # E34706

Lab Code 5034706N  
 Sample ID PUMP-2 4'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	86.4	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	85	mg/kg	0.475	1.5	50	GRO95/8021		6/6/2018	CJR	1
Ethylbenzene	215	mg/kg	0.8	2.5	50	GRO95/8021		6/6/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 1.25	mg/kg	0.55	1.7	50	GRO95/8021		6/6/2018	CJR	1
Naphthalene	74	mg/kg	1.1	3.5	50	GRO95/8021		6/6/2018	CJR	1
Toluene	31.4	mg/kg	0.65	2.05	50	GRO95/8021		6/6/2018	CJR	1
1,2,4-Trimethylbenzene	560	mg/kg	0.95	3	50	GRO95/8021		6/6/2018	CJR	1
1,3,5-Trimethylbenzene	180	mg/kg	0.48	1.55	50	GRO95/8021		6/6/2018	CJR	1
m&p-Xylene	800	mg/kg	0.65	2.1	50	GRO95/8021		6/6/2018	CJR	1
o-Xylene	276	mg/kg	0.31	1	50	GRO95/8021		6/6/2018	CJR	1

Lab Code 5034706O  
 Sample ID PIPE-1 4'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	83.7	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	0.83	mg/kg	0.0095	0.03	1	GRO95/8021		6/6/2018	CJR	1
Ethylbenzene	1.55	mg/kg	0.016	0.05	1	GRO95/8021		6/6/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.025	mg/kg	0.011	0.034	1	GRO95/8021		6/6/2018	CJR	1
Naphthalene	1.27	mg/kg	0.022	0.07	1	GRO95/8021		6/6/2018	CJR	1
Toluene	0.191	mg/kg	0.013	0.041	1	GRO95/8021		6/6/2018	CJR	1
1,2,4-Trimethylbenzene	5.4	mg/kg	0.019	0.06	1	GRO95/8021		6/6/2018	CJR	1
1,3,5-Trimethylbenzene	1.56	mg/kg	0.0096	0.031	1	GRO95/8021		6/6/2018	CJR	1
m&p-Xylene	5.6	mg/kg	0.013	0.042	1	GRO95/8021		6/6/2018	CJR	1
o-Xylene	2.32	mg/kg	0.0062	0.02	1	GRO95/8021		6/6/2018	CJR	1

Project Name 310 E BROWN DEER RD

Invoice # E34706

Project # 3043

Lab Code 5034706P

Sample ID PIPE-2 4'

Sample Matrix Soil

Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	84.1	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	0.41	mg/kg	0.0095	0.03	1	GRO95/8021		6/6/2018	CJR	1
Ethylbenzene	0.52	mg/kg	0.016	0.05	1	GRO95/8021		6/6/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.025	mg/kg	0.011	0.034	1	GRO95/8021		6/6/2018	CJR	1
Naphthalene	0.40	mg/kg	0.022	0.07	1	GRO95/8021		6/6/2018	CJR	1
Toluene	0.101	mg/kg	0.013	0.041	1	GRO95/8021		6/6/2018	CJR	1
1,2,4-Trimethylbenzene	1.24	mg/kg	0.019	0.06	1	GRO95/8021		6/6/2018	CJR	1
1,3,5-Trimethylbenzene	0.39	mg/kg	0.0096	0.031	1	GRO95/8021		6/6/2018	CJR	1
m&p-Xylene	1.69	mg/kg	0.013	0.042	1	GRO95/8021		6/6/2018	CJR	1
o-Xylene	0.71	mg/kg	0.0062	0.02	1	GRO95/8021		6/6/2018	CJR	1

Lab Code 5034706Q

Sample ID PIPE-3 4'

Sample Matrix Soil

Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	85.4	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	63	mg/kg	0.475	1.5	50	GRO95/8021		6/9/2018	CJR	1
Ethylbenzene	196	mg/kg	0.8	2.5	50	GRO95/8021		6/9/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 1.25	mg/kg	0.55	1.7	50	GRO95/8021		6/9/2018	CJR	1
Naphthalene	85	mg/kg	1.1	3.5	50	GRO95/8021		6/9/2018	CJR	1
Toluene	14.9	mg/kg	0.65	2.05	50	GRO95/8021		6/9/2018	CJR	1
1,2,4-Trimethylbenzene	590	mg/kg	0.95	3	50	GRO95/8021		6/9/2018	CJR	1
1,3,5-Trimethylbenzene	187	mg/kg	0.48	1.55	50	GRO95/8021		6/9/2018	CJR	1
m&p-Xylene	730	mg/kg	0.65	2.1	50	GRO95/8021		6/9/2018	CJR	1
o-Xylene	220	mg/kg	0.31	1	50	GRO95/8021		6/9/2018	CJR	1



Project Name 310 E BROWN DEER RD  
 Project # 3043

Invoice # E34706

Lab Code 5034706R  
 Sample ID BOTTOM 14'  
 Sample Matrix Soil  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General										
General										
Solids Percent	85.6	%			1	5021		5/31/2018	NJC	1
Organic										
PVOC + Naphthalene										
Benzene	3.13	mg/kg	0.0095	0.03	1	GRO95/8021		6/8/2018	CJR	1
Ethylbenzene	2.76	mg/kg	0.016	0.05	1	GRO95/8021		6/8/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.025	mg/kg	0.011	0.034	1	GRO95/8021		6/8/2018	CJR	1
Naphthalene	1.24	mg/kg	0.022	0.07	1	GRO95/8021		6/8/2018	CJR	1
Toluene	0.38	mg/kg	0.013	0.041	1	GRO95/8021		6/8/2018	CJR	1
1,2,4-Trimethylbenzene	1.29	mg/kg	0.019	0.06	1	GRO95/8021		6/8/2018	CJR	1
1,3,5-Trimethylbenzene	1.13	mg/kg	0.0096	0.031	1	GRO95/8021		6/8/2018	CJR	1
m&p-Xylene	2.42	mg/kg	0.013	0.042	1	GRO95/8021		6/8/2018	CJR	1
o-Xylene	0.73	mg/kg	0.0062	0.02	1	GRO95/8021		6/8/2018	CJR	1

"J" Flag: Analyte detected between LOD and LOQ

LOD Limit of Detection

LOQ Limit of Quantitation

*Code*      *Comment*

1            Laboratory QC within limits.

All solid sample results reported on a dry weight basis unless otherwise indicated. All LOD's and LOQ's are adjusted for dilutions but not dry weight. Subcontracted results are denoted by SUB in the analyst field.

Authorized Signature



# **Groundwater Quality Test Results Prior to Excavation**

## Environmental Lab, Inc.

1990 Prospect Ct. • Appleton, WI 54914  
920-830-2455 • FAX 920-733-0631

**Sample Handling Request**  
Rush Analysis Date Required \_\_\_\_\_  
(Rushes accepted only with prior authorization)  
 Normal Turn Around

Lab I.D. # \_\_\_\_\_  
Account No.: \_\_\_\_\_ Quote No.: \_\_\_\_\_  
Project #: 3043 Bay Side Service  
Sampler: (signature) *Ralph B. Snyl*

Project (Name / Location): 310 E Brown Deer Road, Bay Side, WI 53217

Reports To:	Invoice To:
Company Om Enterprises, Inc.	Company Om Enterprises, Inc.
Address 124 W. Scott Street	Address 124 W. Scott Street
City State Zip Fond du Lac, WI 54935	City State Zip Fond du Lac, WI 54935
Phone (608) 853-0712	Phone (608) 853-0712
FAX	FAX

Analysis Requested		Other Analysis												
DRO (Mod DRO Sep 95)	GRO (Mod GRO Sep 95)	LEAD	NITRATE/NITRITE	OIL & GREASE	PAH (EPA 8270)	PCB	PVOC (EPA 8021) + GAs	PVOC + NAPHTHALENE	SULFATE	TOTAL SUSPENDED SOLIDS	VOC DW (EPA 624-2)	VOC (EPA 8260)	8-PCRA METALS	PID/FID
							X							

Lab I.D.	Sample I.D.	Collection Date	Time	Comp	Grab	Filtered Y/N	No. of Containers	Sample Type (Matrix)*	Preservation
5034656A	Sample Water	5/15/18	9:00		X	N	03	GW	iced

Comments/Special Instructions (\*Specify groundwater "GW", Drinking Water "DW", Waste Water "WW", Soil "S", Air "A", Oil, Sludge etc.)  
*Sample collected on 5/15/18 for total lead.*

Sample Integrity - To be completed by receiving lab. Method of Shipment: <i>clean</i> Temp. of Temp. Blank _____ °C On Ice: <input checked="" type="checkbox"/> Cooler seal intact upon receipt: <input checked="" type="checkbox"/> Yes _____ No	Relinquished By: (sign) <i>Ralph B. Snyl</i>	Time <i>12:30</i>	Date <i>5/15/18</i>	Received By: (sign)	Time	Date
	Received in Laboratory By: <i>Moh Chik</i>	Time: <i>12:30</i>	Date: <i>5/15/18</i>			

# Synergy Environmental Lab, INC.

1990 Prospect Ct., Appleton, WI 54914 \*P 920-830-2455 \* F 920-733-0631

RAGHU B SINGH, PH D  
 OM ENTERPRISES, INC.  
 124 W. SCOTT STREET  
 FOND DU LAC, WI 54935

Report Date 24-May-18

Project Name 310 E BROWN DEER RD  
 Project # 3043  
 Lab Code 5034636A  
 Sample ID SUMP WATER  
 Sample Matrix Water  
 Sample Date 5/15/2018

Invoice # E34636

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
Organic										
GRO/PVOC										
Gasoline Range Organics	< 100	ug/l	14	45	1	GRO95/8021		5/23/2018	CJR	1
Benzene	< 0.22	ug/l	0.22	0.69	1	GRO95/8021		5/23/2018	CJR	1
Ethylbenzene	< 0.53	ug/l	0.53	1.69	1	GRO95/8021		5/23/2018	CJR	1
Methyl tert-butyl ether (MTBE)	< 0.57	ug/l	0.57	1.82	1	GRO95/8021		5/23/2018	CJR	1
Toluene	< 0.45	ug/l	0.45	1.45	1	GRO95/8021		5/23/2018	CJR	1
1,2,4-Trimethylbenzene	< 0.73	ug/l	0.73	2.33	1	GRO95/8021		5/23/2018	CJR	1
1,3,5-Trimethylbenzene	< 0.75	ug/l	0.75	2.39	1	GRO95/8021		5/23/2018	CJR	1
m&p-Xylene	< 1	ug/l	1	3.17	1	GRO95/8021		5/23/2018	CJR	1
o-Xylene	< 0.58	ug/l	0.58	1.84	1	GRO95/8021		5/23/2018	CJR	1

"J" Flag: Analyte detected between LOD and LOQ


LOD Limit of Detection

LOQ Limit of Quantitation

Code	Comment
1	Laboratory QC within limits.

All solid sample results reported on a dry weight basis unless otherwise indicated. All LOD's and LOQ's are adjusted for dilutions but not dry weight. Subcontracted results are denoted by SUB in the analyst field.

Authorized Signature



# **Groundwater Quality Test Results After Excavation**

CHAIN OF CUSTODY RECORD

# Synergy

## Environmental Lab, Inc.

Chain # No 3303

Page 1 of 1

1990 Prospect Ct. • Appleton, WI 54914  
920-830-2455 • FAX 920-733-0631

<b>Sample Handling Request</b>	
Rush Analysis Date Required _____ (Rushes accepted only with prior authorization)	
<input checked="" type="checkbox"/> Normal Turn Around	

Lab I.D. #	
Account No.:	Quote No.:
Project #: 3043   Bayside Service	
Sampler: (signature) <u>Raghu B. Singh</u>	

Project (Name / Location): <u>310 E. Brown Deer Road, Bayside, WI 53217</u>	
Reports To:	Invoice To:
Company <u>Om Enterprises, Inc.</u>	Company <u>Om Enterprises, Inc.</u>
Address <u>124 W Scott Street</u>	Address <u>124 W Scott Street</u>
City State Zip <u>Fond du Lac, WI 54935</u>	City State Zip <u>Fond du Lac, WI 54935</u>
Phone <u>(262) 853-0712</u>	Phone <u>(262) 853-0712</u>
FAX	FAX

Analysis Requested												Other Analysis		
DRO (Mod DRO Sep 95)	GRO (Mod GRO Sep 95)	LEAD	NITRATE/NITRITE	OIL & GREASE	PAH (EPA 8270)	PCB	PVOC (EPA 8021)	PVOC + NAPHTHALENE	SULFATE	TOTAL SUSPENDED SOLIDS	VOC DW (EPA 524.2)	VOC (EPA 8260)	8-PCRA METALS	PID/ FID
								<input checked="" type="checkbox"/>						

Lab I.D.	Sample I.D.	Collection Date	Time	Comp	Grab	Filtered Y/N	No. of Containers	Sample Type (Matrix)*	Preservation
<u>S034707A</u>	<u>TANK BED WATER</u>	<u>5/29/18</u>	<u>5:45</u>		<input checked="" type="checkbox"/>	<u>N</u>	<u>03</u>	<u>GW</u>	<u>HCl</u>

Comments/Special Instructions (\*Specify groundwater "GW", Drinking Water "DW", Waste Water "WW", Soil "S", Air "A", Oil, Sludge etc.)

Sample Integrity - To be completed by receiving lab. Method of Shipment: <u>Chilled</u> Temp. of Temp. Blank _____ °C On Ice: <input checked="" type="checkbox"/> Cooler seal intact upon receipt: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Relinquished By: (sign) <u>Raghu B. Singh</u>	Time <u>1:10 PM</u>	Date <u>5/30/18</u>	Received By: (sign) _____	Time _____	Date _____
	Received in Laboratory By: <u>[Signature]</u>					
	Time: <u>1:10 PM</u> Date: <u>5-30-18</u>					

# Synergy Environmental Lab, INC.

1990 Prospect Ct., Appleton, WI 54914 \*P 920-830-2455 \* F 920-733-0631

RAGHU B SINGH, PH D  
 OM ENTERPRISES, INC.  
 124 W. SCOTT STREET  
 FOND DU LAC, WI 54935

Report Date 04-Jun-18

Project Name 310 E BROWN DEER RD  
 Project # 3043

Invoice # E34707

Lab Code 5034707A  
 Sample ID TANK BED WATER  
 Sample Matrix Water  
 Sample Date 5/29/2018

	Result	Unit	LOD	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
Organic										
PVOC + Naphthalene										
Benzene	40	ug/l	0.22	0.69	1	GRO95/8021	5/31/2018	CJR		1
Ethylbenzene	9.7	ug/l	0.53	1.69	1	GRO95/8021	5/31/2018	CJR		1
Methyl tert-butyl ether (MTBE)	< 0.57	ug/l	0.57	1.82	1	GRO95/8021	5/31/2018	CJR		1
Naphthalene	7.6	ug/l	1.7	5.38	1	GRO95/8021	5/31/2018	CJR		1
Toluene	39	ug/l	0.45	1.45	1	GRO95/8021	5/31/2018	CJR		1
1,2,4-Trimethylbenzene	16.4	ug/l	0.73	2.33	1	GRO95/8021	5/31/2018	CJR		1
1,3,5-Trimethylbenzene	8.8	ug/l	0.75	2.39	1	GRO95/8021	5/31/2018	CJR		1
m&p-Xylene	24.2	ug/l	1	3.17	1	GRO95/8021	5/31/2018	CJR		1
o-Xylene	11.8	ug/l	0.58	1.84	1	GRO95/8021	5/31/2018	CJR		1

"J" Flag: Analyte detected between LOD and LOQ


LOD Limit of Detection

LOQ Limit of Quantitation

Code	Comment
1	Laboratory QC within limits.

All solid sample results reported on a dry weight basis unless otherwise indicated. All LOD's and LOQ's are adjusted for dilutions but not dry weight. Subcontracted results are denoted by SUB in the analyst field.

Authorized Signature



# Certificates





Wisconsin Department of Agriculture, Trade and Consumer Protection

2811 Agriculture Drive, PO Box 8911, Madison, WI 53708-8911

Certification Number: 401225

Effective Date: May 31, 2018

Expires: May 31, 2020

Statute: 168.23

## Tank-System Site Assessor

Legal Name:

**Raghu B Singh**

124 W Scott St Fond Du Lac WI 54935-2270

### Certification

Attached is your Department of Agriculture, Trade and Consumer Protection (DATCP) certification card. This card is evidence that you are certified to perform work under Wis. Admin. Code §SPS 305.83.

Please review the information on the card. Please note for renewals your certification (credential) number has changed. If any information is incorrect, contact the Bureau of Weights and Measures at (608) 224-4942 or by email at [datcpweightsandmeasures@wi.gov](mailto:datcpweightsandmeasures@wi.gov). Also, please notify us of any address, e-mail or phone number changes to ensure proper delivery of future mail.

A renewal notice will be sent to the address on file approximately 30 days before the expiration date on the card. Renewals are contingent upon compliance with the requirements specified in Wis. Admin. Code §SPS 305.07.

This is your license/permit/certification/registration document. Post or carry as required by law. Non-transferrable - subject to revocation or suspension as provided by law.  
DMS-BIT-06S (03/18/10) Remove this card and carry as identification.

bits-16.qxd (rev. 11/17)

Raghu Singh  
124 W Scott St  
Fond Du Lac WI 54935-2270



Wisconsin Department of  
Agriculture, Trade and Consumer Protection

### Tank-System Site Assessor Certification

**Raghu B Singh**

Certification Number:

401225

Expiration Date:

May 31, 2020

124 W Scott St Fond Du Lac WI 54935-2270

DATCP Contact: (608) 224-4942



Wisconsin Department of Agriculture, Trade and Consumer Protection

2811 Agriculture Drive. PO Box 8911. Madison, WI 53708-8911

Registration Number: 468219

Effective Date: November 02, 2017  
Expires: November 02, 2019  
Statute: 168.23

## Tank Specialty Firm

Legal Name:

**OM Enterprises, Inc.**

124 W Scott St Fond Du Lac WI 54935-2270

Registration

Specialty Area(s): Site Assessment

This is your license/permit/certification/registration document. Post or carry as required by law. Non-transferrable - subject to revocation or suspension as provided by law.  
DMS-BIT-06S (03/18/10) Remove this card and carry as identification.

682-16-001 (rev. 03/16)

OM Enterprises, Inc.  
124 W Scott St  
Fond Du Lac WI 54935-2270



Wisconsin Department of  
Agriculture, Trade and Consumer Protection

### Tank Specialty Firm Registration

**OM Enterprises, Inc.**

Registration Number:  
468219

Expiration Date:  
November 02, 2019

124 W Scott St Fond Du Lac WI 54935-2270

DATCP Contact: (608) 224-4942