

From: Dick Lyster
To: [Sager, John E - DNR](#); [CULLY AKEY](#)
Subject: Minocqua Cleaners Oct Sampling
Date: Wednesday, December 5, 2018 9:34:26 AM
Attachments: [image002.png](#)
[image004.png](#)
[image006.png](#)

John and Cully; Hello, a quick note to share some monitoring results for samples we collected on October 29 and 30, 2018. We did collect a Municipal Well #3 sample and the sample had no detects for VOCs (Cully, I think you told me your plan is to take that well off-line if the district does not need it). We still have ES in the on-site monitoring wells and also at the monitoring well across the property in the St Germaine Street r/w., and other monitoring wells are below PAL. The extraction well on the property pumps ES water, while the replaced well EXW-4 on Pine Street continues to pump some contaminated water, with TCE above the PAL but not above the ES of 5.0.

We do not plan to be at property again until April 2019, so similar to the previous years, some visual checks for freezing are always good.

Let me know if you have any questions.

Thanks

Dick Lyster, MSA



Richard Lyster, PG, CPG | Team Leader

MSA Professional Services, Inc.

+1 (608) 355-8901

