


## DEPARTMENT OF UTILITIES

.meeting community needs...enhancing quality of life."

WASTEWATER DIVISION CENTRAL BUILDING MAINTENANCE 2006 E. Newberry Street • Appleton, WI 54915-2758 920/832-5945 • 920/832-5514 • Fax 920/832-5949

November 1, 2006

Jennifer Borski Hydrogeologist, Remediation and Redevelopment Program **Wisconsin Department of Natural Resources** 625 East County Road Y, Suite 700 Oshkosh, Wisconsin 54901 – 9731



## RE: N.W. MAUTHE SUPERFUND SITE Semi-Annual Pretreatment Program Compliance Monitoring Results

Dear Ms. Borski:

The City of Appleton, Pretreatment Program staff visited your facility within the last six months in order to obtain a sample of the wastewater discharged from your site to the sanitary sewer.

This outfall(s) sample(s) was tested for process-specific pollutants, if applicable, identified in your wastewater discharge permit and Local Limit pollutant parameters identified in your discharge permit and the sewer use ordinance, Chapter 20, Utilities.

The City of Appleton, Pretreatment Program conducts this analysis for compliance monitoring twice, annually for each permitted industry. Pretreatment compliance monitoring is a required component of the state and federal mandated program implementation.

Your facility's effluent was analyzed for the pollutants listed in FORM 13 (attached) that have sample results indicated. This form is the monitoring summary which is submitted to the Wisconsin Department of Natural Resources on a semi-annual basis to reflect all monitoring for the City of Appleton Pretreatment Program.

## Your wastestream was compliant for all parameters indicated above for the sample(s) identified on Form 13.

If you have any questions regarding this notification please contact me at 920 - 832 - 2353.

Best regards,

Jessica A. Garratt Pretreatment Coordinator Form 13 Evaluation Form 1

## INDUSTRIAL USER MONITORING SUMMARY REPORT (Summation of POTW Compliance Monitoring and Industrial Self-Monitoring)

۰,

.'

	N. W. Mauthe Superfund Site / SIU 00 - 21 725 South Outagamie Street						-	Sampling Poir	nt (Refer to Cor	itrol
Location							_	Document)	001 discharge valve in	
									Pretreatment Facility	
SAMPLE TYPE			FP TC (G)	FP TC (G	FP TC (G	FP TC G	FP TC G	FP TC G	FP TC G	FP TC G
			SAMPLE	SAMPLE	SAMPLE	SAMPLE	SAMPLE	SAMPLE	SAMPLE	SAMPLE
			02/23/06	06/27/06	10/05/06					
			DATE	DATE	DATE	DATE	DATE	DATE	DATE	DATE
			SELF	SELF X	SELF	SELF	SELF	SELF	SELF	SELF
			SCHEDUL X	SCHEDUL	SCHEDUL X	SCHEDUL	SCHEDUL	SCHEDUL	SCHEDUL	SCHEDUL
		LIMITS	UNSCHED	UNSCHED	UNSCHED	UNSCHED	UNSCHED	UNSCHED	UNSCHED	UNSCHED
PARAMETERS	UNIT	MAX / AVG	DEMAND	DEMAND	DEMAND	DEMAND	DEMAND	DEMAND	DEMAND	DEMAND
Flow, Regulated	GPD									
Flow, Unregulated	GPD	Variable								
Flow, Dilutional	GPD									
Flow, Total	GPD	Variable								
Arsenic	mg/L	1.0	< 0.0012	< 0.0076	< 0.00011					
Cadmium	mg/L	0.3	< 0.0001	< 0.00074	< 0.0001					
Chromium	mg/L	7.0	0.08	0.7	4.575					
Copper	mg/L_	3.5	< 0.0005	0.0016	0.0068					
Cyanide	mg/L	1.0	< 0.005	< 0.0094	0.01					
Lead	mg/L	2.0	< 0.0008	< 0.0034	< 0.001					
Nickel	mg/L	2.0	0.0022	0.0021	0.0026					
Silver	mg/L									
Zinc	mg/L	10.0	< 0.010	< 0.020	< 0.010			_		
Total Toxic Organics	mg/L									
Aluminum	mg/L	70.0	0.0021	< 0.2	0.037					
Hex Chromium	mg/L			0.35						
Mercury	mg/L	0.002	< 0.0002	< 0.000072	< 0.0002					
	mg/L_									
	mg/L									
pН	s. u.	5.0-12.4	9.11	7.6	7.62					
Oil & Grease	mg/L				·					
Phosphorus	mg/L									
						1			1	