



8040 Excelsior Drive  
Suite 303  
Madison, WI 53717  
P 608.327.5050 F: 608.531.2873

[gannettfleming.com](http://gannettfleming.com)

July 19, 2023  
File #34283.000

Candace Sykora  
Wisconsin Department of Natural Resources  
890 Spruce Street  
Baldwin, WI 54002

Re: National Presto Industries, Inc., Superfund Site, Eau Claire, Wisconsin  
Quarterly Discharge Monitoring Report for April through June 2023  
USEPA CERCLIS ID 006196174  
WDNR BRRTS 02-09-000267 and FID 609038320

Dear Candace:

On behalf of National Presto Industries, Inc. (NPI), Gannett Fleming, Inc. is providing NPI's quarterly discharge monitoring report (DMR) for the referenced period. The enclosed DMR provides June 13, 2023, analytical data from Southwest Corner extraction well EW-6 only. Manhole MH-18 was not sampled on June 13, 2023, because EW-6 was not officially operating then. On February 23, 2023, EW-6 was taken offline to start a 12-month trial shutdown, as approved by the Wisconsin Department of Natural Resources (WDNR) and US Environmental Protection Agency (USEPA).

Submittal of this quarterly DMR is required by the WDNR. Feel free to contact me if you have any questions or need additional information.

Sincerely,  
GANNETT FLEMING, INC.

A handwritten signature in black ink, appearing to be "CW", written over a dotted line.

Clifford C. Wright, P.E., P.G.  
Project Engineer

CCW/jec  
Enc.

ecc: Glenn Lautenbach (USEPA)  
Derrick Paul (NPI)  
Chelsea Payne (Gannett Fleming)



NATIONAL PRESTO INDUSTRIES, INC.  
EAU CLAIRE, WISCONSIN

QUARTERLY DISCHARGE MONITORING RESULTS FOR 04/01/2023 - 06/30/2023

Sample Location	Substance Concentration (µg/l), Result Qualifier (RQ), and Percent Removal (% Removal)															Flow Rate <sup>(1)</sup> (MGD)
	1,1,1-Trichloroethane			1,1-Dichloroethane			1,1-Dichloroethylene			Tetrachloroethylene			Trichloroethylene (TCE)			
	µg/l	RQ	% Removal	µg/l	RQ	% Removal	µg/l	RQ	% Removal	µg/l	RQ	% Removal	µg/l	RQ	% Removal	
EW-1R <sup>(2)</sup>	ns		na	ns		na	ns		na	ns		na	ns		na	0.0
EW-2 <sup>(2)</sup>	ns		na	ns		na	ns		na	ns		na	ns		na	0.0
Influent 1	ns		na	ns		na	ns		na	ns		na	ns		na	0.0
Effluent 1	ns		na	ns		na	ns		na	ns		na	ns		na	0.0
EW-5 <sup>(3)</sup>	ns		na	ns		na	ns		na	ns		na	ns		na	0.0
EW-6 <sup>(4)</sup>	2.25	A	na	2.0	A	na	0.58	UA	na	1.05	A	na	2.7	A	na	0.0
Influent 2	2.25	A	na	2.0	A	na	0.58	UA	na	1.05	A	na	2.7	A	na	0.0
Effluent 2	ns		--	ns		--	ns		--	ns		--	ns		--	0.0
Manhole MH-18	ns		na	ns		na	ns		na	ns		na	ns		na	0.0
Discharge Limit	NLE			NLE			50			50			100			NLE

NOTES:

Concentrations are in micrograms per liter (µg/l) or parts per billion (ppb).

Sample collected from EW-6 on 03/21/23. MH-18 was not sampled on 03/21/23 because EW-6 was offline and <1,000 gal of groundwater were pumped.

Cascade aerator influent results (Influent 1 and Influent 2) were calculated based on the extraction well data (EW-1R ,etc.), where applicable.

Influent 1 = Discharge (flow) from extraction wells EW-1R and EW-2.

Influent 2 = Discharge (flow and flow-weighted concentrations) from EW-5 and EW-6.

Manhole MH-18 = Effluent 1 (+) Effluent 2 for flow. Effluent 2 = MH-18 for concentrations because MH-18 and CAS-2R are less than 60 feet apart.

A = Average of original sample and duplicate.

U = Compound not detected at or above the detection limit, which is the value shown.

na = Not applicable.

NLE = No limit established.

ns = No sample collected for discharge monitoring.

-- = % Removal not calculated because at least one influent concentration was less than the limit of detection or no sample was collected.

FOOTNOTES:

(1) Flow rate in millions of gallons per day (MGD) calculated based on metered volume (0 gallons) and pumping days (0) during period shown.

(2) Melby Road Disposal Site extraction wells EW-1R and EW-2 are currently shut down, as approved by the WDNR and USEPA.

(3) Southwest Corner extraction well EW-5 is currently shut down, as approved by the WDNR and USEPA.

(4) Southwest Corner extraction well EW-6 was taken offline to start a 12-month trial shutdown on 02/23/23, as approved by the WDNR and USEPA.