



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700

December 19, 2018

Mr. John Czappa  
210 S. Washington St.  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. Czappa:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 210 S. Washington St., Unity, Clark County, and inform you of the contaminants found and provide additional information.


Tetrachloroethene (PCE) was detected at 5.2 parts per billion (ppb) which exceeds the state groundwater enforcement standard of 5 parts per billion. Trichloroethylene was detected at 0.36 ppb which is below the state groundwater enforcement standard of 5 ppb. Cis-1,2-Dichloroethene was also detected at 0.57 ppb which is below the state groundwater enforcement standard of 70 ppb.

The DNR has been providing you with a temporary emergency water supply. For questions about a temporary water supply, the cause of the contamination or the status of clean-up efforts, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3750

December 19, 2018

Lunity  
Joseph H. McCune  
P.O. Box 201  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. McCune:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 210 West Clark Street, Unity, Clark County, and inform you of the contaminants found and provide additional information. The well was sampled for Volatile Organic Compounds (VOCs) by DNR on October 22, 2018 as part of the monitoring required for the chlorinated solvent contamination issue in the Village of Unity.

In the pre-treatment water sample tetrachloroethene and trichloroethene were detected at concentrations of 220 micrograms per liter ( $\mu\text{g/l}$ ) and 21  $\mu\text{g/l}$ , respectively, which exceed their groundwater quality standard of 5.0  $\mu\text{g/l}$  for each compound. State groundwater standards are established to The VOC compound cis-1,2-dichloroethene was also detected in your water sample, however this compound was detected below state groundwater standards.

**No VOCs were detected in either of the post-treatment samples collected from this well.** Based on the water sample results the carbon treatment system installed at this location is effective in removing the VOC-related contaminants from your water.

If you have health-related questions about chlorinated solvents in drinking water, contact Robert Leischow at the Clark County Health Department at (715) 743-5105. If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
Peggy Norris – DNR DG  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 20, 2018

Mr. Scott Jones  
919 Martin Dr.  
Marshfield, WI 54449

Subject: Notification of Private Well Test Results

Dear Mr. Jones:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 211 E. Clark St., Unity, Marathon County, and inform you of the contaminants found and provide additional information. Please share these results with any tenants that may be living at the residence in Unity.

The well was sampled for Volatile Organic Compounds (VOCs) by DNR on October 23, 2018 as part of the monitoring required for the chlorinated solvent contamination issue in the Village of Unity. Tetrachloroethene was detected at a concentration of 9.8 micrograms per liter ( $\mu\text{g/l}$ ) which exceeds the groundwater quality standard for tetrachloroethene of 5.0  $\mu\text{g/l}$ . State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water. When a state water standard is exceeded, the state may require the party responsible for the contaminant release to restore groundwater quality. The VOC compounds cis-1,2-dichloroethene and trichloroethene were also detected in your water sample, however these compounds were detected below state groundwater enforcement standards.

If you have health-related questions about chlorinated solvents in drinking water, contact Dale Grosskurth at the Marathon County Health Department at (715) 261-1907.

For questions about the cause of the contamination or the status of clean-up efforts, please contact me at (715) 839-3750 or [Matthewa.thompson@wisconsin.gov](mailto:Matthewa.thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Dale Grosskurth – Marathon County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700

December 19, 2018

Jason and Sierra Snapp  
211 West Cook St.  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. and Mrs. Snapp:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 211 West Cook St., Unity, Clark County, and inform you of the contaminants found and provide additional information.

The well was sampled for Volatile Organic Compounds (VOCs) by DNR on October 22, 2018 as part of the monitoring required for the chlorinated solvent contamination issue in the Village of Unity. Tetrachloroethene was detected at a concentration of 0.61 micrograms per liter ( $\mu\text{g/l}$  or ppb) which does not exceed the groundwater quality standard for tetrachloroethene of 5.0  $\mu\text{g/l}$ . State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water. When a state water standard is exceeded, the state may require the party responsible for the contaminant release to restore groundwater quality.

Based on the results from this and past water samples the DNR is providing you with a temporary emergency water supply. For questions about a temporary water supply, the cause of the contamination or the status of clean-up efforts, please contact me at (715) 839-3750 or [MatthewA.Thompson@wisconsin.gov](mailto:MatthewA.Thompson@wisconsin.gov). If you have health-related questions about chlorinated solvents in drinking water, contact Robert Leischow at the Clark County Health Department at (715) 743-5105.

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Frank and Angela Makovec  
220 West Taylor Street  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. and Mrs. Makovec:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results for the post-treatment water sample collected from the well at 220 West Taylor Street, Unity, Wisconsin, and inform you of the contaminants found and provide additional information.

The well was sampled for Volatile Organic Compounds (VOCs) by DNR on October 22, 2018. Tetrachloroethane was detected at 1.2 micrograms per liter ( $\mu\text{g/l}$ ). This concentration is below state groundwater standards. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have health-related questions about chlorinated solvents in drinking water, contact Robert Leischow at the Clark County Health Department at (715) 743-5105. If you have any questions about the well water sample results, the cause of the contamination or the status of clean-up efforts, please contact me at (715) 839-3750 or [MatthewA.Thompson@wisconsin.gov](mailto:MatthewA.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire,  
Robert Leischow – Clark County Health Department,



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Mr. Dillon Scheer  
221 S. Madison St.  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. Scheer:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 221 S. Madison St., Unity, Clark County, and inform you of the contaminants found and provide additional information.

The well was sampled for Volatile Organic Compounds (VOCs) by DNR in October 22, 2018 as part of the monitoring required for the chlorinated solvent contamination issue in the Village of Unity. Tetrachloroethene was detected at a concentration of 19 micrograms per liter ( $\mu\text{g}/\text{l}$ ) which exceeds the groundwater quality standard for tetrachloroethene of 5.0  $\mu\text{g}/\text{l}$ .

The VOC compounds cis-1,2-dichloroethene and trichloroethene were also detected in your water sample, however these compounds were detected below state groundwater standards.

When contaminant levels in water exceed state standards, the Wisconsin Department of Health Services recommends that people not consume the water either by drinking or by eating food prepared with the water. Based on the results from this water sample the DNR has offered to provide you with a temporary emergency water supply.

If you have health-related questions about chlorinated solvents in drinking water, contact Robert Leischow at the Clark County Health Department at (715) 743-5105. For questions about a temporary water supply, the cause of the contamination or the status of clean-up efforts, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Ms. Dawn High  
231 West Cook Street  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Ms. High:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 231 West Cook Street, Unity, Clark County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.

The well was sampled for VOCs by DNR on October 22, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Ray Neustedt  
251 S. Washington St.  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. Loertscher:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 251 S. Washington Street, Unity, Clark County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.

The well was sampled for VOCs by DNR on October 22, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department





**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Layah Hickerson  
261 South Washington Street  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Ms. Hickerson:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 261 South Washington Street, Unity, Clark County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.

The well was sampled for VOCs by DNR on October 22, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Mr. Adam Shelley  
271 South Madison Street  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. Shelley:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 271 South Madison Street, Unity, Clark County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.


The well was sampled for VOCs by DNR in October 22, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [MatthewA.Thompson@wisconsin.gov](mailto:MatthewA.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire,  
Robert Leischow – Clark County Health Department,



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Mr. and Mrs. Jeremy and Jill Bertsinger  
285 South Madison Street  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. and Mrs. Bertsinger:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 285 South Madison Street, Unity, Clark County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.

The well was sampled for VOCs by DNR on October 23, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Ron Loertscher  
285 S. Washington St.  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. Loertscher:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 285 S. Washington Street, Unity, Clark County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.

The well was sampled for VOCs by DNR on October 22, 2018, as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

November 28, 2018

Mr. Chad Much  
300 South Haslow Street  
Spencer, WI 54479

Subject: Notification of Private Well Test Results

Dear Mr. Much:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results for the water sample collected on October 25, 2018 from the well at 290 South Washington Street, Unity, Wisconsin, and inform you that tetrachloroethylene was detected at 0.71 parts per billion which is below the state groundwater enforcement standard of 5.0 parts per billion.

If you have health-related questions about chlorinated solvents in drinking water, contact Robert Leischow at the Clark County Health Department at (715) 743-5105. If you have any questions about the well water sample results, the cause of the contamination or the status of clean-up efforts, please contact me at (715) 839-3750 or [MatthewA.Thompson@wisconsin.gov](mailto:MatthewA.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire,  
Robert Leischow – Clark County Health Department,



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Mr. Cody Wirtala  
291 South Madison St.  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. Wirtala:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 231 West Cook Street, Unity, Clark County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.

The well was sampled for VOCs by DNR on October 22, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Mr. & Mrs. Clyde & Irene Schreiber  
310 West Clark St.  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. and Mrs. Schreiber:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 310 West Clark Street, Unity, Clark County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.

The well was sampled for VOCs by DNR on October 22, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



## State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Mr. Al Revling  
1801 South Schmidt St.  
Marshfield, WI 54488

Subject: Notification of Private Well Test Results – 101 South Madison St. Unity, WI

Dear Mr. Revling:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 101 South Madison St., Unity, Clark County, and inform you of the post-treatment results and provide additional information. The well was sampled for Volatile Organic Compounds (VOCs) by DNR on October 22, 2018, as part of the monitoring required for the chlorinated solvent contamination issue in the Village of Unity.

In the pre-treatment water sample tetrachloroethene was detected at a concentration of 65 micrograms per liter ( $\mu\text{g/l}$ ), which exceeds the groundwater quality standard of 5.0  $\mu\text{g/l}$  for this compound. Trichloroethene was detected at a concentration of 5.1 micrograms per liter ( $\mu\text{g/l}$ ), which exceeds the groundwater quality standard of 5.0  $\mu\text{g/l}$  for this compound. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water. The VOC compounds trans-1,2-Dichloroethylene and cis-1,2-dichloroethene were also detected in your water sample, however these compounds were detected below state groundwater standards.

**No VOCs were detected in the post-treatment sample collected from this well.** Based on the water sample results the carbon treatment system installed at this location is effective in removing the VOC-related contaminants from your water.

If you have health-related questions about chlorinated solvents in drinking water, contact Robert Leischow at the Clark County Health Department at (715) 743-5105.


If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department





**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Rodney Kohl  
102 South Russell Street  
Unity, WI 54488

Subject: Notification of Private Well Test Results – 102 S. Russell St., Unity, WI

Dear Mr. Kohl:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 102 South Russell Street, Unity, Marathon County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.


The well was sampled for VOCs by DNR on October 22, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Dale Grosskurth – Marathon County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018.

Ms. Shanna Miller  
111 S. Madison St.  
Unity, WI 54488

Subject: Notification of Private Well Test Results - 111 S. Madison St., Unity, WI

Dear Ms. Miller:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 111 S. Madison St., Unity, Clark County, and inform you that Volatile Organic Compounds (VOCs) contaminants were found in the water sample collected from your well on October 22, 2018.

Tetrachloroethene (PCE) was detected at 5.7 parts per billion (ppb) which exceeds the state groundwater enforcement standard of 5 parts per billion. Trichloroethylene was detected at 0.49 ppb which is below the state groundwater enforcement standard of 5 ppb. Cis-1,2-Dichloroethene was also detected at 0.94 ppb which is below the state groundwater enforcement standard of 70 ppb.

At the time of sample collection, the home was vacant, if the house becomes occupied please let me know as the DNR can supply emergency bottled water to occupants of the house.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [MatthewA.Thompson@wisconsin.gov](mailto:MatthewA.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Mr. & Mrs. Robin & Heidi Maldonis  
101 South Main St.  
Unity, WI 54488

Subject: Notification of Private Well Test Results – 101 S. Main St. Unity, WI

Dear Mr. & Mrs. Maldonis:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 120 South Russell Street, Unity, Marathon County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.

The well was sampled for VOCs by DNR on October 22, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Dale Grosskurth - Marathon County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

November 28, 2018

Ms. Bonnie Weideman  
101 South Washington Street  
Unity, WI 54488

Subject: Notification of Private Well Test Results  
101 S. Washington St. Unity, WI

Dear Ms. Weideman:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 101 South Washington Street, Unity, Clark County, and inform you that volatile organic compound tetrachloroethylene (PCE) was found in the water sample collected from your well at a concentration of 0.37 parts per billion. This is below the state groundwater enforcement standard of 5.0 parts per billion.

The well was sampled for VOCs by DNR on October 23, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.thompson@wisconsin.gov](mailto:Matthewa.thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

**Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director**

**Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076**

December 19, 2018

Postal Building & Leasing Company  
720 Olive Street  
Suite 1630  
St. Louis, MO 63101

Subject: Notification of Private Well Test Results,  
Unity Post Office Building  
102 South Front Street, Unity, Wisconsin

Dear Property Manager:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 102 South Front Madison St., Unity, Marathon County, Wisconsin, and inform you of the contaminants found and provide additional information. The well was sampled for Volatile Organic Compounds (VOCs) by DNR on October 22, 2018 as part of the monitoring required for the chlorinated solvent contamination issue in the Village of Unity.

In the pre-treatment water sample tetrachloroethene and cis-1,2-Dichloroethylene were detected at concentrations of 62 micrograms per liter ( $\mu\text{g/l}$ ) and 19  $\mu\text{g/l}$ , respectively. The concentration of tetrachloroethene exceeds the state groundwater quality standard for of 5  $\mu\text{g/l}$ . State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

No VOCs were detected in either of the post-treatment samples collected from this well. Based on the water sample results the carbon treatment system installed at this location is effective in removing the VOC-related contaminants from your water.

If you have health-related questions about chlorinated solvents in drinking water, contact Dale Grosskurth at the Marathon County Health Department at (715) 261-1907.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

  
Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Dale Grosskurth – Marathon County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Ms. Inez Reigel  
120 South Russell Street  
Unity, WI 54488

Subject: Notification of Private Well Test Results - 120 South Russell Street, Unity, WI

Dear Ms. Reigel:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 120 South Russell Street, Unity, Marathon County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.

The well was sampled for VOCs by DNR on October 22, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

A handwritten signature in black ink, appearing to read 'Matt Thompson'.

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Dale Grosskurth – Marathon County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

November 28, 2018

Ms. Cindy Bennett  
124 East Clark St.  
Unity, WI 54488

Subject: Notification of Private Well Test Results - 124 East Clark Street, Unity, WI

Dear Ms. Bennett:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 124 East Clark Street, Unity, Marathon County, and inform you of the contaminants found and provide additional information.

The well was sampled for Volatile Organic Compounds (VOCs) by DNR on October 23, 2018 as part of the monitoring required for the chlorinated solvent contamination issue in the Village of Unity.

In the pre-treatment water sample tetrachloroethene (PCE) was detected at a concentration of 76 micrograms per liter ( $\mu\text{g/l}$ ), which exceeds its groundwater quality standard of 5.0  $\mu\text{g/l}$  for this compound. Trichloroethene was not detected in this sample. The VOC compound cis-1,2-dichloroethene was also detected in your water sample, however this compound was detected below state groundwater standards.

Based on the water sample results the carbon treatment system installed in your home is effective in removing the VOC-related contaminants from your water, **there were no contaminant detections in the post-system water samples.**

If you have health-related questions about chlorinated solvents in drinking water, contact Dale Grosskurth at the Marathon County Health Department at (715) 261-1907.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Dale Grosskurth – Marathon County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Bad Habits Bar and Grill  
140 North Front Street  
Unity, WI 54488

Subject: Notification of Private Well Test Results,  
Bad Habits Bar and Grill - 140 North Front Street, Unity, Wisconsin

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 140 North Front St., Unity, Marathon County, and inform you of the contaminants found and provide additional information. The well was sampled for Volatile Organic Compounds (VOCs) by the DNR on October 23, 2018 as part of the monitoring required for the chlorinated solvent contamination issue in the Village of Unity.

In the pre-treatment water sample tetrachloroethene was detected at a concentration of 26 micrograms per liter ( $\mu\text{g/l}$ ), which exceeds the groundwater quality standard of 5.0  $\mu\text{g/l}$  for this compound. The VOC compounds trichloroethene and cis-1,2-dichloroethene were also detected in your water sample, however these compounds were detected below state groundwater standards.

No VOCs were detected in either of the post-treatment samples collected from this well. Based on the water sample results the carbon treatment system installed at this location is effective in removing the VOC-related contaminants from your water.

If you have health-related questions about chlorinated solvents in drinking water, contact Dale Grosskurth at the Marathon County Health Department at (715) 261-1907. For questions about the cause of the contamination or the status of clean-up efforts, please contact me at (715) 839-3750 or [MatthewA.Thompson@wisconsin.gov](mailto:MatthewA.Thompson@wisconsin.gov)

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Dale Grosskurth – Marathon County Health Department  
Marty Nessman – DNR DG  
Peggy Norris – DNR DG  
David Rozeboom – DNR Eau Claire





State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 20, 2018

Jake Lucht  
150 N. Washington St.  
Unity, WI 54488

Subject: Notification of Private Well Test Results - 150 N. Washington St., Unity, WI

Dear Mr. Lucht:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 150 N. Washington St., Unity, Clark County, and inform you of the contaminants found and provide additional information. The well was sampled for Volatile Organic Compounds (VOCs) by DNR on October 23, 2018 as part of the monitoring required for the chlorinated solvent contamination issue in the Village of Unity.

**No VOCs were detected in the post-treatment water sample collected from your well.**

Based on the water sample results the carbon treatment system installed in your home is effective in removing the VOC-related contaminants from your water.

In the pretreatment water sample tetrachloroethene was detected at a concentration of 76 micrograms per liter ( $\mu\text{g/l}$ ) which exceeds the groundwater quality standard for tetrachloroethene of 5.0  $\mu\text{g/l}$ . State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water. When a state water standard is exceeded, the state may require the party responsible for the contaminant release to restore groundwater quality. The VOC compounds cis-1,2-dichloroethene and trichloroethene were also detected in your pre-treatment water sample, however these compounds were detected below state groundwater standards.

If you have health-related questions about chlorinated solvents in drinking water, contact Robert Leischow at the Clark County Health Department at (715) 743-5105. If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700

December 19, 2018

Mr. Matt Porath  
151 South Madison Street  
Unity, WI 54488

Subject: Notification of Private Well Test Results - 151 South Madison Street, Unity, WI

Dear Mr. Porath:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 151 South Madison Street, Unity, Clark County, and inform you that tetrachloroethene (PCE) was detected in the sample at a concentration of 0.44 ppb. This is below the state groundwater standard of 5 ppb.

The well was sampled for VOCs by DNR on October 23, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700

December 19, 2018

Roger Hamus  
161 North Washington Street  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. Hamus:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 161 North Washington Street, Unity, Clark County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.

The well was sampled for VOCs by DNR on October 22, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700

December 19, 2018

Mr. and Mrs. Jeff and Carrie Bloome  
161 South Washington Street  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. and Mrs. Bloome:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 161 South Washington Street, Unity, Clark County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.

The well was sampled for VOCs by DNR on October 22, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.


If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

A handwritten signature in black ink, appearing to read 'M. Thompson'.

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700

December 19, 2018

Mr. and Mrs. Don and Paula Kieser  
171 South Washington Street  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. and Mrs. Kieser:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 171 South Washington Street, Unity, Clark County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.

The well was sampled for VOCs by DNR on October 22, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700

December 19, 2018

Mr. & Ms. Gary & Linda Meyer  
191 S. Madison St.  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. & Ms. Meyer:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 191 S. Madison St., Unity, Clark County, and inform you of the contaminants found. The well was sampled for Volatile Organic Compounds (VOCs) by DNR on October 22, 2018, as part of the monitoring required for the chlorinated solvent contamination issue in the Village of Unity.

In the pretreatment water sample tetrachloroethene was detected at a concentration of 8.1 micrograms per liter ( $\mu\text{g/l}$ ) which exceeds the groundwater quality standard for tetrachloroethene of 5.0  $\mu\text{g/l}$ . State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water. When a state water standard is exceeded, the state may require the party responsible for the contaminant release to restore groundwater quality. The VOC compounds cis-1,2-dichloroethene and trichloroethene were also detected in your pre-treatment water sample, however these compounds were detected below state groundwater standards.

**No VOCs were detected in the post-treatment water samples collected from your well.** Based on the water sample results the carbon treatment system installed in your home is effective in removing the VOC-related contaminants from your water.

If you have health-related questions about chlorinated solvents in drinking water, contact Robert Leischow at the Clark County Health Department at (715) 743-5105. If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 19, 2018

Mr. Peter Sweeney  
191 South Washington Street  
Unity, WI 54488

Subject: Notification of Private Well Test Results

Dear Mr. Sweeney:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 191 South Washington Street, Unity, Clark County, and inform you that Volatile Organic Compounds (VOCs) contaminants were not found in the water sample collected from your well.


The well was sampled for VOCs by DNR on October 22, 2018 as part of the routine groundwater monitoring program being conducted in the Village of Unity. State groundwater standards are established to protect public health and welfare by limiting the levels of contaminants in groundwater and drinking water.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5  
David Rozeboom – DNR Eau Claire  
Robert Leischow – Clark County Health Department



**State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES**

Scott Walker, Governor  
Dan Meyer, Secretary  
Dan Baumann, Regional Director

Eau Claire Service Center  
1300 W. Clairemont Avenue  
Eau Claire, Wisconsin 54701  
Telephone 715-839-3700  
FAX 715-839-6076

December 27, 2018

Joshua J. Wieseler  
305 East 1<sup>st</sup> St. Apt. 1  
Janesville, MN 56048

Subject: Notification of Private Well Test Results – 131 N. Madison Street, Unity, WI

Dear Mr. Wieseler:

This letter is to notify you that the Department of Natural Resources (DNR) received analytical test results collected from the well at 131 N. Madison Street, Unity, Marathon County, and inform you of the contaminants found and provide additional information.

The well was sampled for Volatile Organic Compounds (VOCs) by DNR on December 03, 2018 as part of the monitoring required for the chlorinated solvent contamination issue in the Village of Unity.

In the pre-treatment water sample tetrachloroethene (PCE) was detected at a concentration of 240 micrograms per liter ( $\mu\text{g/l}$ ), which exceeds its groundwater quality standard of 5.0  $\mu\text{g/l}$  for this compound. Trichloroethene (TCE) was detected in this sample at 18  $\mu\text{g/l}$ , which exceeds its groundwater quality standard of 5.0  $\mu\text{g/l}$ . The VOC compounds cis-1,2-dichloroethene and trans-1,2-dichloroethylene were also detected in your water sample at 58  $\mu\text{g/l}$  and 1.2  $\mu\text{g/l}$ , respectively, however these compounds were detected below state groundwater standards.

Based on the water sample results the carbon treatment system installed in your home is effective in removing the VOC-related contaminants from your water, **there were no contaminant detections in the post-system water samples.**

If you have health-related questions about chlorinated solvents in drinking water, contact Dale Grosskurth at the Marathon County Health Department at (715) 261-1907.

If you have any questions about the well water sample results, please contact me at (715) 839-3750 or [Matthewa.Thompson@wisconsin.gov](mailto:Matthewa.Thompson@wisconsin.gov).

Sincerely,

  
Matt Thompson  
Hydrogeologist

cc: Marty Nessman – DNR DG-5



David Rozeboom – DNR Eau Claire  
Dale Grosskurth – Marathon County Health Department