

Date: 2/6/14	Prepared By: S. Broughman		
	Yes	No	Measurement(s)/Comments
AHA Completed:	V		carbon change out
Overall System:			
System treating water:		\checkmark	see notes
System discharge flowrate (gpm):			
Coagulation Tank:	(3 <u></u>	,	
Operation is Normal:			
pH reading from portable meter:			
Portable calibrated?			
Tank probes calibrated?			
Flocculation Tank:			
Operation is Normal:			
Polymer System:			
Operation is Normal:			
Water level probes cleaned?			
DAF:			
Operation is Normal:			
Turbidity:			
GAC Feed Pump:			
Operation is Normal:			
Bag Filters:			
Operation is Normal:			
Filters changed?			
Starting pressure reading:			
Final pressure reading:			
Pre-Filter Vessel:			
Operation is Normal:			
Filter backwashed?	Ħ	Ħ	
Starting pressure reading:		LI	
Final pressure reading:			

GAC Vessels:	
Operation is Normal:	
Lead GAC pressure reading:	
Lag GAC pressure reading:	
Neutralization Tank:	
Operation is Normal:	
pH reading from portable meter;	
Portable calibrated?	
Tank probes calibrated?	
COW:	
Operation is Normal;	
RDVF:	
Batch treated:	
Bags of DE used:	F (474-5)
Volume of polymer used:	
Beginning float tank level:	
Ending float tank level:	
Greased?	PESAN CONTRACTOR - CR
RDVF Feed Pump:	
Operation is Normal:	
Biovent Blower:	
Operation is Normal:	

Arrived on site

Check system inside and outside - good

North Shore arrives on site to pick up Scaffolding and Mob off site

Did work orders and custodial duties

Siemens arrive on site to fill carbon tanks,

Support Siemens in filling tank

Siemens cleanup and Mob off site

Secure plant - leave site, let carbon soak.

Location(s)	Sample IDs	Analysis

s		<u></u>
<u> </u>		-

Date: 2/19/14	Prepared By: S. Broughman		
	Yes	No	Measurement(s)/Comments
AHA Completed:		\checkmark	
Overall System:			
System treating water:	lacksquare		
System discharge flowrate (gpm):			58.7
Coagulation Tank:			
Operation is Normal:	\checkmark		2002/0
pH reading from portable meter:			5.23
Portable calibrated?	\checkmark		
Tank probes calibrated?		√	
Flocculation Tank:			
Operation is Normal:	\checkmark		good floc
Polymer System:			
Operation is Normal:			
Water level probes cleaned?	\checkmark		
<u>DAF:</u>			
Operation is Normal:	lacksquare		
Turbidity:			in-line = 5.83 manual 12.34
GAC Feed Pump:		(<u></u>	
Operation is Normal:	\checkmark		C Francisco
Bag Filters:			
Operation is Normal:			
Filters changed?		\checkmark	
Starting pressure reading:			0.3
Final pressure reading:			0.8
Pre-Filter Vessel:			
Operation is Normal:	\checkmark		
Filter backwashed?	\checkmark		
Starting pressure reading:		4	6.0
Final pressure reading:			1.3

	Yes	No	Measurement(s)/Comment(s)
GAC Vessels:			
Operation is Normal:	\checkmark		
Lead GAC pressure reading:			-0.0
Lag GAC pressure reading:			0.2
Neutralization Tank:			
Operation is Normal:	\checkmark		
pH reading from portable meter:			6.46
Portable calibrated?	\checkmark		
Tank probes calibrated?			
COW:			
Operation is Normal:	\checkmark		skim scum
RDVF:			
Batch treated:		\checkmark	
Bags of DE used:			
Volume of polymer used:			
Beginning float tank level:			
Ending float tank level:			
Greased?		✓	EA 1957 (0.0000) 31
RDVF Feed Pump:			
Operation is Normal:			
Biovent Blower:			
Operation is Normal:		\checkmark	off-line

Arrived on site

Check system inside and outside - good

Set up for system samples, collect cooler, get ice, pack cooler, did COC, and fed-x air bill.

Zack with Nijhuis arrives on site to go over DAF, did AHA, PTSP, signed all paperwork

Set up for BW, turn off system, turn on potable water, start BW, 3 CYCLES, BW complete, turn off water, restart GAC, restart system, let stabilize.

Did work orders and custodial duties

Check floc tank

Check in-line meter

Check DAF - air, sludge, effluent water

Spray down DAF

Skim scum layer in COW

Check polymer makeup

Calibrated portable ph meter, test both tanks, manually test turbidity

Set system alarm

Secure plant - leave site

Location(s)	Sample IDs	Analysis

Date: 3/9/14	Prepared By: S. Broughman		
	Yes	No	Measurement(s)/Comments
AHA Completed:		\checkmark	2
Overall System:			*
System treating water:	\checkmark		
System discharge flowrate (gpm):			57.6
Coagulation Tank:			
Operation is Normal:	\checkmark		
pH reading from portable meter:			5.19
Portable calibrated?	V		
Tank probes calibrated?		1	
Flocculation Tank:			
Operation is Normal:	1		good floc
Polymer System:			
Operation is Normal:	\checkmark		
Water level probes cleaned?	1		
DAF:			
Operation is Normal:	\checkmark		turned up air in DAF to get better lift of sludge.
Turbidity:			in-line = 5.63 manual 12.95
GAC Feed Pump:			
Operation is Normal:	\checkmark		
Bag Filters:	12 27 23 28	v t:	
Operation is Normal:	\checkmark		
Filters changed?		V	
Starting pressure reading:			1.0
Final pressure reading:			3.3
Pre-Filter Vessel:			
Operation is Normal:	1		
Filter backwashed?			200000000000000000000000000000000000000
Starting pressure reading:		—	6.0
Final pressure reading:			1.4

	Yes	No	Measurement(s)/Comment(s)
GAC Vessels:			
Operation is Normal:	\checkmark		
Lead GAC pressure reading:			0.2
Lag GAC pressure reading:			0.2
Neutralization Tank:	<u> </u>	1 <u>25 - 124</u>	
Operation is Normal:	\checkmark		
pH reading from portable meter:			6.47
Portable calibrated?	\checkmark		
Tank probes calibrated?		\checkmark	
COW:			
Operation is Normal:	✓		skim scum
RDVF:			
Batch treated:		\checkmark	
Bags of DE used:			
Volume of polymer used:			
Beginning float tank level:			
Ending float tank level:			
Greased?		\checkmark	
RDVF Feed Pump:		52 W	
Operation is Normal:			
Biovent Blower:		69	
Operation is Normal:		\checkmark	off-line

Arrived on site

Check system inside and outside - good

Pump UST

Set up for BW, turn off system, turn on potable water, start BW, 2 cycles, BW COMPLETE, turn off water, restart GAC, restart system, let stabilize.

Did BOBCAT Inspection

Change out full bin of filter cake with empty

Check floc tank

Check in-line meter

Check DAF - air, sludge, effluent water

Skim scum layer in COW

Check polymer makeup

Calibrated portable ph meter, test both tanks, manually test turbidity

Set system alarm

Secure plant - leave site

Location(s)	Sample IDs	Analysis
		_
	,	
	,	<u> </u>
	-	:
		-
<u> </u>	-	
		-
		-

Date: 5/2/14	Prepared By: S. Broughman		
	Yes	No	Measurement(s)/Comments
AHA Completed:		\checkmark	
Overall System:			
System treating water:	\checkmark		
System discharge flowrate (gpm):			51.4
Coagulation Tank:			
Operation is Normal:	\checkmark		
pH reading from portable meter:			5.14
Portable calibrated?	1		
Tank probes calibrated?		1	
Flocculation Tank:			
Operation is Normal:	\checkmark		good floc
Polymer System:			
Operation is Normal:	\checkmark		
Water level probes cleaned?	\checkmark		
DAF:			
Operation is Normal:	\checkmark		
Turbidity:			in-line = 1.81 manual 3.02
GAC Feed Pump:			
Operation is Normal:	\checkmark		
Bag Filters:	-		
Operation is Normal:	\checkmark		
Filters changed?		\checkmark	
Starting pressure reading:			0.6
Final pressure reading:			0.8
Pre-Filter Vessel:			
Operation is Normal:	\checkmark		
Filter backwashed?		1	
Starting pressure reading:			1.9
Final pressure reading:			2.7

	Yes	No	Measurement(s)/Comment(s)
GAC Vessels:			
Operation is Normal:	\checkmark		
Lead GAC pressure reading:			0.6
Lag GAC pressure reading:			0.3
Neutralization Tank:			
Operation is Normal:	\checkmark		
pH reading from portable meter:			6.48
Portable calibrated?	1		
Tank probes calibrated?		✓	
COW:			
Operation is Normal:	\checkmark		skim scum
RDVF:			
Batch treated:	Ш	\checkmark	
Bags of DE used:			
Volume of polymer used:			
Beginning float tank level:			
Ending float tank level:	r omene	NS	
Greased?		\checkmark	
RDVF Feed Pump:		F	
Operation is Normal:			
Biovent Blower:			
Operation is Normal:		\checkmark	off-line

Arrived on site

Check system inside and outside - good

Check floc tank

Check in-line meter

Replace tubing on turbidity pump

Check DAF - air, sludge, effluent water

Spray down DAF

Skim scum layer in COW

Check polymer makeup

Calibrated portable ph meter, test both tanks, manually test turbidity

Janssen Saw arrives on site to drop off (6) 1/2 pallets

Charge batteries for vaults

Call in meeting with Mike

Did work orders and custodial duties

Did BOBCAT Inspection

Called Republic Services to add another day for trash pick up for the next 3 weeks. (spring cleaning)

Signed time card

Set system alarm

secure plant - leave site

Location(s)	Sample IDs	Analysis
	-	-
	-	
	p.3.44646.mm	
		-0.00

Date: 5/3/14	Prepared By: S. Broughman		
AHA Completed:	Yes	No	Measurement(s)/Comments
Overall System:	Ш	<u> </u>	
System treating water:	\checkmark		
			52.8
System discharge flowrate (gpm):			02.0
Coagulation Tank:			
Operation is Normal:	\checkmark		5.18
pH reading from portable meter:			5.10
Portable calibrated?	\checkmark		
Tank probes calibrated?		\checkmark	
Flocculation Tank:			
Operation is Normal:	V		good floc
Polymer System:			
Operation is Normal:	\checkmark		
Water level probes cleaned?	\checkmark		
DAF:			
Operation is Normal:	\checkmark		
Turbidity:			in-line = 2.34 manual 5.06
GAC Feed Pump:			
Operation is Normal:	\checkmark		
Bag Filters:			
Operation is Normal:	\checkmark		
Filters changed?		1	
Starting pressure reading:			0.8
Final pressure reading:			1.1
Pre-Filter Vessel:			
Operation is Normal:	1		
Filter backwashed?		H	
Starting pressure reading:			5.0
Final pressure reading:			1.5
The state of the s			

	Yes	No	Measurement(s)/Comment(s)
GAC Vessels:			
Operation is Normal:	\checkmark		
Lead GAC pressure reading:			0.7
Lag GAC pressure reading:			0.3
Neutralization Tank:			
Operation is Normal;	\checkmark		
pH reading from portable meter:	Part was to		6.45
Portable calibrated?	\checkmark		
Tank probes calibrated?		\checkmark	
COW:			
Operation is Normal:	\checkmark		skim scum
RDVF:			
Batch treated:		\checkmark	6
Bags of DE used:			
Volume of polymer used:			
Beginning float tank level:			10 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
Ending float tank level:			
Greased?		\checkmark	
RDVF Feed Pump:			
Operation is Normal:			
Biovent Blower:	2	10 22 40	3
Operation is Normal:		\checkmark	off-line

Arrived on site

Check system inside and outside - good

Set up for BW, turn off system, turn on potable water, start BW, 2 CYCLES, BW complete, turn off water, restart GAC, restart system, let stabilize.

Pump out vaults 10,12 and 13

Charge batteries for vaults

Did work orders and custodial duties

Check floc tank

Check in-line meter

Check DAF - air, sludge, effluent water

Spray down DAF

Skim scum layer in COW

Check polymer makeup

Calibrated portable ph meter, test both tanks, manually test turbidity

Did spring cleaning

Set system alarm

Secure plant - leave site

Location(s)	Sample IDs	Analysis	
-			
-	Service de la constante de la		
	_		
		s = ==================================	
<u>,</u>			
<u></u>			
,			