

Put on BRTS
3/23/15 (99)

Richard, Philip E - DNR

From: Ree, Timothy <tree@croworld.com>
Sent: Monday, March 23, 2015 9:16 AM
To: Richard, Philip E - DNR
Cc: Martin.LindaB@epamail.epa.gov (Martin, Linda)
Subject: Penta Wood - February 2015 eDMR Long Report ~COR-086165~
Attachments: 359563.pdf

Phil,

Please find a copy of the Penta Wood February 2015 eDMR (Discharge Monitoring Report) long report submitted electronically in the WDNR Web Access Management System (WAMS) today (3/23/2015).

Regards,

Tim Ree
Conestoga-Rovers & Associates (CRA)
1801 Old Highway 8 NW, Suite 114
St Paul, MN 55112

Phone: 651.639.0913
Direct: 651.639-0439 (ext. 338)
Cell: 651.592.7697
Fax: 651.639.0923
Email: tree@CRAworld.com
www.CRAworld.com

Think before you print 
Perform every task the safe way, the right way, every time!

This communication and any accompanying document(s) are confidential and are intended for the sole use of the addressee. If you are not the intended recipient, please notify me at the telephone number shown above or by return e-mail and delete this e-mail and any copies. You are advised that any disclosure, copying, distribution, or the taking of any action in reliance upon the communication without consent is strictly prohibited. Thank you.

CRA and GHD have merged! To learn more, visit www.CRAworld.com/ghd

Wastewater Discharge Monitoring Long Report

For DNR Use Only

Facility Name: PENTA WOOD SF SITE
 Contact Address: 1801 Old Highway 8 NW, Ste 114
 Saint Paul, MN 55112-2307
 Facility Contact: Timothy Ree, Engineer
 Phone Number: (651) 639-0913
 Reporting Period: 02/01/2015 - 02/28/2015
 Form Due Date: 03/21/2015
 Permit Number: 0061531

Date Received:	
DOC:	339247
FIN:	16088
FID:	807027980
Region:	Northern Region
Permit Drafter:	Drafter not set
Reviewer:	Kathy M. Bartilson
Office:	Spoooner

Sample Point	001	001	001	001
	Description	Treated Groundwater Discharge	Treated Groundwater Discharge	Treated Groundwater Discharge
Parameter	211	368	307	1287
Description	Flow Rate	Pentachloro- phenol	Naphthalene	Diesel Range Organics (DRO)
Units	gpd	ug/L	ug/L	mg/L
Sample Type	CONTINUOUS	GRAB	GRAB	GRAB
Frequency	DAILY	WEEKLY	MONTHLY	MONTHLY
Sample Results	Day 1	70747		
	2	70486		
	3	71707	0.13	
	4	70877		
	5	75856		
	6	47813		
	7	76530		
	8	74459		
	9	68071		
	10	69179	0.085	
	11	71730		
	12	69275		
	13	58615		
	14	43145		
	15	42258		
	16	43048		
	17	52541		
	18	67895	0.048	
	19	67907		
	20	69889		
	21	70972		
	22	69855		
	23	69218		
	24	70464	0.022	
	25	70432		
	26	70316		
	27	70144		
	28	70676		
	29			
	30			
	31			

	Sample Point	001	001	001	001
	Description	Treated Groundwater Discharge	Treated Groundwater Discharge	Treated Groundwater Discharge	Treated Groundwater Discharge
	Parameter	211	368	307	1287
	Description	Flow Rate	Pentachloro- phenol	Naphthalene	Diesel Range Organics (DRO)
	Units	gpd	ug/L	ug/L	mg/L
Summary Values	Monthly Avg	65860.892857143	0.07125		
	Daily Max	76530	0.13		
	Daily Min	42258	0.022		
Limit(s) in Effect	Monthly Avg		0.10	0	8
QA/QC Information	LOD		0.016*Footnote		
	LOQ		0.1*Footnote		
	QC Exceedance	N	N	N	N
	Lab Certification		998027800		

*Footnote: QA/QC Information is not identical for each day, so the value shown is the maximum of all values for LOD/LOQ data or the first Lab found for Lab Cert data.

Footnotes (DNR Use Only; Instructions for completing this form that are unique for your facility may be displayed here.)

General Remarks

Naphthalene and Diesel Range Organics (DRO) analyses were inadvertently not performed during February 2015. Naphthalene has not been detected at a concentration exceeding the substantive WPDES permit limit (8 ug/L) in any effluent samples since 2006, including effluent samples collected in January and March 2015. DRO has not been detected in any effluent samples since 2008, including effluent samples collected in January and March 2015. There is no substantive WPDES permit limit for DRO.

The daily flowrates reported above are estimated based on the effluent flowmeter flowrates.

Laboratory Quality Control Comments

Submitted by Timothy Ree(timdree0042) on 3/23/2015 9:10:21 AM