

Ref on 15/11/15
6/15/15
(99)

Richard, Philip E - DNR

From: Ree, Timothy <tree@croworld.com>
Sent: Friday, June 12, 2015 2:42 PM
To: Richard, Philip E - DNR
Cc: Martin, Linda (martin.lindab@epa.gov)
Subject: Penta Wood - April through June 2015 eDMR Short Report ~COR-086165~
Attachments: 368722.pdf

Phil,

Please find a copy of the Penta Wood April through June 2015 eDMR (Discharge Monitoring Report) short report submitted electronically in the WDNR Web Access Management System (WAMS) today (6/12/2015).

Regards,

Tim Ree
Conestoga-Rovers & Associates (CRA)
1801 Old Highway 8 NW, Suite 114
St Paul, MN 55112

Phone: 651.639.0913
Direct: 651.639-0439 (ext. 338)
Cell: 651.592.7697
Fax: 651.639.0923
Email: tree@CRAworld.com
www.CRAworld.com

Think before you print 
Perform every task the safe way, the right way, every time!

This communication and any accompanying document(s) are confidential and are intended for the sole use of the addressee. If you are not the intended recipient, please notify me at the telephone number shown above or by return e-mail and delete this e-mail and any copies. You are advised that any disclosure, copying, distribution, or the taking of any action in reliance upon the communication without consent is strictly prohibited. Thank you.

We are changing our name to GHD in July! To learn more about CRA's merger with GHD, visit
www.CRAworld.com/ghd

Wastewater Discharge Monitoring Short Report

For DNR Use Only

Facility Name : PENTA WOOD SF SITE
 Contact Address : 1801 Old Highway 8 NW, Ste 114
 Saint Paul, MN 55112-2307
 Facility Contact : Timothy Ree, Engineer
 Phone Number : (651) 639-0913
 Reporting Period : 04/01/2015 - 06/30/2015
 Form Due Date : 07/21/2015
 Permit Number : **0061531**

Date Received:
 DOC: 344833
 FIN: 16088
 FID: 807027980
 Region: Northern Region
 Permit Drafter: Drafter not set
 Reviewer: Kathy M. Bartilson
 Office: Spooner

Sample Point	Parameter #	Parameter	Date Sample	Sample Type	Sample Results	Units	Limit Type	Limit	LOD	LOQ	QC Exceed?	Lab Certification
701	368	Pentachloro- phenol	04/06/2015	GRAB	1500	ug/L		*****	15	95	N	998027800
701	368	Pentachloro- phenol	05/06/2015	GRAB	200	ug/L		*****	7.6	49	N	998027800
701	368	Pentachloro- phenol	06/02/2015	GRAB	550	ug/L		*****	3.9	25	N	998027800
001	105	Chloride	04/06/2015	GRAB	15	mg/L		*****	0.41	1.0	N	999518190
001	35	Arsenic, Total Recoverable	04/06/2015	GRAB	0.72	ug/L	Monthly Avg	5(0)	0.18	5.0	N	999518190
001	147	Copper, Total Recoverable	04/06/2015	GRAB	<0.002	mg/L		*****	0.00075	0.002	N	999518190
001	553	Zinc, Total Recoverable	04/06/2015	GRAB	0.012	mg/L		*****	0.0073	0.02	N	999518190
001	251	Iron, Total Recoverable	04/06/2015	GRAB	<0.1	mg/L		*****	0.016	0.1	N	999518190
001	277	Manganese, Total Recoverable	04/06/2015	GRAB	0.5	mg/L		*****	0.0011	0.005	N	999518190

Wastewater Discharge Monitoring Short Report

Footnotes (DNR Use Only; Instructions for completing this form that are unique for your facility may be displayed here.)

General Remarks

Laboratory Quality Control Comments

The concentration reported for arsenic was noted with a "B" qualifier by the laboratory, indicating that the compound was found in the blank and sample. The concentrations reported for arsenic and zinc were noted with "J" qualifiers by the laboratory and were less than the respective LOQs but greater than the respective LODs, indicating that the concentrations are approximate values.

Submitted by Timothy Ree(timdree0042) on 6/12/2015 2:31:38 PM