

# WARZYN



Engineers & Scientists  
Environmental Services  
Waste Management  
Water Resources  
Site Development  
Special Structures  
Geotechnical Analysis

OFFICE COPY

December 21, 1989

Ms. Theresa Evanson  
Wisconsin Department of Natural Resources  
Bureau of Solid and Hazardous Waste Management  
101 S. Webster Street, GEF II  
Madison, Wisconsin 53707

RECEIVED  
DEC 27 1989  
BUREAU OF SOLID -  
HAZARDOUS WASTE MANAGEMENT

Re: Copies of Correspondence  
Interim Remedial Measures  
Refuse Hideaway Landfill  
Project No. 13928.41

Dear Ms. Evanson:

Enclosed is one (1) copy of the December 1989 Engineering Design report, entitled "Partial Gas and Leachate Extraction System", Warzyn Project No. 13928.41. It includes the enclosed text and Warzyn Drawings 13928-1 through 13928-7. These documents are being provided to you for distribution to Mr. John DeBeck, per your request. The estimated cost to reproduce the design text and drawings is \$28.00.

If you have any questions or comments regarding the above subject matter, please contact us.

Sincerely,

WARZYN ENGINEERING INC.

Joel V. Schittone, P.E.  
Project Manager

BEM/dlk/JVS  
[jlv-112-53]



Engineers & Scientists  
Environmental Services  
Waste Management  
Water Resources  
Site Development  
Special Structures  
Geotechnical Analysis

December 19, 1989

Ms. Theresa A. Evanson  
Wisconsin Department of Natural Resources  
Bureau of Solid and Hazardous Waste Management  
101 S. Webster Street, GEF II Building  
Madison, Wisconsin 53707

RECEIVED  
DEC 27 1989  
BUREAU OF SOLID -  
HAZARDOUS WASTE MANAGEMENT

OFFICE COPY

Re: Engineering Design/Partial Gas and Leachate Extraction System  
Interim Remedial Measures  
Refuse Hideaway Landfill  
Agreement No. 81217.89-2  
Project No. 13928.41

Dear Ms. Evanson:

Enclosed are three copies of the Engineering Design for the Partial Gas and Leachate Extraction System for the Refuse Hideaway Landfill project. The design includes the enclosed text and separate drawing set.

Draft design drawings and calculations were submitted to the Wisconsin Department of Natural Resources (WDNR) for review on November 1 and 3, 1989, respectively, and much of the contents of the enclosed text were discussed with the WDNR during several meetings and telephone conversations. Subsequent comments made by the WDNR have been incorporated into this document.

If you have any questions, please contact us.

Sincerely,

WARZYN ENGINEERING INC.

Brian E. McVean  
Project Engineer

Joel V. Schittone, P.E.  
Project Manager

JVS/kjw/JVS [wpmisc-112-54] 13928.41

Enclosure: Engineering Design-Partial Gas and Leachate Extraction System (3)

cc: Ms. Susan M. Fisher - WDNR  
Mr. Mark Giesfeldt - WDNR  
Ms. Sally Kefer - WDNR (w/o encl)

Warzyn Engineering Inc  
One Science Court  
University Research Park  
PO Box 5385  
Madison, Wisconsin 53705  
(608) 273-0440



---

**Partial Gas and Leachate  
Extraction System  
Interim Remedial Measures  
Refuse Hideaway Landfill  
Town of Middleton  
Dane County, Wisconsin**

**December 1989**

TABLE OF CONTENTS

	<u>Page No.</u>
INTRODUCTION .....	1
General .....	1
Purpose and Scope .....	1
DESIGN .....	2
General .....	2
Gas Collection and Conveyance .....	3
Basis For Design .....	3
Gas/Leachate Extraction Wells .....	3
Gas Header Piping .....	4
Trenching/Cover Restoration .....	4
Blower Station .....	5
Flare Station .....	5
Condensate/Driplegs .....	6
Leachate Collection and Conveyance .....	6
Leachate Pump .....	6
Leachate Conveyance Piping .....	7
Leachate Holding Tank .....	7
Leachate Removal and Disposal .....	8
Leachate/Gas Monitoring Wells .....	8
Basis For Design .....	8
Monitoring Well Design .....	9
Temporary Storage, Sampling and Characterization of Excavated Waste ...	9
Temporary Storage .....	10
Sampling Procedure for Excavated Waste .....	10
Characterization of Excavated Waste .....	11
Disposal On-Site .....	11
Disposal Off-Site .....	12
CONSTRUCTION OBSERVATION .....	12
SYSTEM PERFORMANCE STANDARDS .....	12
Purpose .....	12
Piping .....	13
Blower .....	13
Flare .....	13
Submersible Pumps .....	13
Leachate Holding Tank .....	14

**DRAWINGS**

DRAWING 13928-1 - PARTIAL GAS AND LEACHATE EXTRACTION SYSTEM LAYOUT
DRAWING 13928-2 - DETAILS
DRAWING 13928-3 - DETAILS
DRAWING 13928-4 - DETAILS
DRAWING 13928-5 - DETAILS
DRAWING 13928-6 - LEACHATE HOLDING TANK DETAILS
DRAWING 13928-7 - TITLE SHEET

**APPENDICES**

APPENDIX A - GAS FLOW ESTIMATE
APPENDIX B - BLOWER SIZING CALCULATIONS
APPENDIX C - FLARE SIZING/SELECTION
APPENDIX D - LEACHATE EXTRACTION AND STORAGE CALCULATIONS





PARTIAL GAS AND LEACHATE EXTRACTION SYSTEM  
INTERIM REMEDIAL MEASURES  
REFUSE HIDEAWAY LANDFILL  
DANE COUNTY, WISCONSIN

INTRODUCTION

General

The Wisconsin Department of Natural Resources (WDNR) has retained Warzyn Engineering Inc. (Warzyn) to provide engineering and construction services in relation to Interim Remedial Measures at the Refuse Hideaway Landfill (Landfill). The Landfill is located in the Town of Middleton, Dane County, Wisconsin and has been identified as a source of groundwater contamination, including the presence of volatile organic compounds (VOCs) at three local residential water supply wells. Additionally, off-site migration of landfill gas, in excess of the lower explosive limit (LEL) of methane has been recorded.

As an interim remedial measure to address these environmental contamination/hazard issues, Warzyn is providing a partial gas and leachate extraction system in a design-build format. This work is being performed under Agreement No. 81217.89-2, and is described in Warzyn's May 1989 Proposal (Proposal No. 81217.89), and October 9 and 19, 1989 documents entitled "Revised Scope of Work" (Project No. 13928.40).

Purpose and Scope

This design document, consisting of Warzyn Drawings 13928-1 through 13928-7 and this text, will provide the WDNR an opportunity to review the proposed partial gas and leachate extraction system design. Draft design drawings and calculations were submitted to the WDNR for review on November 1 and 3, 1989, respectively, and much of the contents of this text were discussed with the WDNR during several meetings and telephone conversations. Subsequent comments made by the WDNR have been incorporated into this document.

The intent of this partial leachate and gas extraction system is to: 1) evaluate leachate drawdown data and the gas well radius of influence and gas flow characteristics, for use in final design of a full gas and leachate extraction system; and 2) to reduce leachate head levels in the landfill and reduce off-site migration of landfill gas. This partial system design includes two gas/leachate extraction wells, three leachate/gas monitoring wells, buried gas header and leachate conveyance piping, blower and flare stations and a leachate holding tank.

As part of the partial system design activities, Warzyn designed a conceptual layout for a full gas and leachate extraction system. To minimize future construction costs and minimize duplication of efforts, Warzyn has designed this partial system to be compatible with the conceptual full system design. It is anticipated that the five wells (two extraction and three monitoring), buried piping, blower station and leachate (and condensate) holding tank will be directly incorporated into the full system when it is installed. The partial system flare station will be available as a back-up flare for the full system. Refer to Drawing 13928-1 for the partial system layout.

## DESIGN

### General

Design of this partial system includes the installation of two gas/leachate extraction wells (extraction wells) located along the southern perimeters of the site (within the refuse fill limits). The conceptual full system design includes a total of thirteen extraction wells, five of which are to be located along the southern perimeter. Because of the potential for elevated leachate levels along the southern perimeter, Warzyn was directed by the WDNR to size the partial system for a minimum of five extraction wells, assuming that only two were to be installed initially.

Because it is anticipated that a full system will be installed in the near future, as much of the partial system was designed for incorporation into the

conceptual full system as economically feasible. For example, the wells, buried piping, blower station and the leachate holding tank have been sized for the anticipated full system design capacities.

The full system design referenced is a conceptual plan and is based on Warzyn's past experience in gas and leachate extraction system designs and utilizing minimal site-specific data from this Landfill. A full system will be designed by Warzyn under the current Agreement after pump test data is available from the partial system.

### Gas Collection and Conveyance

#### Basis For Design

The proposed landfill gas (LFG) extraction system is designed to extract methane gas produced by anaerobic decomposition of refuse. Refer to Appendix A for an estimate of gas flow generation and the assumptions made. The gas/leachate extraction wells serve the dual purpose of extracting gas as well as leachate. A vacuum will be created to withdraw gas from the Landfill, which will then be burned in a flare. System performance may depend on the permeability of the fill, and refuse composition, moisture content, placement and compaction techniques.

#### Gas/Leachate Extraction Wells

Each gas/leachate extraction well will be constructed of a non-perforated section of 6-in. diameter Schedule 80 polyvinyl chloride (PVC) pipe extending into a perforated section of 8-in. diameter Schedule 80 PVC pipe. The well pipes will be placed in 36-in. diameter boreholes, with the annular space around the perforated portion of the pipe consisting of a clear stone pack (refer to Detail 1 of 2 on Drawing 13928-2). The wells will extend to the base of the Landfill. A bentonite seal will be installed at the bottom of the borehole. The partial system has been conservatively sized to draw a suction of 10 in. water column, gauge (WC) at 50 standard cubic feet per minute (SCFM) at each well.

Wells will be constructed with perforated pipe extending from the well bottom to approximately 20 ft below the Landfill surface. A 6-in. x 8-in. PVC



reducing slip coupler will provide a telescoping connection at the location where the 6-in. diameter non-perforated well pipe slides into the 8-in. diameter perforated pipe. This coupling was provided to attempt to compensate for landfill settlement. It is anticipated that wells will range from 49 ft to 52 ft in depth. The radius of influence is estimated to be a minimum of 150 ft, based on field experience at previous sites.

Each well head assembly will include a flexible tubing connection to the gas header pipe to allow for differential settlement. A butterfly valve will be provided at each well for control of gas flow rate. Ports will be provided on each well for gas sampling and flow rate measurement. In addition, two 1-in. diameter PVC pipes will be installed at each well to allow liquid level measurement without dismantling the well head. The well head assemblies will be insulated to minimize the potential for freezing of condensate in the winter. Refer to Detail 1 of 3 on Drawing 13928-3 for a typical well head detail.

#### Gas Header Piping

The gas header system will transport the landfill gas from the extraction wells to the blower station and will be constructed with provision for extension in the future by providing blind flanges in the gas header system at key locations. The pipe inverts will be installed a minimum of 4 ft below final grade for frost protection and to minimize condensate formation. A continuous warning ribbon and tracing wire will be installed above the pipe to alert excavators of the pipe location and aid in locating the pipe in the future. To allow for potential differential settlement, liquids drainage, and removal of condensate formed in the pipes, a minimum slope of 2.0% will be maintained in the headers. Typical pipe bedding details are shown on Drawing 13928-3.

#### Trenching/Cover Restoration

The gas header and leachate conveyance pipes within the landfill refuse limits will be placed in the same trench (see Detail 2 of 3 on Drawing 13928-3). The trench will be constructed through the landfill cover and may extend into the uppermost layer of refuse. The landfill cover areas disturbed will be

restored to a condition equal to or exceeding the condition of the existing cover at that location. Clay materials and placement methods will be in conformance with s. NR 504.07(4), Wisconsin Administrative Code.

#### Blower Station

The LFG blower has been sized to draw gas from the wells and discharge it at a pressure suitable for proper flare operation. Blower sizing calculations are addressed in Appendix B. The New York Blower pressure blower selected is suitable for the full system's flow rate of approximately 650 SCFM and the vacuum/pressure requirements of the two- or five-well partial system. The blower can be upgraded by changing wheel and motor sizes to supply the pressure needed for full system operation, based on available data.

A flame arrestor will be installed at the inlet of the blower to isolate the header system and well field from an explosion or flame initiated at the blower station. A butterfly valve will be installed ahead of the flame arrestor to assist in controlling and balancing the system. Ports will also be provided on the blower inlet piping for monitoring of gas flow rate and for pressure and gas sampling.

#### Flare Station

LFG extracted from the wells will be combusted on-site by a VAREC 239A Series Waste Gas Burner. The Varec 239A flare is suitable for burning saturated, low BTU waste gas and will have an optional cycling electric pilot ignitor. LFG will be used as the pilot gas. The 6-in. diameter flare has the capacity to handle flows from the two-well extraction system as well as having the added capacity to handle a five-well extraction system. Flare sizing calculations and a detailed description of the Varec 239A Series Waste Gas Burner are included in Appendix C. A flame arrestor will be placed at the inlet of the flare to isolate the system from an explosion or flame initiated at the flare.

A condensate dripleg (DL2) will be placed between the blower and the flare to collect and drain condensate formed in the gas discharge pipe. Condensate will be routed by gravity to the leachate holding tank. Dripleg DL2 is illustrated on Detail 2 of 4 on Drawing 13928-4.



### Condensate/Driplegs

Condensate produced by the cooling of the saturated gas mixture in the gas header system will be removed using a dripleg assembly. A dripleg consists of a liquid-filled trap and a connection to the leachate conveyance system, where it will then drain to the leachate holding tank. Dripleg DL1 is located within the refuse limits, on the gas header piping connecting the extraction wells and the blower station. Dripleg DL2 is located between the blower and flare to collect and drain condensate formed in the gas discharge pipe. Refer to Drawing 13928-4 for dripleg details. Condensate flow is estimated to be negligible.

The leachate/condensate conveyance pipes located outside the landfill refuse limits will be encased in 2 ft of compacted clay (see Detail 3 of 3 on Drawing 13928-3). Clay materials and placement methods will be the same as for cover restoration activities performed during trenching activities. In-situ soils excavated will be used to supplement the clay backfill in trenches located outside the landfill refuse limits.

### Leachate Collection and Conveyance

#### Leachate Pump

A Grundfos Model 5S 4-in. diameter stainless steel submersible pump will be installed in each well found to have an elevated leachate level. The pump's flow rate capacity ranges from 2 to 7 gpm, depending on the liquid head. Refer to Appendix D for pump sizing calculations and pump specifications. The submersible leachate extraction pump will discharge through a 1-in. diameter hose which will be piped through stainless steel (SS) fittings mounted in the well head. The well pump will be suspended by a stainless steel cable for ease of removal. After exiting the well head, the leachate discharge pipe will transition from SS to HDPE and extend below grade for connection to the 6-in. SDR 17 HDPE gravity leachate conveyance pipe. This pipe will convey leachate to the leachate holding tank by gravity flow. The leachate discharge piping at the well head will be heat traced and insulated. Refer to Drawings 13928-2 and -3 for applicable details.

The wells are designed so that pumps will be placed as close to the well pipe bottom as possible while minimizing the intake of accumulated sediment. Controls for each pump will be mounted in a control panel and include a manual shut-off switch, elapsed time meter and an automated pump controller. The pump controller includes a timer which activates the pump at pre-set intervals ranging from 15 minutes to 5 hours, and an amperage/flow sensing device which will shut off the pump when the well runs dry. Once the pump is activated by the timer, it will operate until the well runs dry, at which time it will be shut off by the amperage/flow sensing device. The pump will then remain off for the pre-set time interval.

#### Leachate Conveyance Piping

The leachate conveyance piping will be placed in the same trench with the gas header piping (see Detail 2 of 3 on Drawing 13928-3). The gravity leachate conveyance piping has been sized for compatibility with the full system design assuming open channel flow and discharge from each well to be 2 to 7 gpm (see Appendix D). The flow contribution from condensate is assumed negligible.

#### Leachate Holding Tank

A double-wall steel STI-P<sub>3</sub> tank will be installed below grade. The 25,000 gal tank was selected based on an estimate of the future steady state leachate production after the standing head has been drawn down (see Appendix D). The double-wall STI-P<sub>3</sub> steel tank was selected because of monitoring capabilities of the interstice, warranty, cost, delivery time and compatibility with leachate. The interstice will be monitored with a conductivity sensor which will shut down the well pumps in the event moisture is detected between the tank walls. Additionally, this alarm will activate an audible alarm and warning light on-site, with capability for future telemetry (through a modem and phone connection).

The leachate holding tank will have two, high-level float sensors which will sound an alarm when triggered. This alarm will also shut down the well pumps, activate an audible alarm and warning light on-site (different colors for the different alarm conditions), with capability for future telemetry. Two

independent float sensors have been included as a redundant safety precaution to minimize the risk of having leachate overflow from the tank. Leachate and condensate will be pumped from the holding tank on a regular basis.

The leachate holding tank will be ballasted with deadmen to minimize the potential for buoyancy. The Steel Tank Institute (STI) will warranty the tank for 30 years provided the installation is in accordance with their standards. This STI-P<sub>3</sub> system relies heavily on the cathodic protection attached to the tank. To facilitate piping access, a STI-86 containment system has been included which will contain tank piping in a 42-in. diameter manway with a ladder. For details of the leachate holding tank and STI-86 containment system, refer to Drawing 13928-6.

#### Leachate Removal and Disposal

Leachate will be removed from the holding tank by a suction stand pipe with a quick-connect coupling for tanker truck suction pump adaptability. A leachate loadout facility drain pipe has been included for a future full system loadout apron to convey potential spills back to the tank. The pipe will be temporarily capped during partial system construction. It is anticipated that initially there may be frequent tank truck loading due to the high volume of standing leachate in the landfill. After this standing head has been drawn down, it is estimated that a steady state condition would require a less frequent tank truck load out. We are anticipating that a leachate acceptance agreement will be made between WDNR and Madison Metropolitan Sewage District (MMDS) for ultimate acceptance and treatment of the leachate. Tanker trucks will transport the leachate and condensate mixture to the MMDS Wastewater Treatment Plant after the agreement is made.

#### Leachate/Gas Monitoring Wells

##### Basis For Design

Three leachate/gas monitoring wells (LH4, LH5 and LH6) will be installed between the two gas/leachate extraction wells. These monitoring wells will be constructed with multi-depth probes and will be spaced at horizontal intervals of 25, 50, 50, and 90 ft, respectively, between extraction wells GW1 and GW2



(refer to Drawing 13928-1 for leachate/gas monitoring well locations). These monitoring wells have been designed and located to provide the capability to monitor leachate head levels and LFG pressures and quality both before and after partial system operation. This data will be used to evaluate the effectiveness of the partial system and aid in determining the extraction well spacing during full system design activities.

#### Monitoring Well Design

Each leachate/gas monitoring well will consist of a single 6-in. diameter Schedule 80 PVC leachate head monitoring well and three 1-in. diameter Schedule 80 PVC gas monitoring probes, all placed in a 3-ft diameter borehole (see Detail 2 of 2 on Drawing 13928-2). The leachate head well will extend to approximately 1 ft off the landfill base, with the bottom 10 ft screened (perforated). The three gas monitoring probes will be placed at different elevations within the borehole with each screened interval sealed with bentonite. The three gas monitoring probes will be set at approximately the same elevations relative to each of the leachate/gas monitoring wells, to better evaluate the extraction well performance.

#### Temporary Storage, Sampling and Characterization of Excavated Waste

Characterization of waste excavated during drilling activities is required before the waste can be permanently disposed. Wastes derived from drilling of the extraction and monitoring wells will serve as "test borings" for collection of samples of the waste excavated during the gas header and leachate conveyance piping installation. These wells will be spaced on the order of 25 to 90 ft on-center and wastes penetrated are anticipated to be representative of the wastes excavated during trenching activities. Waste excavated will be temporarily stored on-site in a manner which allows for accessibility and identification. Completion of characterization testing will indicate if the refuse possess characteristics of a hazardous waste. If the waste is characterized as hazardous, it will be removed and disposed off-site; otherwise it will be permanently disposed on-site.

It is estimated that refuse excavated in the construction of the extraction and monitoring wells will include approximately 100 cu yd of material. This material will be contained on-site, such that it will not be wind blown and exposure to precipitation and surface water run-on will be minimized.

#### Temporary Storage

The excavated refuse will be temporarily stored in a containment cell constructed as follows:

- Existing cover soils will be removed and salvaged ( a minimum of approximately 1 ft of soils will remain above the waste);
- A synthetic membrane (plastic sheeting or tarps) will be placed and covered with approximately 1 ft of cover soils (to form a temporary liner);
- The cell will be graded such that surface water run-on will be diverted around the contaminant cell and water exposed to waste, if any, will be contained;
- Waste materials will be covered with a synthetic membrane to minimize exposure to water.

The containment cell will be constructed along the western perimeter of the site, near the top of the saddle area. See Drawing 13928-1 for approximate location.

As the drilling process or trenching operations proceed, waste representative of each composite sample (i.e., either from above or below the leachate in wells or of visually suspicious waste from trenching) will be segregated in the temporary containment cell. This will be performed so that waste representative of each composite sample can later be identified and separated from other wastes if characterization testing indicates hazardous characteristics.

#### Sampling Procedure for Excavated Waste

As drilling of wells proceed, two grab samples visually representative of the waste being penetrated will be obtained at 5 ft intervals (maximum). These samples will be placed in 32 oz. glass jars, labeled and temporarily stored

until the well is completed. One of the samples from each 5-ft interval will be identified as "duplicate" and be retained as a record of the material penetrated.

When the well is completed, grab samples will be separated into two groups; those above the leachate level and those below the leachate level. A composite sample from each group will be obtained by emptying the contents of all grab sample jars in the group on a hard, flat HDPE-lined surface, or in the laboratory. The sample will be quartered and split in a manner consistent with ASTM Method C702, Method B, "Standard Practice for Reducing Field Samples of Aggregate to Testing Size". Two composite samples from each group obtained by the above method will be placed in 8 oz. labeled glass jars. One of these composite samples from each group will be identified as "duplicate".

In addition to the composite samples gathered during the drilling operation, samples of visually suspicious waste excavated during trenching activities will be sampled for analysis by EP toxicity testing.

#### Characterization of Excavated Waste

An EP toxicity test (in accordance with "Test Methods for Evaluating Solid Waste-Physical/Chemical Methods" Method SW1310) will be performed on each composite sample. The waste which the composite sample represents must be disposed of as a hazardous waste if the extract of the sample contains concentrations above the maximum limits listed in 40 CFR 261.31 - 261.33.

#### Disposal On-Site

Excavated refuse not characterized as hazardous, will remain in the temporary containment cell and be buried. The procedure for burial at the containment cell will include removal of the surface cover membrane and then puncturing the synthetic liner, such that a perched leachate condition will not occur. The refuse containment cell will then be expanded to include the refuse generated by trenching activities, if required. The landfill cover will be restored to a condition equal to or exceeding the condition of the existing cover at that location. Clay materials and placement methods will be the same

as for cover restoration activities performed during trenching activities. Final cover will be graded in a way such that positive drainage and smooth final contours will result.

#### Disposal Off-Site

In the event excavated refuse is characterized as hazardous, some or all of the refuse will be disposed of off-site as a hazardous waste. This will involve permitting and possibly additional characterization, volume estimation, potentially out-of-state haulage by a licensed hazardous waste hauler and the associated permitting and disposal fees.

### CONSTRUCTION OBSERVATION

Construction of the partial system will be documented by video, still photographs, record drawings and field reports. This information will be incorporated into a Construction Observation Report and submitted to the WDNR.

In addition, soil testing of the clay bedding and cover soils will be performed during construction. Field density tests will be performed at approximately 100 lin. ft intervals, per lift, along the trenches. A Troxler Model 3411-B nuclear density/moisture meter will be used to perform the density tests. Modified Proctor curves will be developed for each 2500 cu yd of clay placed. Grain size and Atterberg limits of the clay will also be determined. Laboratory hydraulic conductivity tests of undisturbed Shelby tube samples will be conducted for each 5000 cu yd of clay placed. The results of the aforementioned field tests will also be presented in the Construction Observation Report.

### SYSTEM PERFORMANCE STANDARDS

#### Purpose

The following performance standards have been developed to demonstrate in the field that the piping, blower, flare, submersible pumps and leachate holding tank can meet or exceed the specifications presented in this document. It may not be possible to duplicate the performance standards specified by the

equipment manufacturer's specifications if the necessary quantity or quality of LFG or leachate is not available from the Landfill, or if other environmental conditions are not adequate (e.g., temperature, pressure, etc.). However, documentation of the performance standards can be adequately demonstrated to satisfy the intent of the specifications.

### Piping

Gas header and leachate conveyance piping will be pressure tested. The pipes will be air pressurized to 3.5 psi (gauge pressure) prior to closing the valve on the pressurizing unit. The valve will then be closed and the pressure monitored. A pressure of 3.0 psi or greater maintained for thirty minutes after the valve closing will be considered acceptable.

### Blower

The blower performance will be verified by measuring air flow through the blower and suction and positive pressures developed at the blower. The blower will be rated for 650 SCFM at 40 in. Static Pressure, 3321 RPM, 8.5 BHP at 0.0676 lb/cu ft air.

### Flare

The flare performance will be checked in accordance with the manufacture's recommendations. The burning capacity of the flare is rated at 20,100 cubic feet per hour (CFH) in air at 60°F and 14.7 PSIA at 1/2 in WC pressure drop, at sea level.

### Submersible Pumps

The performance of the submersible leachate extraction pumps to be installed in the extraction wells will be demonstrated before being installed in the wells. The pumps will be placed in a 55 gal drum of clean water at approximately 20°C and then run through a temporary piping setup consisting of a pressure gage and ball valve. The pressure gage will be installed as close as possible to the pump discharge and will be used to determine the head on the pump. The ball valve will be used to control the discharge flow. The pumps will be turned on and will discharge into a container with a known volume. The time it takes the pump to fill the container will also be

recorded. The flow rate can be determined by applying the time it takes to fill the container to the volume of the container. Also, the head on the pump will be determined by converting the pressure read from the pressure gage into feet of head.

The determined flow rate and head will be used in conjunction with the manufacturer's performance curves to verify pump performance. Additionally, after system startup the pump run time will be compared with volume in the leachate holding tank (as a rough check).

#### Leachate Holding Tank

During the tank installation, continuity testing will be performed to demonstrate that the tank is electrically isolated from ground throughout to maintain the cathodic protection and warranty. The cathodic protection test post at the control panel will be an ongoing check on the cathodic protection. The float switches and interstitial monitoring equipment will be tested in accordance with the manufacturer's recommendations.

Additionally, the tank manufacturer will pressure test the tank and interstice both at the factory and on-site. These tests will be performed in accordance with the Petroleum Equipment Institute Recommended Practices (PEI/RP100).

JCK/kjw/JVS/SGW

[wpmisc-600-54]

13928.41

APPENDIX A  
GAS FLOW ESTIMATE



BY BEM DATE 10/31/89 SUBJECT REFUSE HIDEAWAY SHEET NO. 1 OF 4  
CHKD. BY Ry DATE \_\_\_\_\_ GAS FLOW ESTIMATE JOB NO. 13928-41

A. Objective - Determine gas flow generated by refuse decomposition within the Refuse Hideaway Landfill.

B. Assumptions -

Refuse accepted, Nov. 1974 - May 1988 (say 14 years)

Refuse received, majority was commercial & residential  
(Characteristics as described on pg 2 of 4)

Refuse density, assuming light compaction - 1000 lbs/cy

Refuse Volume, estimated at 1,500,000 cy  
(Volume estimated by Warzyn Oct. 31, 1989 using Base grade information from RMT, Inc. In-field Conditions Report Jan. 1988 and Existing Final Grade information from Warzyn Drawing 13928-1 Nov. 1989)

C. Calculations -

Refuse placed per year; (assumed average)

$$1,500,000 \text{ cy} \times 1000 \text{ lb/cy} \times 1 \text{ ton}/2000 \text{ lb} = 750,000 \text{ tons}$$

$$750,000 \text{ tons} / 14 \text{ yr} = 53,570 \text{ tons/yr}$$

Using the methane generation calculation described on page 2 and 53,570 tons/yr average refuse placed, the Gas Generation Curve on page 3 was generated





Refuse Characterization (2)

Waste Type (%)

Component	Composite			t#	
Food Waste	9.0	0	0	1.5	3.5
Garden Waste	10.0	0	0	7	30
Paper Products	42.0	0	0	10	30
Plastic/Rubber	12.0	0	0	20	60
Textiles	2.0	0	0	7	20
Wood	6.0	0	0	15	50
Rubble/Inerts	19.0	0	0	0	0
Moisture Content	30%	0%	0%		
Dry Solids	70%	0%	0%		
Volatile Solids	56%	0%	0%		
Volatile Solids (Dry Wt. Basis)	47%	0%	0%		
				Total Methane Production	
Maximum Methane Production (3)				-----	
(cu.ft./lba)	1.54	0.00	0.00	1.54	(cu.ft./lba)

(2) Refuse characterization based on "Methane Generation and Recovery From Landfills", EMCON Associates, previous feasibility reports and Warzyn Engineering Inc.

(3) Maximum methane production based on the biodegradability of volatile solids present in the refuse as described in "Methane Generation and Recovery From Landfills", EMCON Associates.

Methane Generation Calculation (4)

First Stage Equation:

$$-k_1(t\theta - t)$$

$$G = (L/2)e$$

Second Stage Equation:

$$-k_2(t - t\theta)$$

$$G = L[1 - .5e]$$

Where:

G = Volume of gas produced prior to time t

L = Maximum methane production

$k_1 = \ln(50/t\theta)$

$k_2 = \ln(50)/(t\theta - t\theta)$

t $\theta$  = time when 50% of methane has been produced in years


t# = time when 99% of methane has been produced in years

(4) Based on the Palos Verdes Kinetic Model where the first stage methane production rate is proportional to the volume of methane already produced until half of the potential methane has been generated. The second stage methane production rate is proportional to the volume of methane remaining to be produced.

**WARZYN**

# Refuse Hideaway Landfill, Middleton WI

## Landfill Gas Generation Projection



BY BEM DATE 10/31/89 SUBJECT REFUSE HIDEAWAY SHEET NO. 4 OF 4  
CHKD. BY \_\_\_\_\_ DATE \_\_\_\_\_ JOB NO. 13928.41

The curve shown on page 3 represents the Total Estimated Gas Flow for the landfill. However, the amount of landfill gas that can be recovered is estimated to be only 75% of the Total Estimated Gas Flow.

From curve Page 3;

Maximum Total Estimated Gas Flow in CFM (1994);  
= 520 CFM

Total Estimated Recoverable Gas Flow in CFM (1994) 75%;

$$\Rightarrow 520 \text{ CFM} \times .75 = 390 \text{ CFM}$$

As a second method to estimate the maximum gas flow expected in the system, an assumption of 50 CFM per well was used. This is based on Warzyn's experience with similar landfills, the estimated depth of the wells (> 50 ft.) and the composition of the refuse.

Maximum Total Estimated Recoverable Gas Flow;  
(Assuming 13 wells in final system design)

$$13 \text{ wells} \times 50 \text{ CFM/well} = 650 \text{ CFM}$$

Therefore,

Maximum Total Estimated Recoverable Gas Flow  $\Rightarrow$

$$\text{Gas Flow Range} = 390 - 650 \text{ CFM}$$



APPENDIX B  
BLOWER SIZING CALCULATIONS

WARZYN ENGINEERING INC.  
MADISON, WISCONSIN

BY RFW DATE 1-17-89 SUBJECT REFUSE HIDEAWAY SHEET NO. \_\_\_\_\_ OF \_\_\_\_\_  
 CHKD. BY JCK DATE 10-24-89 BLOWER SIZING CALCULATIONS JOB NO. 13928-71  
SUMMARY

FLOW

<u>System</u>	<u>How Derived</u>	<u>FLOW (CFM)</u>
2 Well	50 CFM/well *	100 CFM
5 Well	50 CFM/well *	250 CFM
13 Well (FINAL)	50 CFM/well *	650 CFM
Total (FINAL)	Gas Generation Curve **	390 CFM

\* Based on past experience at similar landfills.  
(See Gas Flow Estimate calculations).

\*\* Based on theoretical gas generation model  
(See Gas Flow Estimate calculations).

PRESSURE

<u>System</u>	<u>FLOW (CFM)</u>	<u>SUCTION (in. WC)</u>	<u>PRESSURE (in. WC)</u>	<u>TOTAL</u>
2 Well	100	12.7	Non Controlling	Non Controlling
→ 5 Well	250	26.7	10.3	37.0
Flare Capacity	335	NOT APPLICABLE AT THIS TIME	11.6	

Blower Selection

Based on the information above, a 10 HP New York Blower was selected. The blower has the following rating:

650 CFM @ 40 in SP, 3321 RPM, 8.5 BHP @ .0676 lb/cu ft.

WARZYN

A. Objective - Determine the total head (suction + pressure) required to select a blower for the five (5) well system - conservative design, and then select a blower.

B. Assumptions -

- Use flow criteria of 50 CFM/well since it is the most conservative.
- Head loss due to HDPE pipe fusion (joints) negligible.
- Vacuum set at 10 in. WC at furthest point/well on system. This is also a conservative design.
- 6 in. WC needed at the top of pilot on VAREC flare.
- 3 in. WC needed at the top of burner on VAREC flare.
- Proposed design is for a 2-well system. However, if excess leachate levels are encountered, up to 3 additional wells may be installed. Therefore, size blower for a 5-well system as directed by WDNR. Size blower for 5-well system, pressures and full system flows.

C. Calculations - Suction Pressure

Determine equivalent lengths of fittings and pipe lengths for HL calculations, and estimate the suction pressures.



**WARZYN ENGINEERING INC.**  
MADISON, WISCONSIN

BY SEM DATE 10-17-89 SUBJECT REFUSE & DEWAT SHEET NO. 2 OF 18  
 CHKD. BY VK DATE 10-24-89 BLOWER SIZING CALCULATIONS JOB NO. 13928.41  
SECTION PRESSURES

Two-Well Design

<u>Description</u>	<u>Length or Equivalent Length (F-)</u>	<u>Reference</u>
4" X 3" Reducer	5.0'	Pg 14 of 18
3" Ø Pipe	4.0'	
3" 90° ELL	5.7'	Pg 12 of 18
3" Butterfly Valve (FULLY OPEN)	(40)(3/12) = 10'	Pg 13 of 18
3" Ø Pipe	8.0'	
6" X 6" X 3" Tee (Branch)	(60)(3/12) = 15'	Pg 13 of 18
6" Ø Pipe	21.5'	
6" X 6" X 3" Tee (Run)	(20)(6/12) = 10'	Pg 13 of 18
6" 45° ELL	6.4'	Pg 12 of 18
6" Ø Pipe	110'	
6" 90° ELL	12.9'	Pg 12 of 18
6" Ø Pipe	320'	
6" X 6" Cross (DRIPLEG)	(20)(6/12) = 10'	Pg 13 of 18
6" Ø Pipe	40'	
6" 45° ELL	6.4'	Pg 12 of 18
6" 90° ELL	12.9'	Pg 12 of 18
6" Ø Pipe	10'	
6" 45° ELL	6.4'	Pg 12 of 18
6" Ø PIPE	2'	
6" X 3" REDUCER	7'	Pg 14 of 18
3" Ø PIPE	6'	
3" 90° ELL	5.7'	Pg 12 of 18
3" Ø PIPE	3'	
3" BUTTERFLY VALVE (FULLY OPEN)	(40)(3/12) = 10'	Pg 13 of 18
3" FLAME ARRESTER	.8 in WC	SEE Pg 15 of 18
3" X 6" INCREASER	6'	Pg 14 of 18



WARZYN ENGINEERING INC.  
MADISON, WISCONSIN

BY FCM DATE 6-17-89 SUBJECT REFUSE - DEWAY  
CHKD. BY JOE DATE 10-24-89 BLOWER SIZING CALCULATIONS  
SUCTION PRESSURES

SHEET NO. 3 OF 18  
JOB NO. 13928.41

Five-Well Design

<u>Description</u>	<u>Length or Equivalent Length (EL)</u>	<u>Reference</u>
4" X 3" Reducer	5'	Pg 14 of 18
3" Ø Pipe	4.0	
3" 90° ELL	5.7'	Pg 12 of 18
3" Butterfly Valve (fully open)	(40)(3/12) = 10.0	Pg 13 of 18
3" Ø Pipe	8.0	
- 6" X 6" X 3" Tee (Branch)	(60)(3/12) = 15.0	Pg 13 of 18
- 6" Ø Pipe	250.0	
6" X 6" X 3" Tee (Run)	(20)(6/12) = 10.0	Pg 13 of 18
- 6" Ø Pipe	215.0	
6" X 6" X 3" Tee (Run)	10.0	Pg 13 of 18
- 6" Ø Pipe	210.0	
6" X 6" X 3" Tee (Run)	10.0	Pg 13 of 18
- 6" Ø Pipe	215.0	
6" X 6" X 3" Tee (Run)	10.0	Pg 13 of 18
6" Ø Pipe	110.0	
6" 90° ELL	12.9'	Pg 12 of 18
6" Ø Pipe	320'	
- 6" X 6" Cross	(20)(6/12) = 10'	Pg 13 of 18
6" Ø Pipe	30'	
6" 45° ELL	6.4'	Pg 12 of 18
6" Ø Pipe	10.0	
6" 90° ELL	12.9'	Pg 12 of 18
6" Ø PIPE	10.0	
6" 45° ELL	6.4'	Pg 12 of 18
6" Ø PIPE	2'	
6" X 3" REDUCER	7'	Pg 14 of 18
3" Ø PIPE	6'	
3" 90° ELL	5.7'	Pg 12 of 18
3" Ø PIPE	3'	
3" BUTTERFLY VALVE (FULLY OPEN)	(40)(3/12) = 10'	Pg 13 of 18
3" Ø PIPE	2'	
3" FLAME ARRESTER	4.5 in wc	
3" X 6" INCREASER	6'	



Pg 15 of 18  
Pg 14 of 18







WARZYN ENGINEERING INC.  
MADISON, WISCONSIN

BY BEM DATE 10-17-89 SUBJECT REFUSE HIDEAWAY SHEET NO. 6 OF 18  
CHKD. BY JCK DATE 10.26.89 BLOWER SIZING CALCULATIONS JOB NO. 13928.41  
SUCTION PRESSURES

Assuming controlling Suction Pressure is based on 5-well system design;

Total Suction Pressure estimated is = 26.7 in. WC

BY BEM DATE 10-25-89 SUBJECT REFUSE HIDEAWAY  
 CHKD. BY JCK DATE 10-25-89 BLOWER SIZING CALCULATIONS  
POSITIVE PRESSURES

SHEET NO. 7 OF 18  
 JOB NO. 13728.41


C2. Calculations - Positive Pressure.

Objective - Determine blower pressure (in. WC) necessary to operate 6" VAREC Series 239A Waste Gas Burner at maximum design and flare capacity flows.

Assumptions -

- Max. design flow = 250 CFM (5 wells @ 50 CFM/well)
- Flare Capacity flow = 335 CFM (6" VAREC 239A)
- 6 in. WC @ 1.2 CFM required at top of pilot
- 3 in. WC required at top of burner

Schematic



Calculations

Determine equivalent lengths of fittings and pipe lengths for  $H_L$  calculations, and estimate the positive pressures.

**WARZYN ENGINEERING INC.**  
MADISON, WISCONSIN

BY BEM DATE 10-25-89 SUBJECT REFUSE HIDEWAY SHEET NO. 8 OF 18  
 CHKD. BY JCK DATE 10-25-89 BLOWER SIZING CALCULATIONS JOB NO. 1392241  
POSITIVE PRESSURES

From blower to Pilot:

<u>Description</u>	<u>Length or Equivalent Length</u>	<u>Reference</u>
BLOWER		
6" Ø PIPE	4'	
6" 45° ELL	6.4'	Pg 12 of 18
6" Ø PIPE	6'	
6" 45° ELL	6.4'	Pg 12 of 18
6" Ø PIPE	10'	
DRIPLEG (6"X6"X6" TEE - RUN)	$(20)(\frac{1}{12}) = 10'$	Pg 13 of 18
6" Ø PIPE	15'	
6" 45° ELL	6.4'	Pg 12 of 18
6" Ø PIPE	6'	
6" 45° ELL	6.4'	Pg 12 of 18
6"X4" REDUCER	7'	Pg 14 of 18
4" FLAME ARRESTER	2.5 in. WL @ 335 CFM 1.5 in. WL @ 250 CFM	Pg 15 of 18
4"X6" INCREASER	12'	Pg 14 of 18
(A) → 6" Ø PIPE	2'	
6"X6"X1" TEE (BRANCH)	$(60)(\frac{1}{12}) = 5'$	Pg 13 of 18
1" 90° ELL	2' assumed	
1" Ø PIPE	3'	
1"X½" REDUCER	2' assumed	
½" 90° ELL	1' assumed	
PILOT ½" Ø PIPE	8'	

From blower to Burner:

<u>Description</u>	<u>Length or Equivalent Length</u>	<u>Reference</u>
BLOWER		
SAME AS ABOVE TO POINT (A)	SEE ABOVE	SEE ABOVE
6" Ø PIPE	4'	
6" 90° ELL	12.9	Pg 12 of 18
6" Ø PIPE	8'	







**WARZYN ENGINEERING INC.**  
MADISON, WISCONSIN

BY BEM DATE 10-17-89 SUBJECT REFUSE HIDEAWAY SHEET NO. 11 OF 18  
 CHKD. BY JCK DATE 10-25-89 BLOWER SIZING CALCULATIONS JOB NO. 13928.41  
POSITIVE PRESSURES

Assuming controlling positive pressure is based on 5-well system design; (Blower to Pilot)

Total Positive Pressure estimated is = 10.3 in. WC

Select Blower


Pressure:	Suction Press.	26.7
	Positive Press.	<u>10.3</u>
	Total	37.0 in. WC

Flow :  
(full system) Flow Range = 390 - 650 CFM

- Select blower which has capacity for full system flow, but pressure capacity for 5-well system. Select blower that may be up graded in motor and wheel size for full system pressure capacity.\*

\*Based on limited assumptions at this time.

**06** OUTLET SIZE Performance shown is for Pressure Blowers with outlet duct and with or without inlet duct. Outlet area: .20 sq. ft.



Select New York Blower # 2306A10, 10HP





## FLOW OF AIR IN PIPES

$$P = \frac{1.268 t Q^{1.852}}{1,000,000 p d^{4.973}} \quad \text{FRITZSCHE FORMULA.}$$

- P = drop in pressure in pounds per square inch per foot of pipe.
- t = absolute temperature in degrees Fahrenheit = recorded temp. in degrees F + 459.6.
- Q = cubic feet of free air per minute at 60 degrees Fahrenheit.
- p = absolute pressure in pounds per square inch = gage pressure + 14.7.
- d = diameter of the pipe in inches.




FIG. A - FLOW OF AIR IN CIRCULAR PIPES. MORRILL'S CHART. BASED ON FRITZSCHE FORMULA.\*

TABLE B - ECONOMICAL MAXIMUM VELOCITIES OF AIR FLOW IN PIPES.

SIZE OF PIPE INCHES	MAXIMUM VELOCITY FEET PER SEC	SIZE OF PIPE INCHES	MAXIMUM VELOCITY FEET PER SEC.
6	20	16	50
8	28	20	54
10	35	24	57
12	41	30	60
14	46	36	62

TABLE C - POWER REQUIRED FOR COMPRESSING AIR.\*

FINAL PRESSURE OF AIR LB. PER SQ. INCH	THEORETICAL WORK TO COMPRESS 1 MIL. CU. FT. OF FREE AIR HP - HR.	FINAL PRESSURE OF AIR LB. PER SQ. INCH	THEORETICAL WORK TO COMPRESS 1 MIL. CU. FT. OF FREE AIR HP - HR.
1	72.3	8	490.2
2	144.0	10	596.5
3	200.8	12	697.1
4	265.2	14	785.4
6	384.7	16	875.9

TABLE D - RESISTANCE TO FLOW OF AIR THROUGH FITTINGS.

DIAMETER OF PIPE IN INCHES	EQUIVALENT LENGTH OF STRAIGHT PIPE IN FEET				
	GATE VALVE	ANGLE VALVE	LONG RADIUS ELBOW 45°	STANDARD ELBOW 90°	SIDE OUTLET TEE
2	1.3	4.8	1.7	3.6	7.1
3	2.1	7.7	2.8	5.7	11.4
4	3.0	10.7	3.9	7.9	15.8
6	4.8	17.4	6.4	12.9	25.6
8	6.7	24.1	8.9	17.9	35.6
10	8.8	31.5	11.5	23.4	46.6
12	10.9	39.3	14.4	29.3	58.6
16	15.4	55.4	20.3	41.3	82.6
20	20.2	72.7	26.6	54.1	108.2
24	25.1	90.4	33.1	67.3	134.6
30	32.8	118.1	43.3	87.9	175.8
36	40.9	147.2	54.0	109.6	219.2
42	49.2	177.1	64.9	131.9	263.8
48	57.7	207.7	76.2	157.9	309.2

\*Data from Metcalf & Eddy, American Sewerage Practice, Mc Graw-Hill

### Schedule (Thickness) of Steel Pipe Used in Obtaining Resistance Of Valves and Fittings of Various Pressure Classes by Test\*

Valve or Fitting ANSI Pressure Classification		Schedule No. of Pipe Thickness
Steam Rating	Cold Rating	
250-Pound and Lower	500 psig	Schedule 40
300-Pound to 600-Pound	1440 psig	Schedule 80
900-Pound	2160 psig	Schedule 120
1500-Pound	3600 psig	Schedule 160
2500-Pound	1/2 to 6"	xx (Double Extra Strong) Schedule 160
	8" and larger	

\*These schedule numbers have been arbitrarily selected only for the purpose of identifying the various pressure classes of valves and fittings with specific pipe dimensions for the interpretation of flow test data; they should not be construed as a recommendation for installation purposes.

### Representative Equivalent Length<sup>†</sup> in Pipe Diameters (L/D) Of Various Valves and Fittings

$(L/D) \times D_{12} = L_e$

Description of Product			Equivalent Length In Pipe Diameters (L/D)
Globe Valves	Stem Perpendicular to Run	With no obstruction in flat, bevel, or plug type seat With wing or pin guided disc	Fully open 340 Fully open 450
		Y-Pattern	(No obstruction in flat, bevel, or plug type seat) - With stem 60 degrees from run of pipe line - With stem 45 degrees from run of pipe line
Angle Valves			With no obstruction in flat, bevel, or plug type seat With wing or pin guided disc
Gate Valves	Wedge, Disc, Double Disc, or Plug Disc		Fully open 13 Three-quarters open 35 One-half open 160 One-quarter open 900
		Pulp Stock	Fully open 17 Three-quarters open 50 One-half open 260 One-quarter open 1200
Conduit Pipe Line Gate, Ball, and Plug Valves			Fully open 3**
Check Valves	Conventional Swing		0.5†... Fully open 135
	Clearway Swing		0.5†... Fully open 50
	Globe Lift or Stop; Stem Perpendicular to Run or Y-Pattern		2.0†... Fully open Same as Globe
	Angle Lift or Stop		2.0†... Fully open Same as Angle
	In-Line Ball	2.5 vertical and 0.25 horizontal	†... Fully open 150
Foot Valves with Strainer		With poppet lift-type disc With leather-hinged disc	0.3†... Fully open 420 0.4†... Fully open 75
Butterfly Valves (8-inch and larger)			Fully open 40
Cocks	Straight-Through	Rectangular plug port area equal to 100% of pipe area	Fully open 18
	Three-Way	Rectangular plug port area equal to 80% of pipe area (fully open)	Flow straight through 44 Flow through branch 140
Fittings	90 Degree Standard Elbow		30
	45 Degree Standard Elbow		16
	90 Degree Long Radius Elbow		20
	90 Degree Street Elbow		50
	45 Degree Street Elbow		26
	Square Corner Elbow		57
Standard Tee	With flow through run		20
	With flow through branch		60
Close Pattern Return Bend			50
Pipe	90 Degree Pipe Bends		See Page A-27
	Miter Bends		See Page A-27
	Sudden Enlargements and Contractions		See Page A-26
	Entrance and Exit Losses		See Page A-26

\*\*Exact equivalent length is equal to the length between flange faces or welding ends.

†Minimum calculated pressure drop (psi) across valve to provide sufficient flow to lift disc fully.

‡For limitations, see page 2-11. For effect of end connections, see page 2-10.

For resistance factor "K", equivalent length in feet of pipe, and equivalent flow coefficient, see pages A-31 and A-32.




FLARE CENTERED FLOW THROUGH TEE IS RATED + 15'



# FLOW CAPACITY


## VAREC MODEL 5000/5010 FLAME ARRESTERS



Note: Flow stated in SCFH air can be corrected for gas at 0.8 specific gravity and temperature at 90°F by multiplying above flows by 1.09 factor



calculation  
of duct  
resistance  
(chart a)




Reprinted from Chapter 41, Heating, Ventilating & Air Conditioning Guide, 1949

To illustrate the use of Chart A, above, in measuring friction of round ducts, assume that the requirement is to pass 10,000 CFM through 50 feet of 24-inch diameter duct. Find the line designating 10,000 CFM on the vertical scale at the left and move horizontally to the right to the point of intersection with the diagonal line marked 24". The water gauge scale, represented by the vertical line, shows that the friction per 100

feet of duct length is .05 inches. Therefore, for 50 feet, friction would be 0.5" x .5 or 0.25 inches water gauge. The intersecting diagonal marked "velocity" indicates, in this case, an air velocity in the duct of 3200 FPM. Similarly, any two variables may be determined by intersecting lines when two known variables are plotted on the




BY JK DATE 11.3.98 SUBJECT REUSE HIDEAWAY GAS/LEACHATE EXTRACTION WELL HEAD DETAIL  
 CHKD. BY \_\_\_\_\_ DATE \_\_\_\_\_  
 SHEET NO. 17 OF 18  
 JOB NO. 139725



KEY

- ① 1/4" DIA. STAINLESS STEEL PULLOUT CABLE
- ② 1" DIA. FLEXIBLE DISCHARGE PIPE
- ③ STAINLESS STEEL SAMPLE PORT
- ④ 6" DIA. SCH. 80 PVC GAS WELL PIPE
- ⑤ ELECTRICAL WIRING FOR PUMP
- ⑥ SEAL-TIGHT ELECTRICAL CONDUIT AND WIRING FOR PUMP
- ⑦ 6" x 6" x 3" SCH. 80 PVC TEE
- ⑧ EXPLOSION-PROOF ELECTRICAL PLUG MOUNTED AND SEALED INTO WELL CASING
- ⑨ 1" DIA. STAINLESS STEEL NIPPLE THREADED THROUGH BLIND FLANGE
- ⑩ 1" DIA. STAINLESS STEEL UNION
- ⑪ 1" DIA. STAINLESS STEEL 90° ELL
- ⑫ 1" DIA. STAINLESS STEEL TO HDPE TRANSITION FITTING
- ⑬ 1/4" STAINLESS STEEL EYEBOLT WITH WASHERS AND NUT
- ⑭ 3" DIA. FLEXIBLE COUPLING WITH CLAMPS (FERNCO)
- ⑮ 3" DIA. SCH. 80 PVC PIPE
- ⑯ 1" DIA. HDPE PIPE (INSULATED AND HEAT TRACED)
- ⑰ 3/4" x 1/2" SCH. 80 PVC REDUCING BUSHING WITH 1/2" DIA. SCH. 80 PVC PLUG (MONITORING PORT)
- ⑱ 3" DIA. BUTTERFLY VALVE (TILT FOR CONDENSATE DRAINAGE)
- ⑲ 3" DIA. SCH. 80 PVC 90° ELL
- ⑳ 3" DIA. FLEXIBLE TUBING WITH CLAMPS
- ㉑ 3" DIA. HDPE PIPE
- ㉒ 6" x 6" x 3" HDPE TEE (ON GAS HEADER PIPE)
- ㉓ 6" x 6" x 1" HDPE TEE (ON LEACHATE CONVEYANCE PIPE)

① ③ TYPICAL GAS/LEACHATE EXTRACTION WELL HEAD DETAIL  
SCALE: 1" = 1'-0"







SEE DETAIL (3)

LEACHATE/HOLDING TANK  
SEE DRAWING 13928-6  
CENTER LINE WEST EDGE = 400,600 N, 2,112,890 E  
CENTER LINE EAST EDGE = 400,600 N, 2,112,921 E

FLARE STATION  
400,643 N  
2,112,732 E  
SEE DETAIL (5)

BLOWER STATION  
400,590 N  
2,112,746 E  
SEE DETAIL (5)





APPENDIX C  
FLARE SIZING/SELECTION

A. Objective - Establish design criteria necessary to size a flare and make flare selection.

B. Assumptions

- Maximum estimated flow (e 50 CFM/well conservative)  
Based on the more conservative method of the two methods used to determine gas flow (See Gas Flow Estimate calculations) and based on five well system (as directed by WDNR) is;

$$\text{Flow} = 5 \text{ wells} \times 50 \text{ CFM/well} = 250 \text{ CFM} \\ = 15,000 \text{ CFH}$$

- Waste Gas;

Composition - Assume

50%	methane
49%	Carbon Dioxide
1%	Other

Temperature - Assume 70°F

Moisture Content - Assume Saturated

BTU Value - Assume 500  $\frac{\text{CF}}{\text{CF}}$  (7.5 Million BTUH)

- Flare is sized for Partial System only; may be used back-up for full system.

Selection

Based on the information above, a 6 in. VAREC 239A Series Waste Gas Burner was selected. See pages 2-5 for manufacturer's data and specifications.



## 239A SERIES

# WASTE GAS BURNER

- “Curtain of Flame”  
Ring-Type Pilot
- 304SS Pilot Orifices
- Insulated Pedestal  
Protects Pilot Lines
- Separable Mounting Base



### INTRODUCTION

The VAREC 239A Series Waste Gas Burner is designed for burning excess waste gas generated in the anaerobic digestion process to reduce the potential odor nuisance from venting directly to the atmosphere. This burner is suitable for burning low volumes of waste gas which is typically very “wet”, with a low BTU value (between 550 and 600 BTU), and composed primarily of methane.

### OPERATION AND FEATURES

The VAREC 239A Burner is designed to ignite the waste gas by passing it through a “curtain of flame” developed by the ring-type pilot. The pilot gas mixes with air at the pilot ring and the pilot flame burns on top of the ring. The waste gas is deflected across the pilot flame by an integral baffle. A manually adjustable shutter is provided at the bottom of the burner stack to change the available air volume should the waste gas flow rate fluctuate.

Dual pilot lines in the larger models are located 180° apart to distribute the pilot flame around the entire ring. The burner pedestal is insulated internally, enclosing the pilot line(s) and waste gas piping. A gasketed, separable mounting base is included for pre-installation on a concrete foundation or other suitable support. A covered pilot observation and ignition port with separate inspection port are provided on the burner stack.

A low pressure natural gas pilot supply is recommended with the VAREC 239A Burner. Since Waste Gas is typically moist and dirty with fluctuating pressure and BTU value, it may not provide the reliable pilot flame necessary when using an automatic pilot ignition and monitoring system. The Model 239A Waste Gas Burner is not suitable for a propane or butane pilot gas supply.

### AUXILIARY EQUIPMENT

**Flame Check, Model 52:** Recommended for field installation in the pilot gas piping just upstream of the burner to protect from possible flashbacks generated in the pilot line. See PDS 52WT for details.

**Electric Pilot Ignitor:** Recommended for all burners for improved operator safety. VAREC manufactures several ignition systems. These systems are described in data sheets PDS 240WT, PDS 240HOA, PDS 241WT, and PDS 242WT.

**Secondary Stacks (by others):** “Self-supporting” secondary stacks should be specified for field installation on all 4”, 6”, and 8” burners to protect from winds which can cause an unstable pilot and/or waste gas flame. Consult VAREC for details.

### SPECIFICATIONS

**Sizes:** 2”, 3”, 4”, 6” and 8”

**Connections:**

Waste Gas — Nominal pipe size/weld connection

Pilot Gas — Single 1/2” NPT (2” through 4” sizes)

Dual 1/2” NPT (6” and 8” sizes)

**Mounting:** Concrete pad or other suitable support

**Waste Gas:**

Composition: Primarily methane

BTU Value: 550 to 600

Maximum Inlet Pressure: 20” WC (508 mm WC)

**Material:**


Burner — Fabricated carbon steel

Pilot Flame Ring — Heat resistant cast iron

Pilot orifice/fittings — 304 stainless steel

Observation/ignition Port — Cast iron

### DIMENSIONAL DRAWING



SIZE CODE	02	03	04	06	08
A	2 50	3 75	4 100	6 150	8 200
B	8 3/4 222	10 254	11 279	13 330	15 381
C	17 1/2 444	18 3/4 476	20 508	22 559	24 610
D	12 3/4 324	14 356	16 406	20 508	24 610
E	68 1730	68 1730	68 1730	96 2440	96 2440
F	20 1/4 514	24 1/4 616	24 1/4 616	32 1/4 819	48 3/8 1229
SHIPPING WEIGHT	465 211	590 268	700 318	860 391	1500 682

Inches and lb in bold, mm and kg in light

### BURNING CAPACITY

Flow stated in air at 60°F and 14.7 PSIA at 1/2" WC (13 mm WC) pressure drop, at sea level. For capacities at higher site elevations, consult factory.

SIZE	FT <sup>3</sup> /HR	M <sup>3</sup> /HR
2"	1,850	52
3"	4,025	114
4"	7,875	223
<b>6"</b>	<b>20,100</b>	<b>569</b>
8"	33,475	948

Installation, mounting arrangement, and dimensions are preliminary general information not to be used for construction. Certified drawings are available.

**Note:** Flow stated in SCFH air can be corrected for waste gas at other specific gravities and temperatures. (See Technical Section)


### ORDERING INFORMATION

239A	WASTE GAS BURNER	
Code	Size (Select One)	
02	2"	
03	3"	
04	4"	
06	6"	
08	8"	
239A	06	(EXAMPLE)

## 240 H-O-A SERIES

# MANUAL/CYCLING ELECTRIC PILOT IGNITOR

- Unattended Ignition Spark
- Adjustable "On" and "Off" Cycles
- Hand-Off-Auto Functions



## INTRODUCTION

The VAREC Model 240HOA Manual/Cycling Electric Pilot Ignitor is designed for use with the VAREC 239A Series Waste Gas Burner. The unit provides a manually initiated ignition spark and provision to continuously cycle the spark on and off. This model is recommended when an electrical means of pilot ignition is desired, yet automatic pilot monitoring and status alarms are not required.

The ignition control enclosure should be located at least 10 feet (3 m) away from the waste gas burner to protect operating personnel and enclosure components from radiant heat.

## OPERATION AND FEATURES

A compact ignition transformer with a dual cycling timer switch are provided inside a weatherproof enclosure. The enclosure is fitted with an external "Hand-Off-Auto" switch, and is suitable for panel or wall mounting. The transformer and switches are pre-wired to a terminal strip at the factory. An ignition electrode assembly with weatherproof housing are also provided, and are easily field mounted to the primary stack of the VAREC 239A Burner.

With the three-way switch in the "Hand" position, the ignition transformer is energized. The transformer delivers a continuous high voltage to the ignition electrode which sparks across an air gap to the pilot flame ring, igniting the pilot gas. Once the pilot flame has been established, the switch is turned off.

To provide for unattended re-ignition in the event of pilot flame failure, the switch is placed in the "Auto" position. In this position the timer is activated, alternately energizing and de-energizing the transformer, cycling the ignition spark. The dual cycling timer provides separate adjustment for the spark duration and the time between sparking.

## CONSTRUCTION

The Model 240HOA Ignitor is housed in a NEMA 4 rated enclosure. The ignition electrode housing is steel with an aluminum cover. Both the control enclosure and electrode housing are provided with 1/2-inch NPT female conduit connections.

The transformer is rated for continuous duty with 110 VAC, 60 Hz primary, and 6000 VAC secondary. The timer is adjustable from 3 to 300 seconds for both the "Ignition Spark On" and the "Ignition Spark Off" cycle.


## OPTIONAL IGNITION SYSTEMS

VAREC manufactures several additional models of electric pilot ignition systems for use with the 239A Waste Gas Burner. These systems include Model 240 Manually Operated Ignitor, Model 241UV Manual Start/Automatic Re-Ignition, and Model 242UV Automatic Start/Automatic Re-Ignition. These ignition systems are described fully in their respective data sheets, PDS 240WT, PDS 241UV, and PDS 242WT.



# VAREC 240 H-O-A SERIES MANUAL/CYCLING ELECTRIC PILOT IGNITOR

## DIMENSIONAL DRAWING



### NOTES:

- ① USE 18 AWG WITH 7 mm INSULATION RATED FOR 10,000 VAC AT 250°C.
2. ALL FIELD WIRING AND CONDUIT BY OTHERS.
3. CONTROL PANEL TO BE MOUNTED NOT LESS THAN 10 FEET (3 m) AWAY FROM WASTE GAS BURNER.
4. SHIPPING WEIGHT: 50 LBS (23 KG).

Installation, mounting arrangement, and dimensions are preliminary general information not to be used for construction. Certified drawings are available.

## ORDERING INFORMATION

240	MANUAL/CYCLING ELECTRIC PILOT IGNITOR		
Code	Model		
HOA	Hand-Off-Auto Switch with Cycling Timer		
Code	Size	(Same as Model 239A Burner Size — Select One)	
02	2"		
03	3"		
04	4"		
06	6"		
08	8"		
Code	Enclosure Rating (Select One)		
4	NEMA 4 (Standard)		
240	HOA	04	4 (EXAMPLE)

**VAREC**  
a Rosemount Division

10800 Valley View St., Cypress, CA 90630 (714) 761-1300 Telex: 4722044 FAX: (714) 952-2701

**WARZYN**

APPENDIX D  
LEACHATE EXTRACTION AND STORAGE CALCULATIONS



WARZYN ENGINEERING INC.  
MADISON, WISCONSIN

BY JCK DATE 10.31.89 SUBJECT REFUSE HIDEAWAY SHEET NO. 1 OF 110  
CHKD. BY MAL DATE 11/1/89 LEACHATE EXTRACTION JOB NO. 13723  
WELL PUMP

A. OBJECTIVE : CALCULATE PUMP SIZE NECESSARY  
TO WITHDRAW LEACHATE FROM  
6"  $\phi$  EXTRACTION WELLS

E. ASSUMPTIONS:

- 1) WELL DEPTH RANGES FROM 50' TO 90'  
CALC ASSUMES 90' (FULL SYSTEM)
- 2) SUBMERSIBLE  $\approx$  WELL PUMP  
CONTROLLED BY AMPERAGE SENSOR  
AND TIMER ( $\approx$  5 HOUR CYCLE TIME)
- 3) WELL PUMPS ALSO STOPPED BY  
HIGH LEVEL IN LEACHATE HOLDING  
TANK OR LIQUID DETECTED IN  
TANK INTERSTICE
- 4) 1/4" HOLE DRILLED IN DISCHARGE  
ABOVE PUMP ALLOWS FOR DRAIN  
BACK FOR FROST PROTECTION
- 5) PUMP DISCHARGES THROUGH 1"  
HOSE, 1" HDPE AND THEN TO  
GRAVITY FLOW IN 6" HDPE
- 6) 1" ABOVE GRADE PORTION OF PIPE  
IS INSULATED AND HEAT TRACED
- 7) ALL ELECTRICAL CONNECTIONS  
THRU WELL CASING ARE SEALED
- 8) PUMPING RATE OF 2 - 7 GPM IS  
BASED ON THEORETICAL PROJECTIONS  
AND FIELD EXPERIENCE AT SIMILAR  
SITES. IT IS ESTIMATED THAT WELL  
RECHARGE RATES WILL BE WITHIN  
THIS RANGE OR LESS.

WARZYN ENGINEERING INC.  
MADISON, WISCONSIN

BY JCV DATE 10.31.89 SUBJECT REFUSE HIDEAWAY SHEET NO. 2 OF 10  
 CHKD. BY MAL DATE 11/1/89 LEACHATE EXTRACTION JOB NO. 13923  
WELL PUMP

C. CALCULATION:

STATIC HEAD = 90'

SYSTEM HEADLOSS:

ITEM	LENGTH	EQ. LENGTH 1"
1. 1" $\phi$ EPDM HOSE	90'	—
2. 1" $\phi$ SS 90° ELBOW	—	2.6'
3. 1" $\phi$ HDPE PIPE	10'	—
	100'	2.6'

TOTAL EQ. LENGTH 1" HDPE PIPE = 100 + 2.6 = 102.6'

Q	$h_L$	STATIC	TDH
2 GPM	0.90'	90'	90.9'
5	2.82	↓	92.8
7	5.17	↓	95.2
10	9.86	↓	99.9

∴ WHEN THE SYSTEM TDH CURVE IS COMPARED WITH PUMP CURVE IT IS APPARENT THE PUMP HAS MORE THAN ADEQUATE CAPACITY.

**WARZYN ENGINEERING INC.  
MADISON, WISCONSIN**

BY JK DATE 10-21-89 SUBJECT PIPE HIDEWAY SHEET NO. 3 OF 10  
 CHKD. BY \_\_\_\_\_ DATE \_\_\_\_\_ JOB NO. 13978

**Flow Capacity and Friction Loss for Schedule 80 Thermoplastic Pipe Per 100 Ft.**

GALLONS PER MINUTE	1/2 in.		3/4 in.		1 in.		1 1/4 in.		1 1/2 in.		2 in.		2 1/2 in.		3 in.	
	VELOCITY FEET PER SECOND	FRICITION HEAD FEET	VELOCITY FEET PER SECOND	FRICITION HEAD FEET	VELOCITY FEET PER SECOND	FRICITION HEAD FEET	VELOCITY FEET PER SECOND	FRICITION HEAD FEET	VELOCITY FEET PER SECOND	FRICITION HEAD FEET	VELOCITY FEET PER SECOND	FRICITION HEAD FEET	VELOCITY FEET PER SECOND	FRICITION HEAD FEET	VELOCITY FEET PER SECOND	FRICITION HEAD FEET
1	1.48	4.02	1.74	0.74	0.86	0.37	1.14	0.88	1.21	0.09	0.38	0.10	0.041	0.10	0.05	0.02
2	2.95	8.03	3.48	1.57	1.72	0.74	0.94	0.88	0.38	0.52	0.21	0.09	0.38	0.10	0.041	0.10
5	7.39	45.23	19.59	3.92	9.67	4.19	2.34	2.75	1.19	1.30	0.66	0.29	0.94	0.30	0.126	0.56
7	10.34	83.07	35.97	5.49	17.76	7.69	3.28	5.04	2.19	1.82	1.21	0.53	1.32	0.55	0.24	0.78
10				7.84	33.84	14.65	4.68	9.61	4.16	2.60	2.30	1.00	1.88	1.04	0.45	1.12
15				11.76	71.70	31.05	7.01	20.36	8.82	3.90	4.87	2.11	2.81	2.20	0.95	1.68
20							9.35	34.68	15.02	5.20	8.30	3.59	3.75	3.75	1.62	2.23
25							11.69	52.43	22.70	6.50	12.55	5.43	4.69	5.67	2.46	2.79
30							14.03	73.48	31.82	7.80	17.59	7.82	5.63	7.95	3.44	3.35
35										9.10	23.40	10.13	6.57	10.58	4.58	3.91
40										10.40	29.97	12.98	7.50	13.55	5.87	4.47
45										11.70	37.27	16.14	8.44	16.85	7.30	5.03
50										13.00	45.30	19.61	9.38	20.48	8.87	5.58
60													11.26	28.70	12.43	6.70
70																7.82
75																8.38
80																8.93
90																10.05
100																11.17
125																
150																
175																
200																
250																
300																
350																
400																
450																
500																
750																

**Equivalent Length of Pipe, Feet**

	1/4"	1/2"	3/4"	1"	1 1/4"	1 1/2"	2"	2 1/2"	3"	4"	6"	8"	10"	12"
90° Standard Elbow	0.9	1.6	2.1	2.6	3.5	4.0	5.5	6.2	7.7	10.1	15.2	20.0	25.1	29.8
40° Standard Elbow	0.5	0.8	1.1	1.4	1.8	2.1	2.8	3.3	4.1	5.4	8.1	10.6	13.4	15.9
90° Long Radius Elbow	0.6	1.0	1.4	1.7	2.3	2.7	4.3	5.1	6.3	8.3	12.5	16.5	20.7	24.7
<b>FITTINGS</b> 90° Street Elbow	1.5	2.6	3.4	4.4	5.8	6.7	8.6	10.3	12.8	16.8	25.3	33.3	41.8	49.7
45° Street Elbow	0.8	1.3	1.8	2.3	3.0	3.5	4.5	5.4	6.6	8.7	13.1	17.3	21.7	25.9
Square Corner Elbow	1.7	3.0	3.9	5.0	6.5	7.6	9.8	11.7	14.6	19.1	28.8	37.9	47.6	56.7
Standard Tee With Flow through run	0.6	1.0	1.4	1.7	2.3	2.7	4.3	5.1	6.3	8.3	12.5	16.5	20.7	24.7
Tee With Flow through branch	1.8	4.0	5.1	6.0	6.9	8.1	12	14.3	16.3	22.1	32.2	39.9	50.1	59.7




**WARZYN ENGINEERING INC.**  
**MADISON, WISCONSIN**


BY JJK DATE 11-16-89 SUBJECT ZEPHUS HIDEAWAY SHEET NO. 7 OF 16  
 CHKD. BY \_\_\_\_\_ DATE \_\_\_\_\_ JOB NO. 13923

**MODEL 5S 5 GPM GRUNDFOS**

FLOW RANGE  
 1.2 to 7 GPM  
 PUMP OUTLET  
 1" NPT



**PERFORMANCE CURVES**



**DIMENSIONS AND WEIGHTS**

MODEL NO.	HP	LENGTH (INCHES)	WIDTH (INCHES)	APPROX. UNIT SHIPPING WT. (LBS.)
5S03-9	1/2	24 3/8	3 3/4	27
5S05-13	1/2	28 1/2	3 3/4	31
5S07-18	3/4	33 1/4	3 3/4	34
5S10-22	1	37 1/8	3 3/4	42
5S15-26	1 1/2	42	3 3/4	46
5S15-31	1 1/2	47 7/8	3 3/4	58

Specifications are subject to change without notice.





**WARZYN ENGINEERING INC.**  
MADISON, WISCONSIN

BY JOK DATE 11.16.31 SUBJECT REFUGES HIDEAWAY SHEET NO. 3 OF 16  
 CHKD. BY \_\_\_\_\_ DATE \_\_\_\_\_ LEACHATE EXTRACTION JOB NO. 13928  
WELL PUMP

**GRUNDFOS** **5 GPM** **MODEL 5S**

SELECTION CHARTS FLOW RANGE PUMP OUTLET  
 (Ratings are in GALLONS PER HOUR - GPH) 1.2 to 7 GPM 1" NPT

PUMP MODEL	HP	PSI	DEPTH TO PUMPING WATER LEVEL (LIFT) IN FEET																										
			20	40	60	80	100	120	140	160	180	200	220	240	260	280	300	340	400	460	520	600	700	800	900	1000	1100		
5S03-9	1/8	0																											
		20			420	393	366	339	312	277	242	169	95																
		30			389	362	335	306	276	225	174	37																	
		40			400	358	330	303	265	228	143																		
		50			359	327	296	265	208	150	75																		
		60			337	294	253	211	114																				
Shut-off PSI:			102	94	85	76	68	59	50	42	33	24	16	7															
5S05-13	1/2	0																											
		20			437	418	399	380	362	343	324	305	282	259	222	185	117												
		30			434	415	396	377	359	340	322	301	281	251	222	170	117												
		40			431	412	393	375	356	338	318	299	275	250	210	170	94												
		50			409	390	372	353	335	316	295	273	242	210	153	95													
		60			388	369	350	332	312	293	267	241	197	153	76														
Shut-off PSI:			152	143	134	126	117	108	100	91	82	74	55	56	48	39	30	13											
5S07-18	3/4	0																											
		20							423	409	396	382	369	355	342	329	315	300	267	193									
		30							421	407	394	380	367	353	340	327	313	299	262	149									
		40							432	419	405	392	378	365	351	338	325	311	296	261	212	92							
		50							430	417	403	390	376	363	349	336	323	308	294	277	259	235	173						
		60							428	415	401	388	374	361	347	334	320	307	291	275	255	234	203	123					
Shut-off PSI:			213	204	195	187	178	169	161	152	143	135	126	117	109	100	91	74	48	22									
5S10-22	1	0																											
		20																											
		30																											
		40																											
		50																											
		60																											
Shut-off PSI:																													
5S15-26	1 1/2	0																											
		20																											
		30																											
		40																											
		50																											
		60																											
Shut-off PSI:																													
5S15-31	1 1/2	0																											
		20																											
		30																											
		40																											
		50																											
		60																											
Shut-off PSI:																													



WARZYN ENGINEERING INC.  
MADISON, WISCONSIN

BY JCK DATE 10-31-89 SUBJECT REFUSE HIDEAWAY SHEET NO. 0 OF 10  
CHKD. BY MAL DATE 11/1/89 LEACHATE / CONDENSATE JOB NO. 13923  
PIPING

A. OBJECTIVE: CALCULATE SIZE OF HDPE GRAVITY LEACHATE CONVEYANCE PIPE FROM WELL HEAD TO LEACHATE HOLDING TANK

B. ASSUMPTIONS:

- 1) LEACHATE DENSITY SIMILAR TO WATER
- 2) PIPE IS SDR 17 HDPE, 6"  $\phi$
- 3) MINIMUM PIPE SLOPE IS 0.5%
- 4) MAX. FLOWRATE IF 13 WELLS PUMPS AT 5 GPM EACH IS 65 GPM
- 5) CONDENSATE GENERATION ESTIMATED AT 0.44 GAL/SCFM / DAY GAS EXTRACTED  
13 WELLS @ 50 SCFM (D.H.) = 230 GAL/DAY  
= 630 GPM
- 6) PIPE WILL FLOW AS OPEN CHANNEL GRAVITY FLOW PIPE

\* MAXIMUM CONDENSATE PRODUCTION AT EXISTING LANDFILL FOR WINTER CONDITIONS (BASED ON PREVIOUS CONDENSATE VOLUME ANALYSIS NOV. 1988, WARZYN PROJ. NO. 13262)

C. CALCULATION:

BASED ON GRAVITY FLOW NOMOGRAPH THE FOLLOWING FLOW RATES HAVE BEEN ESTIMATED FOR A 6" PIPE:


<u>SLOPE</u>	<u>FLOWRATE</u>
0.5%	300 GPM
1.0%	500 GPM
2.0%	900 GPM

00 CAPACITY FAR EXCEEDS MAX. FLOW GENERATION.



BY JCK DATE 10.31.89  
CHKD. BY MAC DATE 11.1.89

SUBJECT REFUSE HIDEAWAY  
HDPE GRAVITY FLOW





WARZYN ENGINEERING INC.  
MADISON, WISCONSIN

BY ML DATE 10-31-89 SUBJECT REFUSE MIDEAWAY SHEET NO. 3 OF 16  
CHKD. BY MAL DATE 11/1/89 LEACHATE TANK SIZING JOB NO. 13928

A. OBJECTIVE: ESTIMATE STEADY STATE LEACHATE PRODUCTION RATE FROM SITE AND SIZE HOLDING TANK

B. ASSUMPTIONS:

- 1) THREE DAY LEACHATE HOLDING
- 2) REFUSE POROSITY  $\approx 30\%$
- 3) COVER TO BE UPGRADED TO NR 504.07 REQUIREMENT (FUTURE)  $10^{-7}$  CM/S CONDUCTIVITY
- 4) COVER AREA ESTIMATED AT 19 ACRES
- 5) PRESENT LEACHATE VOLUME STANDING IN REFUSE CANNOT BE ACCURATELY ESTIMATED BECAUSE OF INACCESSIBLE (DAMAGED) LEACHATE HEAD WELLS & OUTDATED DATA
- 6) COVER INFILTRATION ESTIMATED AT 3"-5"/YR. WITH MAX OF 12"/YR.
- 7) BASE PERMEABILITY ALLOWS HEAD TO FORM

C. CALCULATION:

LEACHATE PRODUCTION

$$Q_{3"/YR} = 19 \text{ AC.} \left( \frac{43560 \text{ SF}}{\text{AC}} \right) \frac{3}{12} \left( \frac{7.48}{365} \right) = 4240 \text{ GAL/D}$$

$$Q_{5"/YR} = 19 (43560) \frac{5}{12} \left( \frac{7.48}{365} \right) = 7067 \text{ GAL/D}$$

$$Q_{12"/YR} = 19 (43560) \frac{7.48}{365} = 16,961 \text{ GAL/D}$$

TO BE CONSERVATIVE ASSUME 5"/YR. INFILTRATION RATE. TANK SIZE = 3 DAY STORAGE @ 7067 = 21,201 GAL

SO USE A 25,000 GALLON HOLDING TANK



**AREA AND VOLUME COMPUTATIONS**  
**WARZYN ENGINEERING INC.**

USER INITIALS: JCK DATE: 9-18-69

## \*PROJECT INFORMATION\*

PROJECT NAME: REFUSE HIDEAWAY  
 PROJECT NUMBER: 13928

## \*INITIALIZATION DATA\*

HORZ. SCALE (FT/IN): 60  
 VERT. SCALE (FT/IN): 60  
 PRECISION (%): 995

AREA ID.: 1  
 VOLUME TYPE: LEACHATE  
 AVERAGE DEPTH (FT) = 6  
 AREA (SI) = 112.0713  
 AREA (SF) = 403457  
 AREA (SY) = 44629  
 AREA (ACRES) = 9.262  
 VOLUME (CY) = 89657

NOTE: A PRECISION OVERRIDE OF 99.84 % WAS ACCEPTED FOR THIS AREA

AREA ID.: 2  
 VOLUME TYPE: LEACHATE  
 AVERAGE DEPTH (FT) = 1  
 AREA (SI) = 112.5592  
 AREA (SF) = 405213  
 AREA (SY) = 45024  
 AREA (ACRES) = 9.302  
 VOLUME (CY) = 15008

NOTE: A PRECISION OVERRIDE OF 99.46 % WAS ACCEPTED FOR THIS AREA

AREA ID.: 3  
 VOLUME TYPE: WASTE  
 AVERAGE DEPTH (FT) = 0  
 AREA (SI) = 226.5099  
 AREA (SF) = 822634  
 AREA (SY) = 91404  
 AREA (ACRES) = 18.695  
 VOLUME (CY) = 0

NOTE: A PRECISION OVERRIDE OF 100 % WAS ACCEPTED FOR THIS AREA

MEMORANDUM

November 1, 1989

To: File 13928.40 - H

From: Jan C. Kucher, P.E. JCK

Re: Leachate Generation and Storage  
Refuse Hideaway Landfill

The purpose of this memorandum is to summarize and outline analysis performed to estimate leachate generated and holding tank sizing at Refuse Hideaway Landfill.

Based on leachate level data obtained from the January 1988 In-Field Conditions Report, by RMT Inc. a 10 to 12 ft leachate head was documented on the base of the landfill in the area of leachate headwells LH-1 and LH-2. This information was used in conjunction with an infiltration estimate as a basis for estimating the size of leachate holding tank required.

Typically the HELP model (Hydrologic Evaluation of Liner Performance) is used to determine the flow of precipitation into the landfill through the cover. This model takes into consideration many factors, of which we do not have adequate data.

Based on Help model analyses run on covers of a similar design, a conservative conductivity through the cover would be 3 to 5 inches per year, with a maximum of 12 inches per year. The tank will be designed for three days of leachate storage. Using these assumptions, at three inches per year, the infiltration through the cover is estimated at 4,200 gallons per day, with three-day storage at 12,800 gallons. At five inches per year, infiltration through the cover is estimated at 7,100 gallons per day with three-day storage of 21,300 gallons. At 12 inches per year, infiltration through the cover is estimated at 17,000 gallons per day with three-day storage at 51,000 gallons. Assuming an infiltration of five inches per year through the cover, we anticipate that a 25,000 gallon leachate storage tank will be adequate.

A 30-year design life for the tank is assumed. After determining the size necessary for the leachate tank, an analysis was performed to compare various types of tanks, both below grade and above grade. For above-grade tanks, either double-wall tanks would be needed, or single-wall with a containment berm containing the total volume of the tank. Additionally, tank insulation and heat tracing would be essential, with alarms in the event the leachate temperature dropped near freezing. This would of course incur energy costs for the heating of the tanks, as well as maintenance costs associated with frost protection on both the piping and the tank. Based on these factors, we recommend a below-grade tank.

Both steel and fiberglass double wall tanks were evaluated. A steel tank was found to be most cost effective for this application based on warranty, cost, integrity, monitoring capability, delivery time, and compatibility with leachate.

JCK/kjw/JVS  
[wpmisc-111-99]  
13928.40



WARZYN ENGINEERING INC.  
MADISON, WISCONSIN

BY JCK DATE 10.30.37 SUBJECT REFUSE HIDEAWAY SHEET NO. 11 OF 10  
CHKD. BY MAC DATE 11.1.37 LEACHATE EXTRACTION JOB NO. 13923  
FROM HOLDING TANK

A. OBJECTIVE : CALCULATE PUMP SIZE NECESSARY FOR  
LEACHATE EXTRACTION FROM HOLDING TANK  
(USING TRUCK MOUNTED SUCTION PUMP)


B. ASSUMPTIONS:

- 1) LEACHATE DENSITY SIMILAR TO WATER
- 2) SEPTIC TANK PUMPOUT TRUCK USED
- 3) TRUCK HOSE CONNECTS TO DUCTILE  
IRON STANDPIPE VIA QUICK CONNECT  
COUPLING
- 4) 4" SCH 80 PVC SUCTION PIPE SLOPED  
TO DRAIN BACK TO LEACHATE HOLDING  
TANK (FOR FROST PROTECTION)
- 5) 4" SCH 80 PVC PIPE IS RUN TO  
LOADOUT AREA FOR FUTURE SPILLAGE  
DRAINBACK

WARZYN ENGINEERING INC.  
MADISON, WISCONSIN

BY JK DATE 10-30-89 SUBJECT REFUSE MIDEAWAY SHEET NO. 12 OF 16  
 CHKD. BY MAL DATE 11/1/89 LEACHATE EXTRACTION JOB NO. 13923  
FROM HOLDING TANK

C. CALCULATION:



HYDRAULIC PROFILE

N.T.S.

STATIC HEAD = SUCTION + DISCHARGE = 17.5' + 10' = 27.5'

SYSTEM HEADLOSS:

ITEM	LENGTH	EQ. 4" LENGTH
1. 4" φ SCH 80 PVC SUCTION	13.0'	-
2. 4" φ SCH 80 PVC 90° ELBOW	-	10.1'
3. 4" φ SCH 80 PVC SUCTION	37.0'	-
4. 4" φ SCH 80 PVC 90° ELBOW	-	10.1
5. 4" φ CLAYS 50 D.I.	4.0'	-
6. 4" φ CLAYS 50 D.I. 90° ELBOW	-	10.1'
7. 4" φ EPDM HOSE	10.0'	-
SUCTION SUBTOTAL	64.0'	+ 30.3 = 94.3'
8. 4" φ D.I. PUMP DISCHARGE	10'	-
DISCHARGE SUBTOTAL	10'	-

TOTAL EQUIVALENT LENGTH SCH 80 PVC = 94.3' + 10.0' = 104.3'



WARZYN ENGINEERING INC.  
MADISON, WISCONSIN

BY JLK DATE 10.30.89 SUBJECT REFUSE HIDEAWAY SHEET NO. 13 OF 10  
 CHKD. BY MAC DATE 11/1/89 LEACHATE EXTRACTION FROM JOB NO. 13923  
HOULDING TANK

$Q$	SUCTION $h_L$ ①	DISCH. $h_L$ ②	$\Sigma h_L$	STATIC	TDH	NPSH $_{\Delta}$ ③
50 GPM	0.20'	0.02'	0.22'	27.5'	27.7'	15.3'
75	0.42'	0.04	0.46	↓	28.0	15.1
100	0.72'	0.08	0.80		28.3	14.8
125	1.09	0.12	1.21		28.7	14.4
150	1.52	0.16	1.68		29.2	14.0
175	2.03	0.22	2.25		29.8	13.5
200	2.59	0.28	2.87		30.4	12.94

① SUCTION  $h_L = 94.3 \left( \frac{h_L}{100'} @ n \text{ GPM} \right)$

② DISCHARGE  $h_L = 10 \left( \frac{h_L}{100'} @ n \text{ GPM} \right)$

③  $NPSH_{\Delta} = P_{ATM} - H - P_v - h_L = 14.7(2.31) - 17.5 - 0. + (2.31) - h_L$   
 $= 15.53 - h_L$

$NPSH_{\Delta} > NPSH_{REQ.}$  f(PUMP OPERATING CHARACTERISTICS)

AFTER DISCUSSING APPLICATION WITH PUMP SUPPLIER AND SEPTIC TANK PUMP OUT HAULERS IT SHOULD BE NO PROBLEM TO EXTRACT LEACHATE.




**WARZYN ENGINEERING INC.**  
**MADISON, WISCONSIN**

BY JCK DATE 10-31-59 SUBJECT REFUGE HIDEAWAY SHEET NO. 14 OF 10  
 CHKD. BY \_\_\_\_\_ DATE \_\_\_\_\_ JOB NO. 13923

**Resistance of Valves and Fittings to Flow of Fluids**

Example: The dashed line shows that the resistance of a 6-in. standard elbow is equivalent to approximately 16 ft of 6-in. standard pipe.

Note: For sudden enlargements or sudden contractions, use the smaller diameter, *d* on the pipe-size scale. Head loss through check valves varies with types manufactured. Consult with manufacturer for correct values.



Courtesy of Crane Co.





**WARZYN ENGINEERING INC.  
MADISON, WISCONSIN**

BY JOK DATE 10/31/89 SUBJECT REFUSE HEDWAY SHEET NO. 15 OF 10  
 CHKD. BY \_\_\_\_\_ DATE \_\_\_\_\_ LEACHATE HOLDING TANK JOB NO. 1733  
DEPTH / VOLUME RELATION

REFERENCE : A & S WELDING (TANK MANUFACTURER)

25,000 Gal - 12' x 30'  
Tank Chart

144	25,381	109	20,612	74	13,139	39	5,553
143	25,356	108	20,419	73	12,915	38	5,354
142	25,311	107	20,224	72	12,690	37	5,157
141	25,252	106	20,026	71	12,466	36	4,962
140	25,183	105	19,828	70	12,242	35	4,769
138	25,019	103	19,426	68	11,793	33	4,387
137	24,926	102	19,223	67	11,569	32	4,200
136	24,286	101	19,018	66	11,345	31	4,014
134	24,609	99	18,604	64	10,899	30	3,831
133	24,492	98	18,396	63	10,676	29	3,650
132	24,371	97	18,186	62	10,453	28	3,471
131	24,244	96	17,975	61	10,232	27	3,294
130	24,114	95	17,763	60	10,010	26	3,120
129	23,979	94	17,550	59	9,789	25	2,949
128	23,839	93	17,335	58	9,568	24	2,781
127	23,696	92	17,120	57	9,349	23	2,615
126	23,550	91	16,904	56	9,130	22	2,452
125	23,400	90	16,687	55	8,911	21	2,292
124	23,246	89	16,470	54	8,693	20	2,135
123	23,089	88	16,251	53	8,477	19	1,981
122	22,929	87	16,032	52	8,261	18	1,831
121	22,766	86	15,812	51	8,045	17	1,684
120	22,600	85	15,592	50	7,831	16	1,542
119	22,432	84	15,371	49	7,618	15	1,403
118	22,260	83	15,149	48	7,406	14	1,268
117	22,086	82	14,927	47	7,195	13	1,137
116	21,910	81	14,705	46	6,985	12	1,010
115	21,731	80	14,482	45	6,776	11	888
114	21,550	79	14,259	44	6,569	10	772
113	21,367	78	14,035	43	6,363	9	661
112	21,181	77	13,811	42	6,158	8	555
111	20,993	76	13,587	41	5,955	7	455
110	20,804	75	13,364	40	5,753	6	362
						5	276
						4	198
						3	129
						2	70
						1	25

TABLE TO BE USED TO DETERMINE GALLON VOLUME IN TANK FOR OPERATION AND MAINTENANCE PURPOSES.



WARZYN ENGINEERING INC.  
MADISON, WISCONSIN

BY JJE DATE 10-31-91 SUBJECT REFUSE HIDEAWAY SHEET NO. 16 OF 16  
CHKD. BY DJE DATE 11-1-91 LEACHATE HOLDING TANK JOB NO. 13925  
BALLAST CALCULATION

A. OBJECTIVE: CHECK BOUYANCY AND DESIGN  
BALLAST FOR LEACHATE HOLDING  
TANK

B. ASSUMPTIONS:

- 1) 25,000 GALLON EMPTY TANK
- 2) WATER TABLE AT SURFACE\*
- 3) WT. OF SATURATED SOIL = 60 PCF
- 4) BALLAST TO CONSIST OF  
CONCRETE DEADMEN ON EACH SIDE  
OF TANK ANCHORED WITH STEEL  
STRAPS

\* WATER TABLE ASSUMED AT SURFACE FOR  
BOUYANCY WORST CASE

C. CALCULATION:

RESTRAINING FORCES:

$$\begin{aligned} \text{SOIL ABOVE TANK} & \\ 12 (4) 30' (60 \text{ PCF}) &= 26,400 \# \\ \text{TANK WEIGHT} &= 25,000 \# \\ \text{DEADMEN} & \\ 2 (30')^2 (1' \text{ THK}) (150 - 62.4) &= 10,512 \# \\ \text{SOIL ABOVE DEADMEN} & \\ 2 (30')^2 (17') (60 \text{ PCF}) &= 122,400 \# \\ \hline & 254,312 \# \end{aligned}$$

BOUYANT FORCE:

$$\text{EMPTY TANK} \\ 25,000 \text{ GAL} \left( \frac{\text{CF}}{7.48 \text{ GAL}} \right) \frac{62.4 \#}{\text{CF}} = 208,556 \#$$

$$\text{FACTOR OF SAFETY} = \frac{254,312}{208,556} = 1.2$$






# PARTIAL GAS AND LEACHATE EXTRACTION SYSTEM INTERIM REMEDIAL MEASURES REFUSE HIDEAWAY LANDFILL TOWN OF MIDDLETON DANE COUNTY, WISCONSIN



**SITE LOCATION MAP**



**WARZYN**  
WARZYN ENGINEERING INC.  
Madison • Milwaukee  
Minneapolis • Chicago  
Detroit

## LIST OF DRAWINGS

<u>SHEET NO.</u>	<u>TITLE</u>	<u>DRAWING NO.</u>
1	PARTIAL GAS AND LEACHATE EXTRACTION SYSTEM LAYOUT	13928-1
2	DETAILS	13928-2
3	DETAILS	13928-3
4	DETAILS	13928-4
5	DETAILS	13928-5
6	LEACHATE HOLDING TANK DETAILS	13928-6

PREPARED FOR:  
WISCONSIN DEPARTMENT OF  
NATURAL RESOURCES  
MADISON, WISCONSIN

*Evanson*

RECEIVED  
DEC 20 1989  
BUREAU OF SOLID  
HAZARDOUS WASTE MANAGEMENT

OFFICE COPY


## REVISIONS

**WARZYN**

DECEMBER 1989 13928-7

PARTIAL GAS AND LEACHATE EXTRACTION SYSTEM  
INTERIM REMEDIAL MEASURES  
REFUSE HIDEAWAY LANDFILL  
TOWN OF MIDDLETON  
DANE COUNTY, WISCONSIN





**LEGEND (EXISTING)**

- SPOT ELEVATION
- GROUND CONTOUR
- DEPRESSION
- SURFACE WATER
- ACCESS ROAD
- BUILDING
- FENCE LINE
- TREES AND SHRUBS
- - - APPROXIMATE LIMITS OF LANDFILL
- POLE
- ⊕ LH1 LEACHATE HEADWELL LOCATION AND NUMBER

**LEGEND (PROPOSED)**

- ▲ DRIPLINE LOCATION AND NUMBER
- ⊕ GW1 GAS LEACHATE EXTRACTION WELL LOCATION AND NUMBER
- ⊕ LH5 LEACHATE/GAS MONITORING WELL LOCATION AND NUMBER
- CO2 CLEANWELL RISER LOCATION AND NUMBER
- 6" DIA. HDPE GAS HEADER PIPE
- 6" DIA. HDPE GRAVITY LEACHATE CONVEYANCE PIPE
- 6" DIA. HDPE GRAVITY LEACHATE/CONDENSATE CONVEYANCE PIPE
- 6" DIA. HDPE GRAVITY CONDENSATE CONVEYANCE PIPE
- 6" DIA. GAS DISCHARGE PIPE
- 100' 2.0% PIPE LENGTH, PIPE SLOPE AND DIRECTION OF LEACHATE/CONDENSATE FLOW
- GRAVEL ACCESS ROAD
- TEMPORARY FENCE

**NOTES**

1. BASE MAP DEVELOPED FROM AERIAL PHOTOGRAPHY PROVIDED BY ERM, INC., GRAND TOWNS, MD, DATED AUGUST 21, 1987.
2. CONTOUR INTERVAL IS TWO FEET.
3. PROJECT BENCHMARK IS CHISEL MARK ON TOP STEEL PLATE AT NORTH END OF LOADING DOCK LOCATED ON THE SOUTH SIDE OF MOST EASTERLY SITE BUILDING; ELEV. = 966.31, U.S.G.S. DATUM. ELEVATIONS ARE BASED ON U.S.G.S. DATUM.
4. GRID SYSTEM SHOWN IS STATE PLANE COORDINATE SYSTEM.
5. APPROXIMATE LIMITS OF LANDFILL BASED ON ERM, INC. DRAWING 1181-02-2, DATED NOVEMBER 10, 1986. THESE LIMITS DO NOT REFLECT LIMITS OF REFUSE.
6. LOCATIONS OF EXISTING LEACHATE HEADWELLS LH-1, LH-2 AND LH-3 BASED ON ERM, INC. DRAWING 1181-02-2, DATED NOVEMBER 10, 1986.
7. FACTUAL LOCATIONS AND ELEVATIONS OF GAS AND LEACHATE EXTRACTION SYSTEM COMPONENTS WILL BE DETERMINED BY CONDITIONS ENCOUNTERED IN THE FIELD DURING FIELD STAKING. FIELD STAKING WILL BEGIN AT ORIPLED DL1 (400.560N, 2.112.778E). PIPE GRADES WILL CONFORM TO SLOPES SHOWN.
8. W.F.S.I. - WARZYN TURNKEYS, SUBCONTRACTOR INSTALLED.

Checked By: JAL, 06/03/89  
 Date: 12/19/89  
 Reference:

Designed By: BEM, JAL  
 Drawn By: HLH  
 Approved By: Joel V. Schutte

**WARZYN**  
 WARZYN ENGINEERING INC.  
 MADISON • MINNEAPOLIS  
 MINNEAPOLIS • CHICAGO • DETROIT


Date: By: App'd:

Revisions:

PARTIAL GAS AND LEACHATE EXTRACTION SYSTEM LAYOUT  
 PARTIAL GAS AND LEACHATE EXTRACTION SYSTEM  
 INTERIM REMEDIAL MEASURES REFUSE HIDEAWAY LANDFILL TOWN OF MIDDLETON

Printed: DEC 21 1989  
 Sheet Number: 1 OF 1  
 Project Number: 13928  
**WARZYN**






1  
2  
TYPICAL GAS/LEACHATE EXTRACTION WELL  
NOT TO SCALE

**GAS/LEACHATE EXTRACTION WELL TABLE**

WELL	LOCATION	A	B	C	D	E	F	G	H	I
GW1	400,374N 2,113,054E	49.0'	17'	16'	1'	1'	2'	27.5'	0.5'	1'
GW2	400,340N 2,112,843E	52.3'	17'	16'	1'	1'	2'	30.8'	0.5'	1'



2  
TYPICAL LEACHATE/GAS MONITORING WELL DETAIL  
NOT TO SCALE

**MONITORING WELL TABLE**

WELL	LOCATION	APPROXIMATE GROUND ELEV.	APPROXIMATE BASE ELEV.	WELL DEPTH
LH4	400,369N 2,113,054E	983.5	933.0	50.5
LH5	400,361N 2,112,981E	984.5	933.0	51.5
LH6	400,354N 2,112,932E	985.5	935.0	50.5

Checked BY: CAL 05/14  
Date: 12/19/89  
Designed By: SEPTAL  
Drawn By: ALK  
Approved By: Paul V. Johnston  
Reference: 13928/2  
File Path: 13928/2  
© 1989 Warzyn Engineering Inc. All Rights Reserved.


**WARZYN**  
WARZYN ENGINEERING INC.  
Madison • Milwaukee  
Minneapolis • Chicago  
Detroit

Date: 8/1/89  
Revision: 1

**DETAILS**  
PARTIAL GAS AND LEACHATE EXTRACTION SYSTEM  
INTERIM REMEDIAL MEASURES  
REFUSE HIDEAWAY LANDFILL  
TOWN OF MIDDLETON  
DANE COUNTY, WISCONSIN

Printed: 8/1/89  
Sheet Number: 2 OF 6  
Project Number: 13928  
**WARZYN**






**KEY**

- 1 1/8" DIA. STAINLESS STEEL PULLOUT CABLE
- 2 1" DIA. FLEXIBLE DISCHARGE HOSE
- 3 STAINLESS STEEL SAMPLE PORT
- 4 6" DIA. SCH. 80 PVC GAS WELL PIPE
- 5 ELECTRICAL WIRING FOR PUMP
- 6 SEAL-TIGHT ELECTRICAL CONDUIT AND WIRING FOR PUMP
- 7 6" x 6" x 3" SCH. 80 PVC TEE
- 8 SEALED CONDUIT WELL CASING PENETRATION AND ELECTRICAL JUNCTION BOX STRAPPED TO WELL CASING
- 9 1" DIA. STAINLESS STEEL NIPPLE THREADED THROUGH BLIND FLANGE
- 10 1" DIA. STEEL UNION
- 11 1" DIA. STEEL 90° ELL
- 12 1" DIA. COATED STEEL TO HDPE TRANSITION FITTING
- 13 1/4" STAINLESS STEEL EYEBOLT WITH WASHERS AND NUT
- 14 3" DIA. FLEXIBLE COUPLING WITH CLAMPS (FERNCO)
- 15 3" DIA. SCH. 80 PVC PIPE
- 16 1" DIA. HDPE HEATED TRACED PIPE
- 17 3/4" x 1/2" SCH. 80 PVC REDUCING BUSHING WITH 1/2" DIA. SCH. 80 PVC PLUG (MONITORING PORT)
- 18 3" DIA. BUTTERFLY VALVE (TILT FOR CONDENSATE DRAINAGE)
- 19 3" DIA. SCH. 80 PVC 90° ELL
- 20 3" DIA. FLEXIBLE TUBING WITH CLAMPS
- 21 3" DIA. HDPE PIPE
- 22 PIPE INSULATION
- 23 6" x 6" x 3" HDPE TEE (ON GAS HEADER PIPE)
- 24 6" x 6" x 1" HDPE TEE (ON LEACHATE CONVEYANCE PIPE)


**1 TYPICAL GAS/LEACHATE EXTRACTION WELL HEAD DETAIL**

SCALE: 1" = 1'-0"



**2 TYPICAL PIPE BEDDING DETAIL - INSIDE LANDFILL REFUSE LIMITS**

NOT TO SCALE



**3 HDPE LEACHATE / CONDENSATE CONVEYANCE PIPE BEDDING DETAIL - OUTSIDE LANDFILL REFUSE LIMITS**

SCALE: 1" = 1'-0"

Checked By: JAL, JAL  
 Date: 12/19/89  
 Drawn By: ALK  
 Approved By: JAL, JAL  
 Reference: JAL V. JAL  
 File Path: 13928\3  
 © 1988 Warzyn Engineering Inc. All Rights Reserved.


**WARZYN**  
 WARZYN ENGINEERING INC.  
 Madison • Milwaukee  
 Minneapolis • Chicago  
 Detroit

Date: 8.1.89  
 Revisions


**DETAILS**  
 PARTIAL GAS AND LEACHATE  
 EXTRACTION SYSTEM  
 INTERIM REMEDIAL MEASURES  
 REFUSE-HIDEAWAY LANDFILL  
 TOWN OF MIDDLETON  
 DANE COUNTY, WISCONSIN

Printed: DEC 20 1989  
 Sheet Number: 3 OF 6  
 Project Number: 13928  
**WARZYN**







1 DRIPLEG DETAIL (DL1)  
NOT TO SCALE



2 DRIPLEG DETAIL (DL2)  
NOT TO SCALE



3 CLEANOUT RISER DETAIL AT LEACHATE HOLDING TANK (CO4)  
SCALE: 1" = 2'-0"



4 TYPICAL CLEANOUT RISER DETAIL  
SCALE: 1" = 2'-0"

Checked By: JAL, BEB, JAL  
 Date: 12/19/89  
 Designed By: BEB, JAL  
 Drawn By: ALK  
 Approved By: Joel K. Schutte  
 Reference:   
 File Path: 13928\4  
 © 1988 Warzyn Engineering Inc. All Rights Reserved.

**WARZYN**  
 WARZYN ENGINEERING INC.  
 Madison • Milwaukee  
 Minneapolis • Chicago  
 Detroit


Date: By: App'd

Revisions

**DETAILS**  
 PARTIAL GAS AND LEACHATE  
 EXTRACTION SYSTEM  
 INTERIM REMEDIAL MEASURES  
 REFUSE HIDEAWAY LANDFILL  
 TOWN OF MIDDLETON  
 DANE COUNTY, WISCONSIN


Printed: 12/19/89  
 Sheet Number: 4 OF 6  
 Project Number: 13928  
**4**  
**WARZYN**





- KEY**
- ① FLAME ARRESTOR
  - ② DRIPLEG DL2
  - ③ CONDENSATE CONVEYANCE PIPE
  - ④ GAS DISCHARGE PIPE TO FLARE
  - ⑤ GAS HEADER PIPE
  - ⑥ LEACHATE CONVEYANCE PIPE
  - ⑦ LEACHATE/CONDENSATE CONVEYANCE PIPE
  - ⑧ DRIPLEG DL1
  - ⑨ BUND FLANGE
  - ⑩ BUTTERFLY VALVE
  - ⑪ FLOW MONITORING PORT
  - ⑫ 8' HIGH CHAIN LINK FENCE WITH MANNWAY GATE

①  
⑤ **BLOWER STATION/FLARE STATION SCHEMATIC LAYOUT**  
NOT TO SCALE



②  
⑤ **GUARD POST DETAIL**  
SCALE: 1" = 2'-0"

Checked By: JAL/AEM/3/4  
Date: 12/17/89

Drawn By: ALK

Designed By: BENJ. JAL  
Approved By: Jodi V. G. [Signature]

Reference:  
File Path: \13928\5

© 1988 Warzyn Engineering Inc. All Rights Reserved.

**WARZYN**  
WARZYN ENGINEERING, INC.  
Madison • Milwaukee  
Minneapolis • Chicago  
Detroit

Date: 12/17/89


Revisions

**DETAILS**  
PARTIAL GAS AND LEACHATE  
EXTRACTION SYSTEM  
INTERIM REMEDIAL MEASURES  
REFUSE HIDEAWAY LANDFILL  
TOWN OF MIDDLETON  
DANE COUNTY, WISCONSIN

Printed: 12/17/89  
Sheet Number: 5 OF 6  
Project Number: 13928

**WARZYN**






1 PLAN VIEW - LEACHATE HOLDING TANK  
SCALE: 1" = 5'-0"


north

NOTE:  
EXTERIOR PIPING TO BE  
EXCAVED IN 2 FEET OF  
COMPACTED CLAY




3 SECTION (LOOKING EAST)  
SCALE: 1" = 5'-0"

north




2 SECTION (LOOKING NORTH)  
SCALE: 1" = 5'-0"

NOTE:  
MAINTAIN TANK ELECTRICAL  
ISOLATION FROM EARTH AND  
CONFIRM WITH CONTINUITY  
CHECK.



4 STI-86 CONTAINMENT SYSTEM AND PIPING PLAN  
SCALE: 1" = 1'-0"

north



5 PIPE CONNECTION AT BLIND FLANGE  
SCALE: 1" = 1'-0"

- TANK INSTALLATION NOTES**
- TANK SHALL BE CHECKED WITH FIRMS AND THE FINISH PROTECTED PRIOR TO TANK INSTALLATION.
  - INSTALLATION SHALL BE IN ACCORDANCE WITH PER/PP 100-07 RECOMMENDED PRACTICES FOR INSTALLATION OF UNDERGROUND LIQUID STORAGE SYSTEMS AND API 1615 INSTALLATION OF UNDERGROUND PETROLEUM STORAGE SYSTEMS.
  - TANK SHALL BE ELECTRICALLY GROUNDED FROM GROUND AND CONFIRMED BY CONTINUITY TESTING.
  - EXPOSED METAL SURFACES SHALL BE PAINTED WITH THICK ENAMEL COAL TAR EPOXY.
  - CATHODIC PROTECTION TEST STATION TO BE INSTALLED.
  - INTERSTITIAL MONITORING, FLOAT SYSTEMS AND TANK INSTALLATION SHALL BE IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.
  - W.F.S.I. - WARZYN FURNISHED, SUBCONTRACTOR INSTALLED.
  - INSTALL MEDIA AND CONTROL PANEL BOX WITH HEATER FOR FLOAT SWITCH, INTERSTITIAL MONITORING, WITH AUDIBLE AND VISUAL AIDS.
  - ALL WORK AND MATERIALS SHALL CONFORM IN EVERY RESPECT TO THE CURRENT RULES AND REQUIREMENTS OF THE NATIONAL FIRE PROTECTION ASSOCIATION, NATIONAL AND STATE ELECTRICAL CODES, LOCAL CODES AND ORDINANCES AND OSHA.
  - SEAL ALL OPENINGS TO TANK AND FITTINGS TO STI-86 SYSTEM WATER TIGHT.

- TANK MANUFACTURER NOTES**
- ALL WORK SHALL BE IN ACCORDANCE WITH STEEL TANK INSTITUTE (STI) SPECIFICATIONS AND PROCEDURES. (NOTE: TANK AND STI-86 SYSTEM TO BE COVERED BY STI 30-YEAR WARRANTY AND "AUTOLOG" PROGRAM.)
  - TANK SHALL BE STI-P3 DOUBLE-WALL STEEL WITH STI-86 CONTAINMENT SYSTEM MANHOLE AND PIPING SYSTEM, INCLUDING DIELECTRIC THREADED BUSHINGS, AND PIPE BOOTS.
  - TANK INTERIOR PREPARATION TO CONSIST OF THE FOLLOWING:
    - GRIND ALL WELD SPATTER AND PROTRUSIONS
    - SOLVENT CLEAN SURFACE
    - BLAST TANK ACCORDING TO SSPC-SP10, NEAR-WHITE BLAST WITH CLEAN UNOILED SAND OR BLACKJACK TO EFFECT 2.5 TO 3.0 MIL PROFILE
    - VACUUM ALL BLAST MEDIA
    - SUBSTRATE MUST BE 70°F TO PAINT
    - SPRAY APPLY ONE EVEN COAT OF TIGREX SERIES 61 PRIMER 5002 BEIGE TO MINIMUM DRY FILM THICKNESS (DFT) OF 0 MILS
    - ALLOW TO CURE FOR ONE WEEK, THEN BRUSH COAT ALL KEELS AND ANCHORS
    - FINISH COAT WITH 0 MILS THICKNESS SERIES 61, 5003 GRAY
    - AFTER SECOND COAT USE C-0 LOW VOLTAGE "BIRD COAT" TO CHECK FOR HIGHLIGHTS
    - THREE REPERMEABILITY SMALL PERMEABILITY MONITOR COATINGS AND PREPARE LETTER REPORT ASSURING COMPLIANCE WITH STI WARRANTIES.
  - SAND BLAST AND COAT TANK EXTENDED IN ACCORDANCE WITH STI.
  - CATHODIC PROTECTION TEST STATION TO BE INCLUDED.
  - INCLUDE THEMEC TOUCH UP KIT.
  - INTERIOR A COATING OF STI-86 SYSTEM TO BE COATED IN ACCORDANCE WITH STI.
  - TANK TIGHTNESS TESTS SHALL BE PERFORMED ABOVE GRADE PRIOR TO INSTALLATION AT 5 PSI IN ACCORDANCE WITH TANK MANUFACTURER'S RECOMMENDATIONS AND API 1615.

Checked By: JVL/STK  
Date: 12/19/11  
Designed By: JVK  
Drawn By: ALK  
Approved By: Paul V. Johnson  
Reference:  
File Path: 13928\6

**WARZYN**  
WARZYN ENGINEERING INC.  
Madison • Minneapolis • Detroit

Revisions:  
LEACHATE HOLDING TANK DETAILS  
PARTIAL GAS AND LEACHATE  
EXTRACTION SYSTEM  
INTERIM REMEDIAL MEASURES  
REFUSE, HIGHWAY LANDFILL  
TOWN OF MINNETONKA

Printed: DEC 1 2011  
Sheet Number: 6 OF 6  
Project Number: 13928  
WARZYN