

November 22, 2022

Ms. Cindy Koepke
Hydrogeologist
Wisconsin Department of Natural Resources
3911 Fish Hatchery Road
Fitchburg, WI 53711

Subject: Refuse Hideaway Landfill
October 2022 Operation Monitoring and Maintenance Activities

Dear Cindy:

TRC completed the following operation, monitoring, and maintenance activities and system troubleshooting at the Refuse Hideaway Landfill in Middleton, WI in October 2022.

- October 1 – October 6, 2022: Van Ert Conducted Electrical System Upgrades
- October 3, 2022: Gas Probe Monitoring
- October 6, 2022: Restart GES Blower System, Troubleshoot Air Compressor System, Evaluate GV-4 Broken Air Line
- October 7, 2022: Site Walk to Evaluate Air Line Relocation
- October 11, 2022: Bi-weekly Site Inspection
- October 20, 2022: Landfill Cap Reseeding
- October 21, 2022: GV-4 Air Line Repair
- October 26, 2022: Monthly Site Inspection and Electrical Evaluation
- October 28, 2022: Completed GV-4 Air Line Repair
- October 31, 2022: Electrical System Evaluation with Van Ert

Electrical System Upgrades

Van Ert Electric removed the old transformers from the electrical system, prepped the transformer structure and installed a roof over the structure. Following preparation work, one new Square D (Model EXN75T3H) transformer was installed to replace the old transformers to provide the 480-volts needed to operate the leachate and gas extraction systems. The product data for the transformer is attached. A metal roof cover will be installed in the future when supplies are available.

Van Ert conducted startup of the system on October 6, 2022, and adjustments were made to the transformer based on the output voltage reading 560 volts. The system was restarted, and the output voltage ranged between 497 and 501 volts. The gas extraction and air compressor system were restarted, and further discussion is noted below. Based on the initial system start up, output voltage, and air compressor operation, the system electrical repairs are being evaluated by a TRC electrical engineer. TRC was onsite on October 26, 2022, and October 31, 2022 to collect additional information for the evaluation. A summary of the system upgrades and the evaluation will be provided to WDNR once complete.

Gas Extraction System & Gas Probe Monitoring

The gas extraction system (GES) was restarted on October 6, 2022 and was operated throughout the remainder of the month. TRC conducted two balancing events (October 11 and 26, 2022) since the system was restarted during the month of October.

Ms. Cindy Koepke
Wisconsin Department of Natural Resources
November 22, 2022
Page 2

Perimeter gas probe monitoring was conducted at the site on October 3, 2022, prior to the system being restarted.

Field data from system and gas probe monitoring is included in the attachments.

Leachate Extraction System

The leachate extraction system remained off during the month of October. A new pump head was installed on the air compressor system in June 2022, and the air compressor system was restarted on October 6, 2022 following electrical upgrades. The electrical contactor for the motor starter failed during the start-up and will need to be replaced. Based on the issues with the system to date and the electrical upgrades, the compressor system is being further evaluated by TRC's electrical engineer and a summary will be provided once complete.

During the October 6, 2022, site visit, TRC observed that the air line for gas vent GV-4 was damaged during the September mowing event. TRC coordinated the repairs of the air line with J&R Underground (J&R) and the line was repaired between October 21 and 28, 2022. During the October 21 site visit, the air line was exposed, and it was found that the service line to GV-4 was broken off from a t-fitting installed on the main air supply line. J&R ordered a new t-fitting and installed the fitting along with a new service line to GV-4 on October 28, 2022. Photos of the repair are included in the attached October 28, 2022 field notes.

The leachate tank level was gauged during the October 11, and October 26, 2022 Site Inspections and contained 15.5 inches and 19.75 inches of leachate, respectively.

Cap Inspection


TRC conducted a monthly inspection of the landfill cap and stormwater conveyance features on October 11, 2022. TRC personnel observed areas of bare soil throughout the landfill cap that were previously seeded in 2021. TRC reseeded select areas on October 20, 2022. The areas will be monitored for regrowth in Spring of 2023. The cap inspection form and photo log are attached with further details.

Monitoring results collected during the site visits completed in October 2022 are attached.

If you have any questions, please contact me at astehn@trccompanies.com or 608-807-8112.

Sincerely,

TRC



Andrew Stehn, PE
Project Manager

Attachments: October 2022 Monitoring Results



October 2022 Monitoring Results

REFUSE HIDEAWAY LANDFILL GAS PROBE MONITORING FORM

TECHNICIAN(S): J. Roelke

DATE: 10/3/2022
START TIME: 8:20 AM
END TIME: 2:00 PM

GAS/INSTRUMENT TYPE: GEM 2000
SERIAL NO.: 11668
DATE LAST CALIBRATED: 10/3/2022
METHOD: Standard Calibration Gases
PRESS INSTRUMENT : Manometer

WEATHER CONDITIONS: sunny
TEMPERATURE: 62
BAROMETRIC PRESSURE & TREND: 30.37, falling
GROUND CONDITIONS: moist

GAS PROBE NAME	Time	PRESSURE (in. WC)	METHANE (% LEL)	METHANE (%, by vol.)	CARBON DIOXIDE (%, by vol.)	OXYGEN (%, by vol.)	COMMENTS
GP-1D	8:45	-0.04	6.0	0.3	11.8	4.0	(2)
GP-1S	8:47	0.00	4.9	9.9	14.4	2.3	(2) Stable readings at 2 minutes.
GP-2D	8:53	-0.14	0	0.0	5.4	15.0	(1)
GP-2S	8:55	0.0	0.0	0.0	5.1	15.7	(1)
GP-3	8:58	0.0	22.0	1.1	3.1	16.9	(1)
GP-4	9:04	0.0	0.0	0.0	7.2	15.6	(1)
GP-5	9:07	0.0	0.0	0.0	4.6	17.4	(2)
GP-6	9:12	0.0	0.0	0.0	4.1	18.0	(1)
GP-7	9:20	0.0	0.0	0.0	4.2	17.2	(2)
GP-8	9:28	0.0	0.0	0.0	5.6	16.0	(2)
GP-9	9:33	0.0	0.0	0.0	4.5	16.5	(1)
GP-10	9:38	0.0	0.0	0.0	6.1	15.2	(1)
GP-11D	9:43	0.0	39	1.9	9.9	8.0	(2)
GP-11S	9:45	0.0	0.0	0.0	6.0	15.5	(2)
GP-12D	9:50	0.0	>100	5.9	11.2	9.5	(1) Stable readings at 2 minutes.
GP-12S	9:53	0.0	0.0	0.0	1.6	18.6	(1)
GP-13D	9:57	0.0	3	0.7	4.3	14.4	(2)

GAS PROBE NAME	Time	PRESSURE (in. WC)	METHANE (% LEL)	METHANE (%, by vol.)	CARBON DIOXIDE (%, by vol.)	OXYGEN (%, by vol.)	COMMENTS
GP-13S	9:59	0.0	0.0	0.0	2.1	18.5	(2)
GP-16D	10:19	0.0	0.0	0.0	0.9	19.1	(2)
GP-16S	10:21	0.0	0.0	0.0	2.4	18.1	(2)
GP-17D	10:12	0.0	0.0	0.0	3.2	16.8	(1)
GP-17M	10:14	0.0	0.0	0.0	1.6	18.5	(1)
GP-17S	10:16	0.0	0.0	0.0	3.9	16.6	(1)
GP-18D	10:26	0.0	0.0	0.0	0.2	19.9	(2)
GP-18M	10:28	0.0	0.0	0.0	0.3	19.8	(2)
GP-18S	10:30	0.0	0.0	0.0	0.2	19.9	(2)
GP-19 ⁸⁵⁻¹⁰⁰	11:12	0.0	0.0	0.0	1.1	19.8	(1)
GP-19 ⁵⁰⁻⁷⁰	11:14	0.0	0.0	0.0	1.3	19.5	(1)
GP-19 ²⁵⁻⁴⁰	11:16	0.0	0.0	0.0	1.2	19.5	(1)
GP19 ²⁻¹⁵	11:18	0.0	0.0	0.0	1.9	18.9	(1)
GP-20 ⁸⁵⁻¹⁰⁰	11:03	0.0	0.0	0.0	0.1	20.7	(2)
GP-20 ⁵⁰⁻⁷⁰	11:05	0.0	0.0	0.0	0.3	20.5	(2)
GP-20 ²⁵⁻⁴⁰	11:07	0.0	0.0	0.0	0.7	20.1	(2)
GP-20 ²⁻¹⁵	11:09	0.0	0.0	0.0	2.1	18.8	(2)
GP-21 ⁸⁵⁻¹⁰⁰	10:54	0.0	0.0	0.0	0.2	20.3	(2)
GP-21 ⁵⁰⁻⁷⁰	10:56	0.0	0.0	0.0	0.0	20.8	(2)
GP-21 ²⁵⁻⁴⁰	10:58	0.0	0.0	0.0	0.2	20.5	(2)
GP-21 ²⁻¹⁵	11:00	0.0	0.0	0.0	0.6	20.2	(2)
GP-22 ⁸⁵⁻¹⁰⁰	11:26	0.0	0.0	0.0	2.9	18.0	(2)
GP-22 ⁵⁰⁻⁷⁰	11:28	0.0	0.0	0.0	0.6	19.9	(2)
GP-22 ²⁵⁻⁴⁰	11:30	0.0	0.0	0.0	1.5	19.0	(2)
GP-22 ²⁻¹⁵	11:32	0.0	0.0	0.0	3.9	17.3	(2)

GAS PROBE NAME	Time	PRESSURE (in. WC)	METHANE (% LEL)	METHANE (%, by vol.)	CARBON DIOXIDE (%, by vol.)	OXYGEN (%, by vol.)	COMMENTS
GP-23 ⁸⁵⁻¹⁰⁰	11:36	0.0	0.0	0.0	0.3	20.2	(2)
GP-23 ⁵⁰⁻⁷⁰	11:38	0.0	0.0	0.0	0.2	20.5	(2)
GP-23 ²⁵⁻⁴⁰	11:40	0.0	0.0	0.0	0.0	20.8	(2)
GP-23 ²⁻¹⁵	11:42	0.0	0.0	0.0	0.6	20.1	(2)
GP-24 ⁸⁵⁻¹⁰⁰	11:47	0.0	0.0	0.0	3.5	16.4	(2) Stable readings at 2 minutes.
GP-24 ⁵⁰⁻⁷⁰	11:50	0.0	0.0	0.0	1.0	19.5	(2)
GP-24 ²⁵⁻⁴⁰	11:52	0.0	0.0	0.0	0.2	20.3	(2)
GP-24 ²⁻¹⁵	11:54	0.0	0.0	0.0	1.9	19.0	(2)
GPW-1D	13:33	0.29	0.0	0.0	3.5	16.1	(1)
GPW-1M	13:35	0.30	0.0	0.0	0.4	19.8	(1)
GPW-1S	13:37	0.0	0.0	0.0	2.2	17.8	(1)
G-1D	8:33	0.0	0.0	0.0	0.1	20.7	(1)
G-1S	8:35	0.0	93	4.6	12.8	5.4	(1) Stable readings at 2 minutes.
G-2D	10:03	0.0	0.0	0.0	2.3	18.0	(1)
G-2S	10:05	0.0	>100	6.1	18.1	0.0	(1) Stable readings at 2 minutes.
G-5	9:26	0.0	0.0	0.0	6.8	14.0	(1)
G-6	8:26	0.0	0.0	0.0	0.0	20.8	(1)
G-8	10:49	0.0	0.0	0.0	0.0	20.8	(1)
G-9	10:38	0.0	0.0	0.0	0.1	19.4	(1)
G-10	12:00	-0.04	0.0	0.0	0.3	20.4	(1)
Speedway Office	8:42	0.0	0.0	0.0	0.0	20.8	Open to ATM

NOTES: 8:13 Stopped monitoring probes to assist with compressor/leachate pumps. 9:16 Started to monitor probe GP-6.

Entered by: J. Roelke 10/3/2022

- (1): Locked probe casing.
- (2): Probe is above casing and cannot be locked.
- (3): No cap for probe casing and cannot be locked.

Checked by: A. Ruetten 10/14/2022

Key:

Shallow or 2'-15'
Medium or 25'-40'
Deep or 50'-70'
85'-100'

Monthly System Inspection Log
Landfill Gas Extraction and Leachate Pump System
WDNR - Refuse Highway Landfill
Middleton, Wisconsin


TRC Operator Name: John Roelke	Arrival Time: 8:23	Departure Time: 11:05
Date: 10/11/2022		

Site Conditions	Initial ¹	Final ²	Equipment	
Weather Conditions:	sunny	sunny	Gas/Instrument Type:	GEMS 2000
Ground Condition:	dry	dry	Serial Number:	11668
Barometric Pressure:	30.00	29.95	Date Last Calibrated:	10/11/2022
Barometric Pressure Trend:	falling	falling	Method:	Standard field calibration
Temperature:	54	65	Pressure Instrument:	Dwyer Series 475 Manometer

Landfill Gas Extraction System ³							
System	Location	Tag #	Equipment Description	Set Point	Typical Range	Initial Field Reading ¹	Final Field Reading ²
Blower Motor	Remote	GHS-BLR-301	Amperage	-	3 - 4 amps	3.33	--
			Speed	-	1800 - 1900 rpm	1477.92	--
			Frequency	-	30 - 35 Hz	24.8	--
	HMI		Amperage	-	3 - 4 amps	3.3	--
			Speed	-		34	--
			Hours	-		6474	--

Blower Operating (YES). Note excessive noise or issues observed.

Blower Inlet	HMI	PT-301	Blower Inlet Vacuum	7 in. w.c.	7 in. w.c.	-7.0	-7
	HMI	TE-301	Blower Inlet Temperature	-	50 - 90 °F	68	--
	Local	GHS-PI-301	Blower Inlet Vacuum	7 in. w.c.	7 in. w.c.	-6.97	-6.96
	Local	GHS-TI-301	Blower Inlet Temperature	-	50 - 90 °F	64	72
	Local	Sample Port	Gas Composition - % Methane	-		11.8%	18.2%
			Gas Composition - % CO2	-		8.6%	13.0%
Gas Composition - % Oxygen			-		15.6%	12.9%	
Gas Composition - % Balance			-		64.0%	55.9%	
Demister	Local	GHS-PDI-301	Demister Differential Pressure	-	1-2 in w.c	4	--
	Local		Slight Glass: Liquid Present	-	-	--	--
	HMI	LS-701	Level Indication	-	-	--	--
Blower Outlet	HMI	PT-302	Blower Outlet Flow Pressure	-	-	0.1	0.1
	HMI	TE-302	Blower Outlet Temperature	-	50 - 90 °F	67	72
	HMI	PDT-301	Blower Outlet Flow Differential Pressure	-	1-2 in w.c	0.67	0.68
	HMI	-	Blower Outlet Flow Rate	-	180 - 190 scfm	120	136
	Local	GHS-PI-302	Blower Outlet Flow Pressure	-	-	-6.96	--
	Local	GHS-TI-302	Blower Outlet Temperature	-	50 - 90 °F	64	72
	Local	Sample Port	Gas Composition - % Methane	-		11.8%	18.2%
			Gas Composition - % CO2	-		8.6%	13.0%
Gas Composition - % Oxygen			-		15.6%	12.9%	
Gas Composition - % Balance			-		64.0%	55.9%	
Branch Headers	Local	North	North Branch Vacuum	-	6 - 7 in w.c.	-6.41	-6.16
	Local	North	Valve Position	6 turns open /6	6 turns open	6	6
	Local	North Sample Port	Gas Composition - % Methane	-		30.3%	33.6%
			Gas Composition - % CO2	-		18.3%	20.1%
			Gas Composition - % Oxygen	-		6.9%	5.1%
			Gas Composition - % Balance	-		44.5%	41.2%
	Local	Central	Central Branch Vacuum	-	6 - 7 in w.c.	-6.26	-6
	Local	Central	Valve Position	-	6 turns open	6	6
	Local	Central Sample Port	Gas Composition - % Methane	-		11.3%	12.5%
			Gas Composition - % CO2	-		8.1%	8.9%
			Gas Composition - % Oxygen	-		15.9%	15.0%
			Gas Composition - % Balance	-		64.7%	63.6%
	Local	South	South Branch Vacuum	-	6 - 7 in w.c.	-6.36	-6.17
	Local	South	Valve Position	-	6 turns open	6	6
	Local	South Sample Port	Gas Composition - % Methane	-		10.2%	22.3%
Gas Composition - % CO2			-		8.0%	16.3%	
Gas Composition - % Oxygen			-		16.2%	11.5%	
Gas Composition - % Balance			-		65.6%	49.9%	

Air Compressor System ^{3,5,6} - AIR COMPRESSOR SYSTEM OFFLINE								
Operational Settings	Pressure Set Points				Condensate Set Points			
	Tank Low (psi)	Tank High (psi)	Well Field (psi)	On (min.)	Off (min.)	Open (sec.)	Closed (min.)	Test Operation
	NOT OPERATING							(yes/no)
Air Dryer System⁴ - AIR DRYER OFFLINE		Electrical Status			HMI Heater/Air Conditioner			
System Operational:		NO		3-Phase Power Indicator:		3 of 3		Operational
Condensate Drain Operational:		NO		GFI 1 Status:		GREEN		Temperature
Alarm Indicator:		NO		GFI 2 Status:		GREEN		Filter Cleaned
Condenser Cleaned ² :		NO		Leachate Tank/Loadout				
Dew Point Indicator: N/A		Liquid Level (inches):		15.5 inches		Visual Check:		
 Indicate which bars are green(G) or red (R) and note (F) if flashing.		Contact WDNR if level is above		71 inches		Evidence of Tank Overflow: no		
		Leak Detection Test Completed:		NO		Inspect concrete pad and storm sewer for damage or backup		
		Overfill Float Functional ⁷		YES				
		Exhaust Stack						
		Drain Stack Sump (vol. removed)		NONE		Stack Condition ⁵ : GOOD		

1. Initial site conditions represents readings collected upon arrival to the site and initial field readings are collected prior to the landfill balancing.
2. Final site conditions represents readings collected upon departure from the site and final field readings are collected following the landfill balancing.
3. Check all air lines and gas extraction lines for leaks during each site visit. Drain inline air filters and replace as needed.
4. Air Dryer - Clean the condenser monthly using an air jet (max. 2 bar / 30 psig) inside out. Make sure not to damage the aluminum lamellae of the cooling package.
5. On a quarterly basis change the oil and check/clean the air filters and intercoolers for the air compressor.
6. Inspect mounting brackets and bolts for the air compressor and effluent stack for tightness.
7. Test overfill float operation on a monthly basis.

Comments/Notes:
 Air compressor and air dryer offline, leachate tank is @ 15.5"
 NA - Not Applicable
 NM - Not Measured

Data Entered By: J. Roelke 10/19/2022
 Checked By: B. Wachholz 11/19/2022

Monthly System Inspection Log
Landfill Gas Extraction and Leachate Pump System
WDNR - Refuse Highway Landfill
Middleton, Wisconsin


TRC Operator Name: John Roelke	Arrival Time: 9:14	Departure Time: 11:34
Date: 10/26/2022		

Site Conditions	Initial ¹	Final ²	Equipment	
Weather Conditions:	Cloudy		Gas/Instrument Type:	GEMS 2000
Ground Condition:	moist		Serial Number:	11668
Barometric Pressure:	30.35		Date Last Calibrated:	10/26/2022
Barometric Pressure Trend:	rising		Method:	Standard field calibration
Temperature:	38		Pressure Instrument:	GEMS 2000

Landfill Gas Extraction System ³							
System	Location	Tag #	Equipment Description	Set Point	Typical Range	Initial Field Reading ¹	Final Field Reading ²
Blower Motor	Remote	GHS-BLR-301	Amperage	-	3 - 4 amps	3.35	--
			Speed	-	1800 - 1900 rpm	1444.81	--
			Frequency	-	30 - 35 Hz	24.29	--
	HMI		Amperage	-	3 - 4 amps	3.3	--
			Speed	-		33	--
			Hours	-		6855	--

Blower Operating (YES). Note excessive noise or issues observed.

Blower Inlet	HMI	PT-301	Blower Inlet Vacuum	7 in. w.c.	7 in. w.c.	-7.0	-7
	HMI	TE-301	Blower Inlet Temperature	-	50 - 90 °F	55	--
	Local	GHS-PI-301	Blower Inlet Vacuum	7 in. w.c.	7 in. w.c.	-6.8	-6.9
	Local	GHS-TI-301	Blower Inlet Temperature	-	50 - 90 °F	50	54
	Local	Sample Port	Gas Composition - % Methane	-		8.3%	8.7%
			Gas Composition - % CO2	-		9.3%	8.8%
Gas Composition - % Oxygen			-		14.6%	14.7%	
Gas Composition - % Balance			-		67.8%	67.8%	
Demister	Local	GHS-PDI-301	Demister Differential Pressure	-	1-2 in w.c	1	--
	Local		Slight Glass: Liquid Present	-	-	none	--
	HMI	LS-701	Level Indication	-	-	--	--
Blower Outlet	HMI	PT-302	Blower Outlet Flow Pressure	-	-	0.1	0.1
	HMI	TE-302	Blower Outlet Temperature	-	50 - 90 °F	56	65
	HMI	PDT-301	Blower Outlet Flow Differential Pressure	-	1-2 in w.c	0.87	0.84
	HMI	-	Blower Outlet Flow Rate	-	180 - 190 scfm	138	135
	Local	GHS-PI-302	Blower Outlet Flow Pressure	-	-	0.13	--
	Local	GHS-TI-302	Blower Outlet Temperature	-	50 - 90 °F	54	62
	Local	Sample Port	Gas Composition - % Methane	-		8.2%	8.8%
			Gas Composition - % CO2	-		9.2%	8.7%
Gas Composition - % Oxygen			-		14.8%	14.7%	
Gas Composition - % Balance			-		67.8%	67.8%	
Branch Headers	Local	North	North Branch Vacuum	-	6 - 7 in w.c.	-5.90	-6.30
	Local	North	Valve Position	6 turns open /6	6 turns open	6	6
	Local	North Sample Port	Gas Composition - % Methane	-		19.4%	30.2%
			Gas Composition - % CO2	-		17.9%	19.3%
			Gas Composition - % Oxygen	-		6.9%	4.4%
			Gas Composition - % Balance	-		55.8%	46.1%
	Local	Central	Central Branch Vacuum	-	6 - 7 in w.c.	-5.7	-6.5
	Local	Central	Valve Position	-	6 turns open	6	6
	Local	Central Sample Port	Gas Composition - % Methane	-		5.8%	5.9%
			Gas Composition - % CO2	-		6.6%	5.6%
			Gas Composition - % Oxygen	-		16.6%	16.5%
			Gas Composition - % Balance	-		71.0%	72.0%
	Local	South	South Branch Vacuum	-	6 - 7 in w.c.	-5.80	-6.40
	Local	South	Valve Position	-	6 turns open	6	6
	Local	South Sample Port	Gas Composition - % Methane	-		9.8%	10.2%
			Gas Composition - % CO2	-		11.5%	11.2%
Gas Composition - % Oxygen			-		13.7%	13.5%	
Gas Composition - % Balance			-		65.0%	65.1%	

Air Compressor System ^{3,5,6} - AIR COMPRESSOR SYSTEM OFFLINE							
Operational Settings	Pressure Set Points				Condensate Set Points		
	Tank Low (psi)	Tank High (psi)	Well Field (psi)	On (min.)	Off (min.)	Open (sec.)	Closed (min.)
NOT OPERATING							
Air Dryer System⁴ - AIR DRYER OFFLINE		Electrical Status			HMI Heater/Air Conditioner		
System Operational:	NO	3-Phase Power Indicator:		3 of 3		Operational	
Condensate Drain Operational:	NO	GFI 1 Status:		GREEN		Temperature	
Alarm Indicator:	NO	GFI 2 Status:		GREEN		Filter Cleaned	
Condenser Cleaned ² :	NO	Leachate Tank/Loadout					
Dew Point Indicator: N/A		Liquid Level (inches):		19.75 inches		Visual Check:	
 Indicate which bars are green(G) or red (R) and note (F) if flashing.		Contact WDNR if level is above		71 inches		Evidence of Tank Overflow: no	
		Leak Detection Test Completed:		NO		Inspect concrete pad and storm sewer for damage or backup	
		Overfill Float Functional ⁷		YES			
		Exhaust Stack					
		Drain Stack Sump (vol. removed)		NONE		Stack Condition ⁶ : GOOD	

1. Initial site conditions represents readings collected upon arrival to the site and initial field readings are collected prior to the landfill balancing.
2. Final site conditions represents readings collected upon departure from the site and final field readings are collected following the landfill balancing.
3. Check all air lines and gas extraction lines for leaks during each site visit. Drain inline air filters and replace as needed.
4. Air Dryer - Clean the condenser monthly using an air jet (max. 2 bar / 30 psig) inside out. Make sure not to damage the aluminum lamellae of the cooling package.
5. On a quarterly basis change the oil and check/clean the air filters and intercoolers for the air compressor.
6. Inspect mounting brackets and bolts for the air compressor and effluent stack for tightness.
7. Test overfill float operation on a monthly basis.

Comments/Notes:
 Air compressor and air dryer offline.
 NA - Not Applicable
 NM - Not Measured

Data Entered By: J. Roelke 11/21/2022
 Checked By: T. Perkins 11/21/2022



October 2022 Cap Inspection

Cap Inspection			
Inspection Details		Site Conditions	
Inspector:	John Roelke	Weather Conditions:	Sunny
Date:	10/11/2022 & 10/20/2022	Ground Condition:	Dry
Time:	11:15	Temperature:	65 F
Note: Photograph all issues encountered during inspection			
Note: Keep vehicle traffic to gravel roadways, avoid driving on the landfill surface			
Is the landfill surface covered in snow (Y/N)? No			
Inspect the landfill surface when not covered in snow. Describe the condition and any issues observed for each category below:			
Cap integrity: Cap integrity is acceptable, with no changes from previous condition.			
Condition of drainage ways: West Drainage Ditch - the north portion shows signs of vegetation die-off, see Photo 1. During September's inspection standing water was observed. This area was identified as having less positive slope than its surroundings and regraded several times during 2020-2021 grading work at the Site. Final survey showed positive slope. East Drainage Ditch - TRC has continues to monitor the rip rap along west embankment of the northern culvert and riprap appears to be eroding, see photo 2. Following the September mowing event, soil was exposed at north portion of the drainage ditch, see Photo 3. Natural flow of the surface water is draining into the sediment pond. TRC reseeded select areas in both drainage ditches on October 20, 2022 to re-establish vegetation. The areas will be monitored for regrowth in Spring of 2023. Beyond the above noted issues, drainage ways are acceptable, with minimal to no changes from previous conditions.			
Extent of vegetation cover: Vegetation cover is acceptable over the majority of the Site. Some areas that were seeded post-construction in 2021 are not showing signs of growth, as shown in photos 4-6. Re-seeding was conducted by TRC on October 20, 2022 in select areas to re-establish vegetation. The areas will be monitored for regrowth in Spring of 2023. Burrowing was observed at gas extraction wells GW-2, GW-4, and GW-12, see photos 7-9. Larger holes were filled in with top soi during the October 20, 2022 reseeded event.			
Significant erosion: No evidence of significant erosion at the Site observed.			
Repeated erosion: No evidence repeated erosion at the Site observed.			
Vegetation die-off: <i>West Drainage Ditch</i> - The north portion shows signs of vegetation die off, see Photo 1. No standing water in this area during the inspection but vegetation regrowth was sparing indicating water may be ponding at times. <i>East Drainage Ditch</i> - Following the mowing event light erosion was observed along a north portion of the drainage ditch, see Photo 3. TRC will continue will reseed in the fall. TRC reseeded select areas in both drainage ditches on October 20, 2022 to re-establish vegetation. The areas will be monitored for regrowth in Spring of 2023.			
Maintain surface water conveyances and the sedimentation basin by completing the following:			
Inspect drainage ditches for erosion, blockages, and vegetation, describe and note any issues: <i>East Drainage Ditch</i> - Some light erosion to the north end of the north-to-south portion observed, see Photo 3. TRC reseeded the area on October 20, 2022 to re-establish vegetation. The areas will be monitored for regrowth in Spring of 2023.			
Inspect sedimentation basin banks and outfalls for erosion, describe and note any issues: No erosion or other issues at sedimentation basin banks and outfalls.			
Measure the distance between the invert of the sedimentation basin outlet and the top of the sediments accumulated in the basin (June Only): NM			



Data Entered By: J. Roelke 10/11/2022

Checked By: A. Stehn 11/18/2022



Photographic Log

Client Name: Wisconsin Department of Natural Resources (WDNR)		Site Location: Refuse Hideaway Landfill Middleton, WI	Project No.: TRC # 457573
Photo No. 1	Date 10/11/2022		
Description <u>Western Drainage Ditch:</u> North portion shows signs vegetation die off at the time of the inspection. During September's inspection standing water was observed. Surface water is flowing naturally towards the southernly riprap. TRC reseeded the area on October 20, 2022.			
Photo No. 2	Date 10/11/2022		
Description <u>Eastern Drainage Ditch:</u> Riprap has begun to deteriorate at the west side of the western culvert. Drainage is flowing and is not being obstructed.			

Photographic Log

Client Name:		Site Location:	Project No.:
Wisconsin Department of Natural Resources (WDNR)		Refuse Hideaway Landfill Middleton, WI	TRC # 457573
Photo No.	Date		
3	10/11/2022		
Description <u>Eastern Drainage Ditch:</u> After mowing operations bare soil was observed at the north portion of the drainage ditch. Drainage shows natural flowage of surface water into the sediment pond. TRC reseeded the area on October 20, 2022.			
Photo No.	Date		
4	10/11/2022		
Description <u>Northwestern Landfill Extents</u> Select areas that were seeded following the 2021 construction event contained bare soil. TRC reseeded the areas on October 20, 2022.			

Photographic Log

Client Name: Wisconsin Department of Natural Resources (WDNR)		Site Location: Refuse Hideaway Landfill Middleton, WI	Project No.: TRC # 457573
Photo No. 5	Date 10/11/2022		
Description <u>Northern Landfill Extents</u> Select areas that were seeded following the 2021 construction event contained bare soil. TRC reseeded the areas on October 20, 2022.			
Photo No. 6	Date 10/11/2022		
Description <u>Central Landfill Extents</u> Select areas that were seeded following the 2021 construction event contained bare soil. TRC reseeded the areas on October 20, 2022.			

Photographic Log

Client Name: Wisconsin Department of Natural Resources (WDNR)	Site Location: Refuse Hideaway Landfill Middleton, WI	Project No.: TRC # 457573
---	--	-------------------------------------




Photo No. 7	Date 10/11/2022	
<p>Description <u>Southern Landfill Extents:</u> Signs of burrowing at GW-2. No damage to the header pipe.</p> <p>Holes were filled in during the October 20, 2022 reseeding event.</p>		

Photo No. 8	Date 10/11/2022	
<p>Description <u>Southern Landfill Extents:</u> Signs of burrowing at GW-4. No damage to the header pipe.</p> <p>Holes were filled in during the October 20, 2022 reseeding event.</p>		

Photographic Log


Client Name: Wisconsin Department of Natural Resources (WDNR)		Site Location: Refuse Hideaway Landfill Middleton, WI	Project No.: TRC # 457573
Photo No. 9	Date 10/11/2022		
Description <u>Northern Landfill Extents:</u> Signs of burrowing at GW-12. No damage to the header pipe. Holes were filled in during the October 20, 2022 reseeding event.			

Gas Vent GV-4 Repair Field Notes

RHL Repairs - Daily Log

Refuse Hideaway, October 28, 2022

11/21/2022, 3:48:31 PM UTC



CREATED

🕒 10/28/2022, 2:28:33 PM UTC

👤 by Andrew Stehn

UPDATED

🕒 11/21/2022, 3:48:31 PM UTC

👤 by Andrew Stehn

STATUS

🟢 Complete

LOCATION

📍 43.097461, -89.579177

PROJECT

📁 No Project

ASSIGNED TO

👤 No Assignment

Work Date	October 28, 2022
Work Start Time	09:31
Project Name	RHL Source Control Systems Repair and Upgrades
TRC Project Manager Name	Andrew Stehn
Client Contact Name	Cynthia Koepke - WDNR
TRC Field Team Lead Name	Andrew Stehn
General Weather Conditions	Sunny and 40s
Daily Work Objective	Repair air line to GV-4
On-Site Personnel (Name - Company)	Andrew Stehn
On-Site Equipment (Name - Company)	

Weather (1 Item)

Weather - 1. 09:32

Date	October 28, 2022
Time	09:32
Tap to Add Weather Data	
Weather Summary	CONDITIONS: Clear, TEMPERATURE: 42.71 F, PRESSURE: 1020 hPa, RELATIVE HUMIDITY: 92 %, WIND SPEED: 1.99 MPH, WIND DIRECTION: 140 degrees

Health and Safety Tailgate

Health and safety tailgate conducted?	Yes
Tail Board Leader	Andrew astehn
Attendees	Kyle Maseruch, Connor Hunter. JR
Topics of H&S	Physical Hazards - Slip/Trips and Falls, Physical Hazards - Underground or Overhead Utilities, Physical Hazards - Fire/Explosion

Work Summary

Work Summary Entry (4 Items)

Work Summary Entry - 1. AS, 08:00

Time of Summary Entry	08:00
-----------------------	-------



Description of Activities	<p>Chris received a call from Kyle with JR that they were on-site to complete the air line repair at GV-4.</p> <p>Andy Stehn mob to site to let in JR. Andy called Timm with JR and Timm confirmed that the additional cost to replace the t-fitting would be between \$400 and \$500.</p> <p>Andy contacted Cindy with WDNR to provide an update on work being completed and that the cost to replace the t-fitting, in addition to the supply line to GV-4, would be between \$400 and \$500. Andy provided Cindy with an update on the electrical system and the compressor operation. TRC met with internal Electrical Engineers to discuss the issues at the site.</p> <p>Andy to follow up with Bryan Dahm about the air line repair.</p> <p>Andy called Bryan Dahm and left him a voicemail confirming the damaged air line was being repaired and that the additional cost to replaced the t-fitting would be between \$400 and \$500.</p>
Initials	AS

Work Summary Entry - 2. AS, 08:38

Time of Summary Entry	08:38
Description of Activities	Andy shutdown the blower and JR are working on repairing the airline.
Initials	AS

Work Summary Entry - 3. AS, 10:25

Time of Summary Entry	10:25
Description of Activities	<p>JR has installed two butt fusions. One to the existing supply line running east to west and one to the t fitting.</p> <p>Electro fuse joints were used to attached the supply line at the 90 degree bend and the two connections on the 1 inch service line.</p>
Initials	AS

Work Summary Entry - 4. AMS , 11:00

Time of Summary Entry	11:00
Description of Activities	<p>JR completed the air line repair and backfilling. See photos. TRC placed grass seed on disturbed area.</p> <p>JR offsite 1100</p> <p>Andy called Cindy and proved update to her that line was repaired.</p> <p>Andy restarted blower system and vac out to well field is 6 to 7 in wc. Flow around 148cfm</p>
Initials	AMS

Site Visitors



Construction Activity Photos

Photo Info (4 Items)

Photo Info - 1. 09:29, JR repairing the air line at GV-4

Photos



Photo Date	October 28, 2022
Photo Time	09:29
View Direction	
Description	JR repairing the air line at GV-4
Photographers Name	Andrew astehn

Photo Info - 2. 10:21, Supply line repairs complete.

Photos





Photo Date	October 28, 2022
Photo Time	10:21
View Direction	
Description	Supply line repairs complete.
Photographers Name	Andrew astehn

Photo Info - 3. 10:25, Electro fuse wells used for connecting the the 90 degree on the supply line and the two connections for the 1 inch line. See photo

Photos



Photo Date	October 28, 2022
Photo Time	10:25
View Direction	
Description	Electro fuse wells used for connecting the the 90 degree on the supply line and the two connections for the 1 inch line. See photo
Photographers Name	Andrew Stehn

Photo Info - 4. 11:07, Air line repairs and backfilled. TRC placed grass seed down after backfilling was complete.

Photos



Photo Date	October 28, 2022
Photo Time	11:07
View Direction	
Description	Air line repairs and backfilled. TRC placed grass seed down after backfilling was complete.
Photographers Name	Andrew astehn

End of Day Notes

Summary of Daily Activities	Repaired airline at GV-4
Next Day's Scope of Work	
Work End Date	October 28, 2022
Work End Time	11:30


TRC Field Team Lead Signature

Signed 10/28/2022, 9:13:15 PM UTC

Square D Transformer Product Data Sheet

Product data sheet

Specifications



Low voltage transformer, DOE 2016, dry type, 3 phase, 75kVA, 480V pri, 208Y/120 sec, Al, 150C rise, Type 2

EXN75T3H

Product availability : Stock - Normally stocked in distribution facility

Price* : 5,456.00 USD

Main

Range of Product	Square D
Product or Component Type	DOE 2016 energy efficient transformer
Device short name	DOE 2016
Transformer type	Energy efficient
Device Application	Low voltage electrical distribution

Complementary

Box number	20M
Phase	3 phase
Rated operational power in VA	75 kVA
Network Frequency	60 Hz
Type of cooling	Natural convection
Primary Voltage	480 V delta
Number of tap-offs	2 2.5 % FCAN 4 2.5 % FCBN
Primary operational current	90.21 A 208.18 A 75 kVA
Secondary voltage	208Y/120 V
Coil Material	Aluminium
Basic IMP level (BIL)	10 kV
Temperature Rise	150 °C 220 °C insulated
DOE Efficiency	98.63 % at 35 % load factor , 167 °F (75.0 °C)
Sound Level	3 dB NEMA ST-20 47 dB
%IZ	4.90 %
%IX	3.97 %
X/R Ratio	1.54
Inrush current	985 A
Let Through Current	3.71 kA
Transformer Losses	142 no load (core loss)

* Price is "List Price" and may be subject to a trade discount – check with your local distributor or retailer for actual price.

2226 load loss (coil loss)

Transformer BTU/HR	696 16.6 % 959 25 % 2383 50 % 4757 75 % 8080 100 %
Height	33.50 in (851 mm)
Depth	27.44 in (697 mm)
Width	30.08 in (764 mm)
Net Weight	515.00 lb(US) (233.60 kg)
Mounting support	Floor Floor, with 7400FMB Ceiling, with 7400CMB18M19M20M Wall, with 7400WMB18M19M20M
Degree of protection	UL type 2 UL type 3R, with 7400WS18M19M20M
Electrical connection	2 Hole Nema Pad primary 0.44 in (11.1 mm) 2 Hole Nema Pad secondary 0.44 in (11.1 mm) 4 Hole Nema Pad sec - XO 0.44 in (11.1 mm)
Number of mounting holes	0.51 in (13 mm)

Environment

Ambient air temperature for operation	104 °F (40 °C)
Average ambient air temperature for operation	30 °C
Standards	UL 1561 CSA C22.2 No 47 NEMA ST-20

Ordering and shipping details

Category	16256-3PH EXN/2016 15-150KVA LVGP XFMR
Discount Schedule	PE2X
GTIN	785901272687
Returnability	Yes
Country of origin	MX

Packing Units



Unit Type of Package 1	PCE
Package 1 Length	32.00 in (81.28 cm)
Number of Units in Package 1	1
Package 1 Width	35.00 in (88.9 cm)
Package 1 Height	38.50 in (97.79 cm)
Package 1 Weight	544.98 lb(US) (247.2 kg)

Offer Sustainability

Sustainable offer status	Green Premium product
California proposition 65	WARNING: This product can expose you to chemicals including: Phenyl Glycidyl Ether, which is known to the State of California to cause cancer and birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov
REACH Regulation	REACH Declaration
REACH free of SVHC	Yes
EU RoHS Directive	Compliant EU RoHS Declaration

Toxic heavy metal free	Yes
Mercury free	Yes
RoHS exemption information	Yes
China RoHS Regulation	China RoHS declaration Pro-active China RoHS declaration (out of China RoHS legal scope)
Environmental Disclosure	Product Environmental Profile
PVC free	Yes
Halogen content performance	Halogen free plastic parts product


Dimensions



EXN75T3H

in.
[mm]

ALL DIMENSIONS ARE APPROXIMATE.
 REFER TO TECHNICAL DRAWINGS AND
 DOCUMENTATION FOR COMPLETE INFORMATION.




Wiring Diagram

IN EACH PHASE CONNECT TO TAPS	
PRIMARY VOLTS	2-2.5% FCAN 4-2.5% FCBN
504	1
492	2
480	3
468	4
456	5
444	6
432	7

EXN75T3H

NOTE: ACTUAL VOLTAGES &
 NAMEPLATE VALUES MAY NOT
 MATCH VOLTAGE IN TABLE



REFER TO TECHNICAL DRAWINGS AND
 DOCUMENTATION FOR COMPLETE INFORMATION.