

**State of Wisconsin - Department of Natural Resources
Substance Release Notification Report (SERTS)
Report created on 11/20/2014**

SPILL ID# Z0140903NO44-1 BRK13# 04-44-062889

Incident Date & Time: 09/03/2014	Reported Date & Time: 09/03/2014 1404	BRRTS No: 04-44-562869	Spill ID: 20140903NO44-1
DATCP Reported? No DATCP Transferred? No	NFA Letter Sent? No	ERP Transferred? No	Incident Closed? Yes : 11/20/2014

Location			
Region: NO	County: Oneida	Municipality: RHINELANDER, CITY OF	
Facility/Property Name and Street Address: CITY OF RHINELANDER PROPERTY S RANCH RD		Description: NORTH END OF SOUTH RANCH RD	
Facility Type: Other			
Lat/Long:		PLSS:	WTM: X 560068 Y 572774
Weather Conditions:			

Responsible Parties			
Name/Address (1): MUNICIPAL WELL AND PUMP PO BOX 311 WAUPUN, WI 53963- (800) 383-7412 x Primary	Contact: PATRICK HARRINGTON PROJECT MANAGER (920) 960-8466 x primary	Other Contact:	Spill Packet:

Cause

Cause Type: VEHICLE FUEL TANK LEAK

Substances						
Name	Other / Comments	Amt Released	Amt Recovered	Type	Color	Odor
Diesel		EST 25.0 Gal	EST 25.0	LIQUID		

Environmental Impacts / Damages			
Environmental Impacts: SOIL	Resource Damages: No	Injuries: No	Evacuation: No

Cleanup Actions	
Method	Description
Excavation	

Cleanup Action Comments

Contractors Hired	
Name	Description
SAND CREEK CONSULTANTS	

Waste Destinations	
Location	Description
LINCOLN COUNTY LANDFILL	

**State of Wisconsin - Department of Natural Resources
Substance Release Notification Report (SERTS)
Report created on 11/20/2014**

SPILL ID# 20140903NO44-1 BRK1 S# 04-44-002009

Agencies Notified / On Scene				
Agency	Notified	On Scene		
DNR	X			
Additional Comments				
CHRIS ROG, SAND CREEK CONSULTANTS, CALLED SAGER AT ~1406HRS ON 9/3/14. MUNICIPAL WELL AND PUMP VEHICLE WAS PARKED OVERNIGHT. WHEN WORKERS RETURNED TO THE TRUCK ON 9/3/14 AT ~1200HRS THE DIESEL TANK ON THE TRUCK WAS LEAKING. BUCKETS WERE USED TO CAPTURE LEAKING DIESEL FUEL. SAND CREEK CONSULTANTS IS WORKING TO HAVE SOIL EXCAVATED BY THE END OF THE DAY ON 9/3/14. SOIL WILL BE STORED IN TRUCKS AT MUSSON BROTHERS, RHINELANDER, AND DISPOSED OF AT LINCOLN COUNTY LANDFILL ON 9/4/14. ROG WILL SEND SAGER AN UPDATE ON 9/4/14 OR SOONER IF SITUATION CHANGES. SAGER RECEIVED A STATUS UPDATE FROM SAND CREEK ON 9/5/14 SAGER RECEIVED A FINAL RESPONSE REPORT FROM SAND CREEK CONSULTANTS ON 11/20/2014.				
Enforcement Action/Citation				
Enforcement Action/Citation? No				
Case Activity Reports:				
Person Reporting				
Name	Representing / Address	Primary Phone	Secondary Phone	
CHRIS ROG	SAND CREEK CONSULTANTS	(715) 365-1818 x		
Contractors Hired				
Name / Address			Zone Contractor Hired by DNR?	
			No	
Contacts				
Role	Name	Office Phone	Date	Time
Prepared By:	JOHN SAGER	(715) 392-7822 x	09/03/2014	
Person Notified:	JOHN SAGER		09/03/2014	
Investigated By:	JOHN SAGER		09/03/2014	
Incident Commander:				
Spill Coordinator:	JOHN SAGER, NO Region	(715) 365-8959 x	11/20/2014	
Electronic Attachments (list)				
Name	Type			
20140903NO44-1_RP_Documentation_Status_Report.pdf	Portable Document Format			
20140903NO44-1_RP_Documentation_Response_Report.pdf	Portable Document Format			

Sager, John E - DNR

From: Christopher Rog <christopher.rog@sand-creek.com>
Sent: Thursday, November 20, 2014 11:02
To: Sager, John E - DNR
Subject: RE: Municipal Well and Pump spill SERTS ID 20140903NO44-1
Attachments: 2014.10.03 SCC Rhinelander MW&P_City Well 8 Final Report.pdf

Follow Up Flag: Follow up
Flag Status: Flagged

John
I'm sorry – I thought I sent this to you back on the day it was completed. But I checked my email and I can't seem to find that I sent it! So here it is. Have a good weekend!

Regards,

Christopher J. Rog, P.G. CPG, Sr. Project Manager, Principal
Sand Creek Consultants, Inc. | 108 E. Davenport St. | Rhinelander, WI 54501
main 715.365.1818 | direct 715.365.1828 | cell 715.360.1827 | fax 866.608.6473
www.sand-creek.com | christopher.rog@sand-creek.com

From: Sager, John E - DNR [<mailto:John.Sager@wisconsin.gov>]
Sent: Thursday, November 20, 2014 10:56 AM
To: Christopher Rog
Subject: Municipal Well and Pump spill SERTS ID 20140903NO44-1

Hi Chris,

I am trying to get some of my spill backlog cleared up. Is Sand Creek preparing a response report for the Municipal Well and Pump Spill? I know I received a status update from you but I do not see that I received a final report.

Thanks.

We are committed to service excellence.

Visit our survey at <http://dnr.wi.gov/customersurvey> to evaluate how I did.

John Sager

Hydrogeologist – Remediation and Redevelopment Program
Wisconsin Department of Natural Resources
1701 N. 4th St.
Superior, WI 54880
Phone: (715) 392-7822
Fax: (715) 392-7993
john.sager@wisconsin.gov

