

DATE: 4/19/19

FILE REF: 213551964

TO: Steve Martin – RR/Fitchburg

FROM: Jim Walden – RR/5

SUBJECT: Vapor Mitigation System (VMS) audit Klinke Cleaners Campus, 2875 University Ave.,
Madison

On April 3, 2019 I met Rich Klinke at the site to inspect the VMS. The system consists of two drops, one fan and an alarm. Upon arrival Rich told me that the fan was not working. At some point the alarm had triggered and an employee had unplugged the alarm without telling him. He plugged the alarm in and it immediately sounded. Rich will put a sign on the alarm telling employees to call him if the alarm ever sounds again and will have the fan replaced.

Recommendation: I asked Rich to inform Mike Schmoller when the fan had been replaced.