

A-1 Vacuum & Radon
2343 S Oneida St
Green Bay, WI 54304
+1 9204659333
info@a1vacuumcenter.com
a1vacuumcenter.com



INVOICE

BILL TO

Jagemann Plating Co Inc

INVOICE # 12830

DATE 06/29/2023

DUE DATE 06/29/2023

TERMS Due on receipt

ACTIVITY	QTY	RATE	AMOUNT
VOC Mitigation Inspection Annual Inspection of VOC Mitigation System is good working order at Jagemann Plating Co Inc. Mitigation system is moving air well and communicating with all ports. Port #1 0.083 Port #2 0.135 Port #3 0.130 Port #4 0.011	1	500.00	500.00
BALANCE DUE			\$500.00