

# Wastewater Discharge Monitoring Long Report

For DNR Use Only

Facility Name: MADISON KIPP CORPORATION  
 Contact Address: 708 Heartland Trail, Suite 3000  
 Madison, WI 53717  
 Facility Contact: Andrew Stehn, Project Engineer  
 Phone Number: 608-826-3665  
 Reporting Period: 02/01/2021 - 02/28/2021  
 Form Due Date: 03/21/2021  
 Permit Number: 0046566

Date Received:  
 DOC: 463272  
 FIN: 7960  
 FID: 113125320  
 Region: South Central Region  
 Permit Drafter: Drafter not set  
 Reviewer: David J Haas  
 Office: Green Bay

Sample Point	001	001	001
Description	Surface Water Discharge	Surface Water Discharge	Surface Water Discharge
Parameter	211	918	457
Description	Flow Rate	Potassium Permanganate	Suspended Solids, Total
Units	gpd	mg/L	mg/L
Sample Type	ESTIMATED	GRAB	GRAB
Frequency	DAILY	MONTHLY	PER OCCURANCE
Sample Results	Day 1	57600	
	2	57600	
	3	57600	
	4	57600	
	5	55883	
	6	57600	
	7	56760	
	8	29457	
	9	57600	
	10	57600	
	11	57600	
	12	57600	
	13	57600	
	14	57600	
	15	57600	
	16	57600	
	17	57600	
	18	57600	
	19	57600	
	20	57600	
	21	57600	
	22	57600	
	23	39440	
	24	33005	
	25	57600	
	26	57600	
	27	57600	
	28	57600	
	29		
	30		
	31		

	<b>Sample Point</b>	001	001	001
	<b>Description</b>	Surface Water Discharge	Surface Water Discharge	Surface Water Discharge
	<b>Parameter</b>	211	918	457
	<b>Description</b>	Flow Rate	Potassium Permanganate	Suspended Solids, Total
	<b>Units</b>	gpd	mg/L	mg/L
<b>Summary Values</b>	<b>Monthly Avg</b>	54976.607142857		
	<b>Daily Max</b>	57600		
	<b>Daily Min</b>	29457		
<b>Limit(s) in Effect</b>	<b>Daily Max</b>			40
<b>QA/QC Information</b>	<b>LOD</b>			
	<b>LOQ</b>			
	<b>QC Exceedance</b>	N	N	N
	<b>Lab Certification</b>			

Footnotes (DNR Use Only; Instructions for completing this form that are unique for your facility may be displayed here.)

General Remarks

Permanganate: Absent (Parameter visually monitored by MKC for neutralization and photo documentation can be provided upon request).

The GETS shutdown for a period of time on February 5,2021 due to a chemical fault alarm for the peroxide system. The pump was primed and the system was restarted.

The GETS shutdown for period of time between February 7,2021 and February 8, 2021 due to a chemical fault alarm for the peroxide system. The pump was primed and the system was restarted.

The GETS shutdown for period of time between February 23,2021 and February 24, 2021 due to a chemical fault alarm for the peroxide system. The pump was primed and the system was restarted.

Laboratory Quality Control Comments

Submitted by astehn on 03/16/2021 3:50:27 PM