

**State of Wisconsin - Department of Natural Resources
Substance Release Notification Report (SERTS)
Report created on 02/10/2014**

SPILL ID# 20130925NO16-1 BRRTS# 04-16-561650

Incident Date & Time: 09/25/2013 07:00	Reported Date & Time: 09/25/2013 09:03	BRRTS No: 04-16-561650	Spill ID: 20130925NO16-1
DATCP Reported? No DATCP Transferred? No	NFA Letter Sent? No	ERP Transferred? No	Incident Closed? Yes : 02/05/2014

Location		
Region: NO	County: Douglas	Municipality: SUPERIOR, CITY OF
Facility/Property Name and Street Address: ENBRIDGE ENERGY 2800 E 21ST ST		Description: LINE 61 TRAP
Facility Type: Bulk Petroleum Storage (Tank Farm/Terminal/Refinery)		
Lat/Long:	PLSS:	WTM:

Responsible Parties			
Name/Address (1): ENBRIDGE ENERGY 2800 E 21ST ST SUPERIOR, WI 54480-	Contact: TERRY PICTON COMPLIANCE COORDINATOR (715) 398-4779 x primary	Other Contact:	Spill Packet:

Cause
VAC TRUCK OVERFILL

Cause Type: Overfill (storage tank, vehicle or equipment)

Substances						
Name	Other / Comments	Amt Released	Amt Recovered	Type	Color	Odor
Crude Oil		EST 10.0 Gal	EST 10.0 Gal	LIQUID		

Environmental Impacts / Damages			
Environmental Impacts: SOIL	Resource Damages: No	Injuries: No	Evacuation: No

Cleanup Actions	
Method	Description
Vacuum	
Excavation	

Cleanup Action Comments
APPROXIMATELY 88 TONS SOIL EXCAVATED.

Contractors Hired	
Name	Description
OTHER	BARR ENGINEERING

Waste Destinations	
Location	Description
SHAMROCK LANDFILL	CLOQUET, MN

**State of Wisconsin - Department of Natural Resources
Substance Release Notification Report (SERTS)
Report created on 02/10/2014**

SPILL ID# 20130925NO16-1 BRRTS# 04-16-561650

Agencies Notified / On Scene				
Agency	Notified	On Scene		
DNR	X			
Additional Comments				
SAGER SPOKE TO TERRY PICTON, ENBRIDGE AT APPROXIMATELY 1445 HRS ON 9/25/13. THE SPILL WAS AT THE LINE 61 TRAP. THE SPILL WAS 5-10 GALLONS. ENBRIDGE IS RESPONDING TO THE SPILL. ENBRIDGE SUBMITTED FINAL RESPONSE REPORT ON 2/5/14.				
Enforcement Action/Citation				
Enforcement Action/Citation? No				
Case Activity Reports:				
Person Reporting				
Name	Representing / Address	Primary Phone	Secondary Phone	
TERRY PICTON	ENBRIDGE ENERGY	(715) 398-4779 x		
Contractors Hired				
Name / Address			Zone Contractor Hired by DNR?	
			No	
Contacts				
Role	Name	Office Phone	Date	Time
Prepared By:	JOHN SAGER	(715) 365-8959 x	02/05/2014	
Person Notified:	JOHN SAGER		09/25/2013	
Investigated By:	JOHN SAGER		09/25/2013	
Incident Commander:				
Spill Coordinator:	JOHN SAGER, NO Region	(715) 365-8959 x	02/05/2014	
Electronic Attachments (list)				
Name		Type		
20130925NO16-1_RP_Documentation_Response_Report.pdf		Portable Document Format		