

From: [Karl Beaster](#)
To: [Sager, John E - DNR](#)
Subject: Enbridge Energy Superior Terminal - Pump house 6 release
Date: Monday, November 18, 2013 13:36:19
Attachments: [Figure1_Pump_House_6_Valve_Release_Map.pdf](#)

John – please find attached map that shows in detail where the impacts were discovered that were reported to WDNR last week. The excavation is nearly complete and we have had Barr on-site field screening and collecting analytical samples as appropriate.

Please let me know if you need further information at this point. The source appears to be a weeping flange.

Regards,
Karl

Karl F. Beaster, PG
Environmental Analyst II, LP Environment

ENBRIDGE
TEL: 715-398-4754 | CELL: 715-718-1040
1320 Grand Ave, Superior, WI 54880
www.enbridgeUS.com

Integrity. Safety. Respect.

* * * * * IMPORTANT NOTICE * * * * *

Unless otherwise indicated or obvious from the nature of the transmittal, the information contained in this email message is CONFIDENTIAL information intended for the use of the individual or entity named herein. If the reader of this message is not the intended recipient, or the employee or agent responsible to deliver it to the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you have received this communication in error, please immediately notify the sender using the above contact information or by return email and delete this message and any copies from your computer system. Thank you.