

August 24, 2017

## SPILL REPORT

SITE LOCATION: MARINETTE MARINE

1600 ELY ST, MARINETTE, WI

DATE OF SPILL: 8/22/2017 @ 14:00

PROJECT: AFFF PUMPING FROM DOCKSIDE FRACK TANK

DNR SERTS#: 20170823NE38-1

CONDITIONS: SUNNY, BREEZY

## DESCRIPTION AND CAUSE:

The task was to pump AFFF material out of a frack tank, located dockside, near the NE corner of the property. During the pumping process, the foam which formed inside the vacuum tank during pumping, exited out of the vacuum exhaust port, while the truck was only partially full. The volume of foam, equating to @ 1 gallon of concentrate and water, breached the containment below the exhaust port of the truck and went onto the asphalt drive and some into the storm drain. The breezy conditions spread it over an @ 10' x 20' area.

## REMEDIAL ACTION:

Another vacuum tanker was used to vacuum out the drain and the surface of the drive / lot. No residual was found in the storm drain and no had left the storm drain. The surface of the lot was pressure washed and dried.

Questions related to the spill can be directed to me at 262-278-7840 you have any questions.

Respectfully,

Gary Schacht Regional Manager OSI Environmental

