Moll, John G - DNR (Gregory)

From: Moll, John G - DNR (Gregory)

Sent: Thursday, September 1, 2022 08:02

To: shane@roerscompanies.com

Cc: dpelczar@ksinghengineering.com; rreineke@ksinghengineering.com; Pfeiffer, Jane K -

DNR

Subject: Community Within The Corridor - East Block, BRRTS #07-41-590208 and #

02-41-263675

Dear Mr. LaFave,

I have reviewed your application for approval to build on an historic fill site, prepared on your behalf by K. Singh & Associates, in a document titled "Development at Historic Fill Site or Licensed Landfill Exemption Application," dated July 20, 2022. The following additional information is needed to complete the application review.

- 1. Page 2 of application Form 4400-226 was not signed and dated by the property owner. Please provide a new application form that is signed and dated.
- 2. A figure needs to be provided with your application to show where the proposed building activities (new asphalt and concrete pavement, parking garage ramp, and landscaped areas) are located.
- 3. A methane assessment needs to be provided to determine whether the historic fill material or underlying undisturbed soil has the potential to generate methane gas. If the methane assessment does not include sampling for methane gas, an explanation needs to be provided for why the historic fill material and underlying soil do not present a risk for methane gas generation.
- 4. A draft Cap Maintenance Plan needs to be provided to describe each type of protective barrier that will be used at the property. The draft Cap Maintenance Plan should include a figure indicating the location of each type protective barrier.

The requested information can be submitted by email to me at <u>john.moll@wisconsin.gov</u> and the project manager for the case, Jane Pfeiffer at <u>jane.pfeiffer@wisconsin.gov</u>. Please feel free to contact me if you have questions concerning the requested additional information.

Best Regards, Greg

We are committed to service excellence.

Visit our survey at http://dnr.wi.gov/customersurvey to evaluate how I did.

J. Gregory Moll, P.G.

Hydrogeologist - Remediation and Redevelopment Program Wisconsin Department of Natural Resources Southeast Region - Milwaukee Service Center 1027 W. St. Paul Ave.
Milwaukee, WI 53233

Phone: 262-202-3921 john.moll@wisconsin.gov

