



Northern Lake Service, Inc • 400 N Lake Ave • Crandon, WI 54520
800-278-1254 • www.nlslab.com

March 30, 2023

Mark Pauli
Wisconsin Department of Natural Resources
101 S Webster St
Madison, WI 53707

Project: 2023 Drinking Water Testing - Starks Expanded Area
Project Number: 2023 Drinking Water Testing
Work Order: CB02640
Received: 03/17/23

Enclosed are the results of analyses for samples received by our laboratory on 3/17/2023. If you have any questions concerning this report, please feel free to contact a client service representative at clientservices@nlslab.com.

Sincerely,

A handwritten signature in black ink that reads "Tom Priebe".

Tom Priebe For Client Services
Northern Lake Service, Inc.



Wisconsin Department of Natural Resources
101 S Webster St
Madison, WI 53707

Project: 2023 Drinking Water Testing - Starks Expanded Area
Project Number: 2023 Drinking Water Testing
Project Manager: Mark Pauli

Reported:
3/30/23 8:14

Work Order:
CB02640

Sample Summary

Descriptions of all qualifiers listed throughout this report can be found on the Qualifiers and Definitions Page.

Lab ID	Sample	Matrix	Sample Type	Qualifiers	Date Sampled	Date Received
CB02640-01	RF765	DW			3/17/23 13:40	3/17/23 14:30
CB02640-02	Field Blank	GW			3/17/23 0:00	3/17/23 14:30



Wisconsin Department of Natural Resources
101 S Webster St
Madison, WI 53707

Project: 2023 Drinking Water Testing - Starks Expanded Area
Project Number: 2023 Drinking Water Testing
Project Manager: Mark Pauli

Reported:
3/30/23 8:14

Work Order:
CB02640

Sample Results

Sample: RF765

CB02640-01 (DW) Sampled: 03/17/23 13:40

Analyte	Result	Qualifier	LOD	LOQ	MCL	Units	Date Prepared	Date Analyzed	Analyst	Method	Lab Cert Code
Semi-Volatiles											
11-chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	ND		0.31	1.0		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
9-chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	ND		0.34	1.1		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
4,8-dioxa-3H-perfluorononanoic acid (ADONA)	ND		0.37	1.2		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
hexafluoropropylene oxide dimer acid (HFPO DA)	ND		0.41	1.4		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND		0.47	1.6		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
n-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND		0.40	1.3		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
perfluorobutanesulfonic acid (PFBS)	ND		0.30	1.0		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
perfluorodecanoic acid (PFDA)	ND		0.33	1.1		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
perfluorododecanoic acid (PFDoA)	ND		0.23	0.77		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
perfluoroheptanoic acid (PFHpA)	0.57	J	0.44	1.5		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
perfluorohexanoic acid (PFHxA)	0.61	J	0.47	1.6		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
perfluorohexanesulfonic acid (PFHxS)	ND		0.34	1.1		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
perfluorononanoic acid (PFNA)	ND		0.46	1.5		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
perfluorooctanoic acid (PFOA)	1.3	J	0.49	1.6		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
perfluorooctanesulfonic acid (PFOS)	0.87	J	0.31	1.0		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
perfluorotetradecanoic acid (PFTA)	ND		0.34	1.1		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
perfluorotridecanoic acid (PFTrDA)	ND		0.43	1.4		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
perfluoroundecanoic acid (PFUnA)	ND		0.30	1.0		ng/L	3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) C13-PFHxA	97%		Limits: 70-130%				3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) C13-HFPODA	90%		Limits: 70-130%				3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) C13-PFDA	96%		Limits: 70-130%				3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) d5-NEtFOSAA	86%		Limits: 70-130%				3/20/23 6:51	3/22/23 18:58	RAW	EPA 537.1, Rev 2.0	2

Sample: Field Blank

CB02640-02 (GW) Sampled: 03/17/23 00:00

Analyte	Result	Qualifier	LOD	LOQ	MCL	Units	Date Prepared	Date Analyzed	Analyst	Method	Lab Cert Code
Semi-Volatiles											



Wisconsin Department of Natural Resources
101 S Webster St
Madison, WI 53707

Project: 2023 Drinking Water Testing - Starks Expanded Area
Project Number: 2023 Drinking Water Testing
Project Manager: Mark Pauli

Reported:
3/30/23 8:14

Work Order:
CB02640

Sample Results (Continued)

Sample: Field Blank (Continued)

CB02640-02 (GW) Sampled: 03/17/23 00:00

Analyte	Result	Qualifier	LOD	LOQ	Units	Date Prepared	Date Analyzed	Analyst	Method	Lab Cert Code
Semi-Volatiles (Continued)										
11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	ND		0.31	1.0	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
9-chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	ND		0.34	1.1	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
4,8-dioxa-3H-perfluorononanoic acid (ADONA)	ND		0.37	1.2	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
hexafluoropropylene oxide dimer acid (HFPO DA)	ND		0.41	1.4	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND		0.47	1.6	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
n-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND		0.40	1.3	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
perfluorobutanesulfonic acid (PFBS)	ND		0.30	1.0	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
perfluorodecanoic acid (PFDA)	ND		0.33	1.1	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
perfluorododecanoic acid (PFDoA)	ND		0.23	0.77	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
perfluoroheptanoic acid (PFHpA)	ND		0.44	1.5	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
perfluorohexanoic acid (PFHxA)	ND		0.47	1.6	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
perfluorohexanesulfonic acid (PFHxS)	ND		0.34	1.1	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
perfluorononanoic acid (PFNA)	ND		0.46	1.5	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
perfluorooctanoic acid (PFOA)	ND		0.49	1.6	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
perfluorooctanesulfonic acid (PFOS)	ND		0.31	1.0	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
perfluorotetradecanoic acid (PFTA)	ND	CCV%H	0.34	1.1	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
perfluorotridecanoic acid (PFTTrDA)	ND		0.43	1.4	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
perfluoroundecanoic acid (PFUnA)	ND		0.30	1.0	ng/L	3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) C13-PFHxA	93%		Limits: 70-130%			3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) C13-HFPODA	96%		Limits: 70-130%			3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) C13-PFDA	98%		Limits: 70-130%			3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) d5-NEtFOSAA	96%		Limits: 70-130%			3/24/23 6:37	3/26/23 15:50	RAW	EPA 537.1, Rev 2.0	2



Wisconsin Department of Natural Resources
101 S Webster St
Madison, WI 53707

Project: 2023 Drinking Water Testing - Starks Expanded Area
Project Number: 2023 Drinking Water Testing
Project Manager: Mark Pauli

Reported:
3/30/23 8:14

Work Order:
CB02640

List of Certifications

Code	Description	Number	Expires
2	NLS (Crandon) WDNR Laboratory ID No.	721026460	8/31/23



Wisconsin Department of Natural Resources
101 S Webster St
Madison, WI 53707

Project: 2023 Drinking Water Testing - Starks Expanded Area
Project Number: 2023 Drinking Water Testing
Project Manager: Mark Pauli

Reported:
3/30/23 8:14


Work Order:
CB02640

Qualifiers and Definitions

Item	Definition
CCV%H	The continuing calibration verification standard recovery was above QC limits at 145%.
J	Result is between LOD and LOQ and considered to be within a region of less-certain quantitation.
ND	Analyte NOT DETECTED at or above the LOD or MRL.
LOD	Limit of Detection.
LOQ	Limit of Quantitation.
NA	Not Applicable.
Dry	Dry Weight Basis.
Wet	Wet Weight Basis.
% Dry	Equal to: (mg/kg dry) / 10000.
1000 ug/L	Equal to: 1 mg/L.
MCL	Maximum Contaminant Levels for Drinking Water Samples. Shaded results indicate >MCL.
RPD	Relative Percent Difference.
%REC	Percent Recovery.
Source	Sample that was matrix spiked or duplicated.

All LOD/LOQs adjusted to reflect preparation volumes, dilutions, and/or solids content.

CB02640




SAMPLE COLLECTION AND CHAIN OF CUSTODY RECORD

Wisconsin Lab Cert. No. 721026460
WT DATCP 105-000330

CLIENT: **WISCONSIN DNR - DRINKING AND GROUNDWATER**
 ADDRESS: **PO BOX 7921, D6LS**
 CITY: **MAISON** STATE: **WI** ZIP: **53707**
 PROJECT DESCRIPTION / NO.: **PHAS PRIVATE WELLS** QUOTATION NO.
 DNR RID #: _____ DNR LICENSE # _____
 CONTACT: **MARK PAULI** PHONE: **715-499-0612**
 PURCHASE ORDER NO.: **000022899** FAX _____

MATRIX:
 SW = surface water
 WW = waste water
 GW = ground water
 DW = drinking water
 TIS = tissue
 AIR = air
 SOIL = soil
 SED = sediment
 PROD = product
 SL = sludge
 OTHER _____

ITEM NO.	ANALYSIS LABELING	SAMPLE ID	COLLECTION		MATRIX (See above)	NO.	COLLECTION REMARKS (ie. DNR Well ID #)
			DATE	TIME			
1.		RF765	3/17/23	13:40	GW		(2) SAMPLE (D) FB
2.							
3.							
4.							
5.							
6.							
7.							
8.							
9.							
10.							



COLLECTED BY (signature): *William Roberts* DATE/TIME: 13:140
 CUSTODY SEAL NO. (IF ANY): 3-17-23
 RELINQUISHED BY (signature): *William Roberts* RECEIVED BY (signature): _____ DATE/TIME: 14:130
 DISPATCHED BY (signature): _____ METHOD OF TRANSPORT: _____ DATE/TIME: _____

RECEIVED ANALYS BY (signature): *[Signature]* DATE/TIME: 03/17/23 14:30
 CONDITION: _____ TEMP: 6.4
 REMARKS & OTHER INFORMATION: _____
 WDNR FACILITY NUMBER: _____ E-MAIL ADDRESS: _____

REPORT TO: *2 of 3 Bottles labeled incorrectly RF765 - Corrected RF765 by
 INVOICE TO: GLJ 3/17/23
 [Signature] WFR

IMPORTANT!
 1. TO MEET REGULATORY REQUIREMENTS, THIS FORM MUST BE COMPLETED IN DETAIL AND INCLUDED IN THE COOLER CONTAINING THE SAMPLES DESCRIBED.
 2. PLEASE USE ONE LINE PER SAMPLE, NOT PER BOTTLE.
 3. RETURN THIS FORM WITH SAMPLES-CLIENT MAY KEEP PINK COPY.
 4. PARTIES COLLECTING SAMPLE, LISTED AS REPORT TO AND LISTED AS INVOICED TO AGREE TO STANDARD TERMS & CONDITIONS ON REVERSE.

483

1875

1875

1875

1875