

CLIENT INFORMATION

Client: Kate Easton
Requested On: Feb 18, 2023
Phone:
Email: kate.easton@wisconsinhistory.org

hello@gosimplelab.com

Route 130 North
Cinnaminson, New Jersey

TESTING PERFORMED

Testing Requested: PFAS Water Test
Matrix: Drinking Water
Testing / Report ID: 54DAVW

SAMPLE INFORMATION

Collection Date: Mar 12, 2023
Collected By: Kate Easton
Received Date: Mar 16, 2023
Reported On: Mar 30, 2023
Sample Location: Wellhead service
Sample Address: 4112 Cambria Point Rd., Rhinelander,
WI 54501, United States

TESTING NOTES

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact hello@gosimplelab.com

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	METHOD	EVALUATION
NEtFOSAA	µg/L	NOT DETECTED	0.00061	EPA 537.1	
NMeFOSAA	µg/L	NOT DETECTED	0.00076	EPA 537.1	
Perfluorobutanesulfonic acid	µg/L	0.0167	0.00081	EPA 537.1	< HGL
Perfluorodecanoic acid	µg/L	NOT DETECTED	0.00084	EPA 537.1	
Perfluorododecanoic acid	µg/L	NOT DETECTED	0.00104	EPA 537.1	
Perfluoroheptanoic acid	µg/L	0.38	0.00594	EPA 537.1	> HGL (0.02)
Perfluorohexanesulfonic acid	µg/L	NOT DETECTED	0.00064	EPA 537.1	
Perfluorohexanoic acid	µg/L	0.715	0.00517	EPA 537.1	< HGL
Perfluorononanoic acid	µg/L	NOT DETECTED	0.00092	EPA 537.1	
Perfluorooctanesulfonic acid	µg/L	NOT DETECTED	0.00102	EPA 537.1	
Perfluorooctanoic acid	µg/L	0.0678	0.00086	EPA 537.1	> HGL (0.002)
Perfluorotetradecanoic acid	µg/L	NOT DETECTED	0.00125	EPA 537.1	
Perfluorotridecanoic acid	µg/L	NOT DETECTED	0.00105	EPA 537.1	
Perfluoroundecanoic acid	µg/L	NOT DETECTED	0.00099	EPA 537.1	

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Health Guidance Level.

This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used

among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Simple Lab Recommendation.

This is a health protective, non-enforceable drinking water benchmark. SLR is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the SLR over the course of your lifetime is thought to be safe.

MQL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team configured to measure.



Did you know?

This Tap Score report is easier to understand when viewed online. Access in-depth information about every detection, including health risks and treatment solutions.

gosimplelab.com/signin