

Edler, Alex R - DNR

From: Edler, Alex R - DNR
Sent: Wednesday, August 31, 2016 12:00 PM
To: jasonp@metcohq.com
Cc: 'Ron Anderson, METCO - Environmental Division'; Klauk, Robert H - DNR; Edler, Alex R - DNR
Subject: 1404 S. Webster Ave (LUST) SI Workplan-notice to proceed #0305560082

Good morning Jason,

This email acts as my acknowledgement of receipt/notice to proceed with the August 22, 2016, Site Investigation Workplan, for the 1404 S. Webster Ave – LUST site, received by the DNR on August 29, 2016. All actions must comply with the ch. NR 700 rule series, Wis. Adm. Code, and all other applicable state statutes and administrative rules. This email does not represent a DNR approval.

To note:

- Not indicated are the proposed soil sample intervals.
- No indication of Vapor sampling, pending sampling results.
- The monitoring well (MW) locations to the North across Derby lane are a ways away from the proposed source area.
- MW-9 from the Knothole Bookstore site indicates an increasing trend for some PVOC's. If groundwater is effected a MW may be needed to east/northeast of the former pump island to provide plume definition.

SUMMARY OF GROUNDWATER ANALYSIS RESULTS

Parameter (ppb)	MW-9								DNR PAL	DNR ES
	06/23/98	10/01/01	09/12/02	12/11/02	03/26/03	06/11/03	09/16/04	12/16/04		
BENZENE	9.5	ND	3.6	ND	ND	ND	NA	NA	0.5	5
ETHYLBENZENE	350	600	49	700	780	880	NA	NA	140	700
NIPE	ND	24	9.3	23	48	43	NA	NA	12	60
NAFTHALENE	100	270	61	270	330	410	NA	NA	6	40
TOLUENE	47	16	3.4	14	13	31	NA	NA	200	1000
TRIMETHYLBENZENES	510	830	309	960	1070	1220	NA	NA	90	480
TOTAL XYLENES	2050	3440	1110	4330	4900	5500	NA	NA	1000	10000
TRICHLOROETHENE	43	NA	NA	NA	NA	NA	NA	NA	0.5	5
TETRACHLOROETHENE	870	NA	NA	NA	NA	NA	NA	NA	0.5	5
TOTAL LEAD	NA	NA	NA	NA	NA	NA	NA	NA	1.5	15

If you have any questions, please feel free to contact me.

Thanks,

We are committed to service excellence.

Visit our survey at <http://dnr.wi.gov/customersurvey> to evaluate how I did.

Alex Edler
Hydrogeologist
Wisconsin Department of Natural Resources
2984 Shawano Ave, Green Bay, WI 54313
Phone: (920) 662-5149
alex.edler@wisconsin.gov



dnr.wi.gov



NOTICE: This e-mail and any attachments may contain confidential information. Use and further disclosure of this information by the recipient must be consistent with applicable Wisconsin and federal laws, regulations and agreements. If you received this e-mail in error, please notify the sender; delete the e-mail; and do not use, disclose, or store the information it contains.