



Northern Lake Service, Inc • 400 N Lake Ave • Crandon, WI 54520
800-278-1254 • www.nlslab.com

April 06, 2023

Mark Pauli
Wisconsin Department of Natural Resources
101 S Webster St
Madison, WI 53707

Project: 2023 Drinking Water Testing - Starks Expanded Area
Project Number: PFAS Private Wells
Work Order: CB02667
Received: 03/20/23

Enclosed are the results of analyses for samples received by our laboratory on 3/20/2023. If you have any questions concerning this report, please feel free to contact a client service representative at clientservices@nlslab.com.

Sincerely,

A handwritten signature in black ink that reads "Tom Priebe".

Tom Priebe For Client Services
Northern Lake Service, Inc.



Wisconsin Department of Natural Resources
101 S Webster St
Madison, WI 53707

Project: 2023 Drinking Water Testing - Starks Expanded Area
Project Number: PFAS Private Wells
Project Manager: Mark Pauli

Reported:
4/6/23 14:42

Work Order:
CB02667

Sample Summary

Descriptions of all qualifiers listed throughout this report can be found on the Qualifiers and Definitions Page.

Lab ID	Sample	Matrix	Sample Type	Qualifiers	Date Sampled	Date Received
CB02667-01	QA067	DW			3/20/23 12:45	3/20/23 15:15
CB02667-02	Field Blank	DW			3/20/23 0:00	3/20/23 15:15



Wisconsin Department of Natural Resources
101 S Webster St
Madison, WI 53707

Project: 2023 Drinking Water Testing - Starks Expanded Area
Project Number: PFAS Private Wells
Project Manager: Mark Pauli

Reported:
4/6/23 14:42

Work Order:
CB02667

Sample Results

Sample: QA067

CB02667-01 (DW) Sampled: 03/20/23 12:45

Analyte	Result	Qualifier	LOD	LOQ	MCL	Units	Date Prepared	Date Analyzed	Analyst	Method	Lab Cert Code
Semi-Volatiles											
11-chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	ND		0.32	1.0		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
9-chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	ND		0.35	1.1		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
4,8-dioxa-3H-perfluorononanoic acid (ADONA)	ND		0.38	1.2		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
hexafluoropropylene oxide dimer acid (HFPO DA)	ND		0.42	1.4		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND		0.48	1.6		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
n-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND		0.41	1.3		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
perfluorobutanesulfonic acid (PFBS)	ND		0.31	1.0		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
perfluorodecanoic acid (PFDA)	ND		0.34	1.1		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
perfluorododecanoic acid (PFDoA)	ND		0.23	0.79		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
perfluoroheptanoic acid (PFHpA)	1.0	J	0.45	1.5		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
perfluorohexanoic acid (PFHxA)	1.0	J	0.48	1.6		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
perfluorohexanesulfonic acid (PFHxS)	ND		0.35	1.1		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
perfluorononanoic acid (PFNA)	0.81	J	0.47	1.5		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
perfluorooctanoic acid (PFOA)	2.7		0.50	1.6		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
perfluorooctanesulfonic acid (PFOS)	2.0		0.32	1.0		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
perfluorotetradecanoic acid (PFTA)	ND		0.35	1.1		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
perfluorotridecanoic acid (PFTrDA)	ND		0.44	1.4		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
perfluoroundecanoic acid (PFUnA)	ND		0.31	1.0		ng/L	3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) C13-PFHxA	97%		Limits: 70-130%				3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) C13-HFPODA	86%		Limits: 70-130%				3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) C13-PFDA	92%		Limits: 70-130%				3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) d5-NEtFOSAA	81%		Limits: 70-130%				3/27/23 5:15	3/27/23 18:04	RAW	EPA 537.1, Rev 2.0	2

Sample: Field Blank

CB02667-02 (DW) Sampled: 03/20/23 00:00

Analyte	Result	Qualifier	LOD	LOQ	MCL	Units	Date Prepared	Date Analyzed	Analyst	Method	Lab Cert Code
Semi-Volatiles											



Wisconsin Department of Natural Resources
101 S Webster St
Madison, WI 53707

Project: 2023 Drinking Water Testing - Starks Expanded Area
Project Number: PFAS Private Wells
Project Manager: Mark Pauli

Reported:
4/6/23 14:42

Work Order:
CB02667

Sample Results (Continued)

Sample: Field Blank (Continued)

CB02667-02 (DW) Sampled: 03/20/23 00:00

Analyte	Result	Qualifier	LOD	LOQ	MCL	Units	Date Prepared	Date Analyzed	Analyst	Method	Lab Cert Code
Semi-Volatiles (Continued)											
11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	ND		0.31	1.0		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
9-chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	ND		0.34	1.1		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
4,8-dioxa-3H-perfluorononanoic acid (ADONA)	ND		0.37	1.2		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
hexafluoropropylene oxide dimer acid (HFPO DA)	ND		0.41	1.4		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND		0.47	1.6		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
n-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND		0.40	1.3		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
perfluorobutanesulfonic acid (PFBS)	ND		0.30	1.0		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
perfluorodecanoic acid (PFDA)	ND		0.33	1.1		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
perfluorododecanoic acid (PFDoA)	ND		0.23	0.77		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
perfluoroheptanoic acid (PFHpA)	ND		0.44	1.5		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
perfluorohexanoic acid (PFHxA)	ND		0.47	1.6		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
perfluorohexanesulfonic acid (PFHxS)	ND		0.34	1.1		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
perfluorononanoic acid (PFNA)	ND		0.46	1.5		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
perfluorooctanoic acid (PFOA)	ND		0.49	1.6		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
perfluorooctanesulfonic acid (PFOS)	ND		0.31	1.0		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
perfluorotetradecanoic acid (PFTA)	ND		0.34	1.1		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
perfluorotridecanoic acid (PFTTrDA)	ND		0.43	1.4		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
perfluoroundecanoic acid (PFUnA)	ND		0.30	1.0		ng/L	3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) C13-PFHxA	86%		Limits: 70-130%				3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) C13-HFPODA	79%		Limits: 70-130%				3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) C13-PFDA	88%		Limits: 70-130%				3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURR) d5-NEtFOSAA	85%		Limits: 70-130%				3/30/23 8:19	3/31/23 10:59	RAW	EPA 537.1, Rev 2.0	2



Wisconsin Department of Natural Resources
101 S Webster St
Madison, WI 53707

Project: 2023 Drinking Water Testing - Starks Expanded Area
Project Number: PFAS Private Wells
Project Manager: Mark Pauli

Reported:
4/6/23 14:42

Work Order:
CB02667

List of Certifications

Code	Description	Number	Expires
2	NLS (Crandon) WDNR Laboratory ID No.	721026460	8/31/23



Wisconsin Department of Natural Resources
101 S Webster St
Madison, WI 53707

Project: 2023 Drinking Water Testing - Starks Expanded Area
Project Number: PFAS Private Wells
Project Manager: Mark Pauli

Reported:
4/6/23 14:42


Work Order:
CB02667

Qualifiers and Definitions

Item	Definition
J	Result is between LOD and LOQ and considered to be within a region of less-certain quantitation.
ND	Analyte NOT DETECTED at or above the LOD or MRL.
LOD	Limit of Detection.
LOQ	Limit of Quantitation.
NA	Not Applicable.
Dry	Dry Weight Basis.
Wet	Wet Weight Basis.
% Dry	Equal to: $(\text{mg/kg dry}) / 10000$.
1000 ug/L	Equal to: 1 mg/L.
MCL	Maximum Contaminant Levels for Drinking Water Samples. Shaded results indicate >MCL.
RPD	Relative Percent Difference.
%REC	Percent Recovery.
Source	Sample that was matrix spiked or duplicated.

All LOD/LOQs adjusted to reflect preparation volumes, dilutions, and/or solids content.

CB02667



SAMPLE COLLECTION AND CHAIN OF CUSTODY RECORD

Wisconsin Lab Cert. No. 721026460
WI DATCP 105-000330

CLIENT WISCONSIN DNR-DRINKING AND GROUNDWATER	
ADDRESS PO Box 7921, D665	STATE WI
CITY MADISON	ZIP 53707
PROJECT DESCRIPTION / NO. PPAS PRIVATE WELLS	
DNR FID #	DNR LICENSE #
CONTACT MARK PAULI	PHONE 765-499-0612
PURCHASE ORDER NO. 000022899	

USE BOXES BELOW: indicate Y or N if GW Sample is field filtered.
Indicate G or C if WW Sample is Grab or Composite.

SW = surface water	Y
WW = waste water	N
GW = groundwater	Y
DW = drinking water	N
TIS = tissue	N
AIR = air	N
SOIL = soil	N
SED = sediment	N
PROD = product	N
SL = sludge	N
OTHER	

ANALYZE PER ORDER OF ANALYSIS: **ERPMETHOD 5371**

NO.

ITEM NO.	MATRIX LABEL NO.	SAMPLE ID	DATE	TIME	MATRIX (See above)	COLLECTION	REMARKS (i.e. DNR Well ID #)
1.		QA067	3/20/23	12:45	GW		(P) sample / (M) FS
2.							
3.							
4.							
5.							
6.							
7.							
8.							
9.							
10.							

COLLECTED BY (signature): *William Roberts*

RECEIVED BY (signature): *William Roberts*

DISPATCHED BY (signature)

CUSTODY SEAL NO. (IF ANY): **3-20-23**

DATE/TIME: **12:45**

RECEIVED BY (signature): *William Roberts*

DATE/TIME: **15:15**

METHOD OF TRANSPORT

REPORT TO

INVOICE TO

RECEIVED AT NLS BY (signature): *William Roberts*

DATE/TIME: **03/20/23**

CONDITION: **0-2**

TEMP: **0-2**

REMARKS & OTHER INFORMATION

WDNR FACILITY NUMBER

E-MAIL ADDRESS

PRESERVATIVE:
N = nitric acid
Z = zinc acetate
M = methanol
S = sulfuric acid

COOLER #

OH = sodium hydroxide
HA = hydrochloric & ascorbic acid
HI = hydrochloric acid

IMPORTANT!

1. TO MEET REGULATORY REQUIREMENTS, THIS FORM MUST BE COMPLETED IN DETAIL AND INCLUDED IN THE COOLER CONTAINING THE SAMPLES DESCRIBED.
2. PLEASE USE ONE LINE PER SAMPLE, NOT PER BOTTLE.
3. RETURN THIS FORM WITH SAMPLES - CLIENT MAY KEEP PINK COPY.
4. PARTIES COLLECTING SAMPLE, LISTED AS REPORT TO AND LISTED AS INVOICED TO AGREE TO STANDARD TERMS & CONDITIONS ON REVERSE.