

WSLH Sample: 670611001

Report To:
 ANN WELLENS
 2200 SPRING DRIVE
 RHINELANDER, WI 54501

Invoice To:
 ANN WELLENS
 2200 SPRING DRIVE
 RHINELANDER, WI 54501
 Customer ID: 358149

Field #: VSC040722
 Project No:
 Collection End: 3/29/2023 2:45:00 PM
 Collection Start:
 Collected By: ANN WELLENS
 Date Received: 3/30/2023
 Date Reported: 4/21/2023
 Sample Reason:

ID#:
 Sample Location:
 Sample Description:
 Sample Type: PO-PRIVATE WELL
 Waterbody:
 Point or Outfall:
 Sample Depth:
 Program Code:
 Region Code:
 County:

PFAS in DW

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: 03/31/23 08:35		Analysis Date: 04/03/23 12:08			
PFBS (375-73-5)	EPA Method 537.1	<0.278	ng/L	0.278	0.928
PFHxA (307-24-4)	EPA Method 537.1	<0.396	ng/L	0.396	1.86
HFPO-DA (13252-13-6)	EPA Method 537.1	<0.409	ng/L	0.409	1.86
PFHpA (375-85-9)	EPA Method 537.1	<0.358	ng/L	0.358	1.86
PFHxS (355-46-4)	EPA Method 537.1	<0.256	ng/L	0.256	0.928
DONA (919005-14-4)	EPA Method 537.1	<0.381	ng/L	0.381	1.86
PFNA (375-95-1)	EPA Method 537.1	<0.375	ng/L	0.375	1.86
PFOS (1763-23-1)	EPA Method 537.1	<0.281	ng/L	0.281	0.928
9CI-PF3ONS (756426-58-1)	EPA Method 537.1	<0.282	ng/L	0.282	0.928
PFDA (335-76-2)	EPA Method 537.1	<0.404	ng/L	0.404	1.86
N-MeFOSAA (2355-31-9)	EPA Method 537.1	<0.286	ng/L	0.286	0.928
N-EtFOSAA (2991-50-6)	EPA Method 537.1	<0.276	ng/L	0.276	0.928
PFUnA (2058-94-8)	EPA Method 537.1	<0.387	ng/L	0.387	1.86
PFOA (335-67-1)	EPA Method 537.1	<0.387	ng/L	0.387	1.86

PFAS in DW

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: 03/31/23 08:35	Analysis Date: 04/03/23 12:08				
11CI-PF3OUdS (763051-92-9)	EPA Method 537.1	<0.271	ng/L	0.271	0.928
PFDoA (307-55-1)	EPA Method 537.1	<0.357	ng/L	0.357	1.86
PFTTrDA (72629-94-8)	EPA Method 537.1	<0.423	ng/L	0.423	1.86
PFTeDA (376-06-7)	EPA Method 537.1	<0.371	ng/L	0.371	1.86

WDNR LAB ID:113133790 NELAP LAB ID:2091 EPA LAB ID:WI00007, WI00008 WI DATCP ID:105-415

List of Abbreviations:

LOD = Level of detection

LOQ = Level of quantification (for PFAS the LOQ = MRL)

ND = None detected. Results are less than the LOD

F next to result = Result is between LOD and LOQ

Z next to result = Result is between 0 (zero) and LOD

if LOD=LOQ, Limits were not statistically derived

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/about/compliance/nelac-laboratory-accreditation>

Results, LOD and LOQ values have been adjusted for analytical dilutions and percent moisture where applicable.

Results relate only to the items tested.

This Laboratory Report shall not be reproduced except in full, without written approval of the laboratory.

The water microbiology unit analyzes samples as received and not all samples are tested for preservation before analysis is performed.

Responsible Party

Inorganic Chemistry: Graham Anderson, Supervisor 608-224-6281

Metals: Graham Anderson, Supervisor 608-224-6281

Organics: Erin Mani, Supervisor 608-224-6269

Environmental Toxicology: Dawn Perkins, Supervisor 608-224-6230

Water Microbiology: Martin Collins, Supervisor 608-224-6239

Radiochemistry: Jesse Wouters, Radiochemistry Supervisor 608-224-6227
