


Daily TCE Detection Log
Community Within the Corridor – East Block
2748 N. 32nd Street, Milwaukee, WI

| | |
|------------------------------|---|
| Date: | 08/30/2023 |
| Testing Performed by: | K. Singh & Associates, Inc., Ph: 262-821-1171 |
| Engineer on Site: | Sameer Neve, Ph.D., ENV SP |
| Signature: |  |

| No. | Location | Time | TCE Reading (ug/m ³) | >8.8 ug/m ³ |
|-----|------------------------|-----------|----------------------------------|------------------------|
| 1 | Unit 1045 | 8: 28 AM | 2.7 | - |
| 2 | N Mechanical Room | 8: 36 AM | 9.9 | Y |
| 3 | Unit 1050 | 8: 43 AM | <0.6 | - |
| 4 | Unit 1043 | 8: 51 AM | <0.6 | - |
| 5 | Calibration (100 ppbv) | 12: 55 PM | 97 ppbv | - |
| 6 | N Mechanical Room | 1: 03 PM | 8.04 | - |
| 7 | Basketball Court | 1:11 PM | 3.71 | - |
| 8 | Outside Unit 1051 | 1: 29 PM | 1.73 | - |
| 9 | Laundry Room | 1: 38 PM | 2.63 | - |
| 10 | | | | |
| 11 | | | | |
| 12 | | | | |
| 13 | | | | |
| 14 | | | | |
| 15 | | | | |

** Method Detection Limit = 0.6 µg/m³

** Note that Workplace Vapor Action Level is 8.8 µg/m³

** It is strongly recommended to wear a fit-tested respirator in the construction areas, and to wear appropriate Personal Protective Equipment at all times.

**For more information on TCE, please scan the QR Code or visit these links:

<https://www.dhs.wisconsin.gov/chemical/trichloroethylene.htm> and

<https://www.epa.gov/sites/default/files/2016-09/documents/trichloroethylene.pdf>

