



Northern Lake Service, Inc • 400 N Lake Ave • Crandon, WI 54520
800-278-1254 • www.nlslab.com

August 07, 2023

Greg Vandervest
Jelinek Well Drilling Inc
3480 County Hwy N
Rhineland, WI 54501

Project: 2023 PFAS Testing
Project Number: Roger Hamann - 4139 Camp Bryn Afon Rd - Stella
Work Order: CB08762
Received: 07/31/23

Enclosed are the results of analyses for samples received by our laboratory on 7/31/2023. If you have any questions concerning this report, please feel free to contact a client service representative at clientservices@nlslab.com.

Sincerely,

A handwritten signature in black ink, appearing to read "Tom Priebe".

Tom Priebe For Client Services
Northern Lake Service, Inc.



Jelinek Well Drilling Inc
3480 County Hwy N
Rhineland, WI 54501

Project: 2023 PFAS Testing
Project Number: Roger Hamann - 4139 Camp Bryn Afon Rd - Stella
Project Manager: Greg Vandervest

Reported:
8/7/23 11:09

Work Order:
CB08762

Sample Summary

Descriptions of all qualifiers listed throughout this report can be found on the Qualifiers and Definitions Page.

Lab ID	Sample	Matrix	Sample Type	Qualifiers	Date Sampled	Date Received
CB08762-01	Drinking Water	DW			7/31/23 9:34	7/31/23 11:15

Analysis Qualifiers:

LabNumber	Analysis	Qualifier
CB08762-01	537.1 Perfluorinated Chemicals by LC/MS/MS	FBNA1



Jelinek Well Drilling Inc
3480 County Hwy N
Rhineland, WI 54501

Project: 2023 PFAS Testing
Project Number: Roger Hamann - 4139 Camp Bryn Afon Rd - Stella
Project Manager: Greg Vandervest

Reported:
8/7/23 11:09

Work Order:
CB08762

Sample Results

Sample: Drinking Water
CB08762-01 (DW) Sampled: 07/31/23 09:34

Analyte	Result	Qualifier	LOD	LOQ	MCL	Units	Date Prepared	Date Analyzed	Analyst	Method	Lab Cert Code
Semi-Volatiles											
11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	ND		0.32	1.0		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
9-chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	ND		0.35	1.1		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
4,8-dioxa-3H-perfluorononanoic acid (ADONA)	ND		0.38	1.2		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
hexafluoropropylene oxide dimer acid (HFPO DA)	ND		0.42	1.4		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND		0.48	1.6		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
n-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND		0.41	1.3		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
perfluorobutanesulfonic acid (PFBS)	ND		0.31	1.0		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
perfluorodecanoic acid (PFDA)	ND		0.34	1.1		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
perfluorododecanoic acid (PFDoA)	ND		0.23	0.79		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
perfluoroheptanoic acid (PFHpA)	ND		0.45	1.5		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
perfluorohexanoic acid (PFHxA)	ND		0.48	1.6		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
perfluorohexanesulfonic acid (PFHxS)	ND		0.35	1.1		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
perfluorononanoic acid (PFNA)	ND		0.47	1.5		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
perfluorooctanoic acid (PFOA)	ND		0.50	1.6		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
perfluorooctanesulfonic acid (PFOS)	ND		0.32	1.0		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
perfluorotetradecanoic acid (PFTA)	ND		0.35	1.1		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
perfluorotridecanoic acid (PFTrDA)	ND		0.44	1.4		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
perfluoroundecanoic acid (PFUnA)	ND		0.31	1.0		ng/L	8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURRE) C13-PFHxA	85%		Limits: 70-130%				8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURRE) C13-HFPODA	80%		Limits: 70-130%				8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURRE) C13-PFDA	79%		Limits: 70-130%				8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2
Surrogate: (SURRE) d5-NEtFOSAA	71%		Limits: 70-130%				8/2/23 8:50	8/3/23 11:20	RAW	EPA 537.1, Rev 2.0	2



Jelinek Well Drilling Inc
3480 County Hwy N
Rhineland, WI 54501

Project: 2023 PFAS Testing
Project Number: Roger Hamann - 4139 Camp Bryn Afon Rd - Stella
Project Manager: Greg Vandervest

Reported:
8/7/23 11:09

Work Order:
CB08762

List of Certifications

Code	Description	Number	Expires
2	NLS (Crandon) WDNR Laboratory ID No.	721026460	8/31/23



Jelinek Well Drilling Inc
3480 County Hwy N
Rhineland, WI 54501

Project: 2023 PFAS Testing
Project Number: Roger Hamann - 4139 Camp Bryn Afon Rd - Stella
Project Manager: Greg Vandervest

Reported:
8/7/23 11:09


Work Order:
CB08762

Qualifiers and Definitions

Item	Definition
FBNA1	The field sample had no detects at or greater than 2.0 ng/L, per the WDNR the corresponding field reagent blank was not required to be analyzed.
ND	Analyte NOT DETECTED at or above the LOD or MRL.
LOD	Limit of Detection.
LOQ	Limit of Quantitation.
NA	Not Applicable.
Dry	Dry Weight Basis.
Wet	Wet Weight Basis.
% Dry	Equal to: (mg/kg dry) / 10000.
1000 ug/L	Equal to: 1 mg/L.
MCL	Maximum Contaminant Levels for Drinking Water Samples. Shaded results indicate >MCL.
RPD	Relative Percent Difference.
%REC	Percent Recovery.
Source	Sample that was matrix spiked or duplicated.

All LOD/LOQs adjusted to reflect preparation volumes, dilutions, and/or solids content.

CB08762



PFAS by EPA Method 537.1 Test Kit
18 PFAS compounds

Return your sample as soon as possible to one of our two locations.

Northern Lake Service
400 N Lake Ave
Crandon, WI 54520

OR

Northern Lake Service
2420 N Grandview Blvd
Waukesha, WI 53188

Please provide the following information:

-Customer ↓

Name: Roger Hamann

Address: 4139 Camp Bryn Afon Rd - Stella

City/State/Zip: 1786 Chateau Dr, Green Bay, WI 54304

Phone: 920-246-9248 Email: info@drillforwater.com

Sample Collection Date: 7/31 Sample Collection Time: 9:32/9:59 AM/PM

Sample Collection Location (ex. Pressure Tank) _____

Sample Collected By: Greg Vandervest

Report by email only Report by mail only Report by email and mail

Per EPA 537.1, each sample set **must be accompanied by a field blank. The purpose of the field blank is to allow for the identification of potential contamination during sample collection and handling. If you choose not to have the field blank analyzed, the PFAS data may be viewed as a screening and may not be suitable for compliance use.

*Please send results to:
and bill*

Please initial in **ONE** of the check boxes below that apply:

Cost for PFAS Kit Without Field Blank - \$367.50

OR

Cost for PFAS Kit Including Field Blank - \$552.50

Jelinek Well Drilling, Inc.
3480 Cty Hwy N
Rhineland, WI 54501

info@drillforwater.com
715-282-7400

Your credit card will be charged according to the option you have chosen above

Pam Pam 7/31/13 11:15
onice 40



Jelinek Well Drilling Inc

CLIENT: Sarah Schroeder
3480 County Hwy N
Rhineland, WI 54501
715-282-7400
No field blanks

Cust #: 15370
Order #: 109008
Ship Date: 04/14/2023
Type: DW

Sample ID: Drinking Water

2 SETS

PFAS Compounds by EPA Method 537.1 Without Field Blank (18 compounds included in analysis) \$367.50
2 x 250mL Nalgene bottles with Trizma Preservative

Shipped and Completed by: _____