04-21-177536

PLEASE PRINT

State of Wisconsin Substance Release Notification Form

24-Hour Emergency Hotline Number: 1-800-943-0003 — Form 4400-91 Rev. 11-95

Date and Mil. Time of Incident	Date and Mil. Time Reported
7/25/97 ~11:00	7/25/97 11:00

Person Reporting: Annonymous Employee	Telephone # ( )
Representing Agency, Firm, or Citizen: American Can Employee	
Responsible Party: American National Can Company	
Contact Name: David Ellison, Mgr. Env. Eng.	Telephone # (414) 727-6027
Address: 2301 Industrial Drive, P.O. Box 702	City, State, Zip Code: Neenah, WI 54957-0702

Substance Involved	Amount & Units Released	Amt. Recovered	Is this a 304 (11004 42 USC) spill?
Propane	Unknown	None	☐ Yes ☐ No ☐ Unknown

☐ Solid ☐ Semisolid ☐ Liquid ☒ Gas Color NONE Odor Natural Gas

Exact Location (inc. address, facility name, mileage, bldg. #, etc.) ~~2301 Industrial Drive~~ 1815 Marathon Avenue

City	County	Lat/long
Neenah	Winnebago	
DNR Region: NE	¼ ¼sec T NR (E/W)	Weather Cond.

Cause of Incident: The facility maintains a large propane supply on hand in case their supply is interrupted. They have an underground line outside from this tank to a building where they vaporize the propane into the air to make natural gas. This underground pipe was leaking. The leaking caused a mound in the ground to form (~ 1' high, 6' dia). (over)

Spilled Substance Impact To: Check (✓) all that apply
- ☒ Air ☐ Potential
- ☒ Soil ☐ Potential
- ☒ Groundwater ☒ Potential
- ☒ Surface Water ☒ Potential
  - Name: Neenah Slough
- ☒ Storm Sewer ☒ Potential
- ☐ Sanitary Sewer ☐ Potential
- ☐ Concrete/Asphalt ☐ Potential
- ☐ Private Well ☐ Potential
- ☐ Contained/Recovered
- ☐ Other:

Spill Source:
- ☐ Transportation Accident, Fuel Supply Tank Spill
- ☐ Transportation Accident, Load Spill
- ☒ Industrial Facility ☐ Paper Mill ☐ Chemical Co.
- ☐ Ag Coop/Facility/Food Factory/Facility
- ☐ Gas/Service Station/Garage/Auto Dealer, Repair Shop
- ☐ Pipeline, Terminal, Tank Farm, Oil Jobber/Wholesaler
- ☐ Public Property (city, state, church, school, etc.)
- ☐ Utility Co., Power Generating/Transfer Facility
- ☐ Private Property (home/farm)
- ☐ Construction, Excavation, Wrecking, Quarry, Mine
- ☐ Airport Facility ☐ Railroad Facility
- ☐ Other

Action Taken By Spiller
- ☐ No Action Taken
- ☐ No Action Needed
- ☐ Monitor
- ☒ Cleanup Method: Propane drained
- ☐ Waste Destination:
- ☐ Containment
- ☒ Contractor Hired
  - Name: W.W. Energies
- ☐ Other:

Injuries? ☐ Yes ☒ No If yes, how many? ____ | Has an evacuation occurred? ☐ Yes ☒ No Potential? ☒ Yes ☐ No

Are there any resource damages? ☐ Yes ☐ No What kinds? Unknown

Other Agencies Notified (✓ first column if notified); Check (✓) both columns if on scene

☒☒ Fire Department/Hazmat	☐☐ Local DNR	☐☐ EPA
☐☐ Local Law Enforcement	☐☐ Div. Emer. Gov.	☐☐ Nat'l Resp. Ctr. 800-442-8802
☐☐ LEPC or Local Emer. Gov.	☐☐ DATCP 608-224-4500	☐☐ Chemtrec 800-424-9300
☐☐ Regional Response Team	☐☐ DHSS 608-266-2830	☐☐ Other

Incident Commander, if known: ____ Phone: ____

Prepared By: (Print) Michael O. Ref	(Sign) Michael O. Ref	Date: 8/1/97	Rpt'd to DATCP? ☐Yes ☐No
Person Notified: Michael O. Ref	Region Notified: NER	Time: 11:00	Date: 7-25-97
Invstgtd By: (Print) Michael O. Ref	(Sign) Michael O. Ref	Date: 8/1/97	Site Closed? ☒Yes ☐No
Spill Coordinator Signoff:	Date: 11-10-97	Transferred to ERP? ☒No ☐Yes; Case #	NFA Letter Sent? ☐Yes ☒No
			Spill Packet Sent? ☐Yes ☒No

04-11-1736

PLEASE PRIN

State of Wisconsin Substance Release Report (Con't)
Form 4400-91 Rev. 11-95

Date and Military Time of Incident 7/25/97 ~11:00	Responsible Party American National Can Co.

Additional Comments:

The mound was caused by propane trapped underground. The grass in the mound was dead (probably from propane). The smell of natural gas was strong. The fire department was there (7/24/97) and told facility it was ok to wait until a repair company could fix the leak. The company (Amer.Can) taped off the area. The repair company said they were booked-up and would get there as soon as they could. I investigated at 14:00 on 7/25/97. Tom Knudstrope and David Ellison of American Can accompanied me. The mound was immediately next to the facility open storm sewer outfall. I considered this too great an environmental and human hazard to leave for next week. I expressed these concerns. Tom Knudstrope & David Ellison said the contacted the repair company before I got there and were moved up on the priority list. They said the repair company would be there shortly. Tom Knudstrope called me and left a message that the repair company was there on the afternoon of 7/25 and drained and sealed the line so it was safe. He said they would now dig up the line and replace it.

DEJ