Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8BL289

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ELDOR SCHULT	Phone #
Mailing Address: W6303 WOOD AVE.	
City: MERRILL	State: WI / Zip Code
County: Lincoln	Co. Permit # / Notification # / Completed: 10-28-1987

1. Well Location

Town of SCOTT	Fire # (if avail.): W6303
Street Address or Road Name and Number: WOOD AVE.	
Subdivision Name / Lot # / Block #	
Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code
NE NW or Govt Lot # / Section: 33 / Township: 31 N / Range: 6 E	

Well Constructor (Business Name): ROGER D. LANG - LANG WELL DRILLING CO.	Lic. #	Facility ID # (Public Wells)
Address		Well Plan Approval # / Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.3

2. Well Type

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

3. Well serves # of Farm

Private,potable

Heat Exchange____# of drillholes

Hicap Well ?

Hicap Property ?

Hicap Potable ?

Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	15
8	15	40
6	40	128

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	Clay, Gravel & Boulders	Surface	13
K		Q		Black Granite	13	105
R		Q		Red & White Granite	105	128

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	Plain End Steel Pipe 6.625 x .280 Wall ASTM A53 Grade B Tested 1780# PSI Sumitomo Metal Ind.	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

25 ft. _____ ground surface

10. Pump Test

Pumping level 125 ft. below surface

Pumping at 30 GP for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ?

Disinfected ?

Capped ?

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Neat Cement	Surface	40	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: