Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8BL386

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: EDWARD FARRAR | Phone #:

Mailing Address: 1301 ASHLAND AVENUE

City: CHICAGO HEIGHTS | State: IL | Zip Code:

County	Co. Permit #	Notification #	Completed
Lincoln			05-08-1981

Well Constructor (Business Name): ALAN LANG - ALAN LANG WELL & PUMP, INC. | Lic. #: | Facility ID # (Public Wells):

Address:

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well # | Common Well # | Specific Capacity: 2.5

3. Well serves # of Home

Private,potable

Heat Exchange____# of drillholes

Hicap Well ?

Hicap Property ?

Hicap Potable ?

1. Well Location

Town of MERRILL

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #
RIVER BEND HEIGHTS	11	

Latitude / Longitude in Decimal Degree (DD): °N °W | Method Code

SE or Govt Lot #	Section	Township	Range
	30	32 N	6 E

2. Well Type

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	42.583

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Sand & Gravel	Surface	42.583

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	New Black Standard Steel 19.45# ASTM A53 Grade B Mfg. LaBarge, Inc. Threaded & Coupled	Surface	39.583
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

13 ft. _____ ground surface

10. Pump Test

Pumping level 19 ft. below surface

Pumping at 15 GP for 1 Hrs.

Pumping Method ?

11. Well Is

30 in. above grade

Developed ?

Disinfected ?

Capped ?

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: