

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BL386		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner EDWARD FARRAR						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 1301 ASHLAND AVENUE								Town of MERRILL									
City CHICAGO HEIGHTS						State IL		Zip Code									
County Lincoln		Co. Permit #		Notification #		Completed 05-08-1981		Subdivision Name RIVER BEND HEIGHTS				Lot # 11					
Well Constructor (Business Name) ALAN LANG - ALAN LANG WELL & PUMP, INC.						Lic. #		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)					
Address						Well Plan Approval #		°N °W				Method Code					
								SE Section Township Range or Govt Lot # 30 32 N 6 E									
Approval Date (mm-dd-yyyy)								2. Well Type									
Hicap Permanent Well #						Common Well #		Specific Capacity				of previous unique well # constructed in					
3. Well serves # of Home						Hicap Well ?		Reason for replaced or reconstructed well ?									
Private, potable						Hicap Property ?											
Heat Exchange ___ # of drillholes						Hicap Potable ?		Construction Type									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		42.583		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Y		Sand & Gravel		Surface		42.583	
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		13 ft. _____ ground surface		30 in. above grade					
6		New Black Standard Steel 19.45# ASTM A53 Grade B Mfg. LaBarge, Inc. Threaded & Coupled				Surface		39.583		10. Pump Test		Developed ?					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 19 ft. below surface		Disinfected ?					
										Pumping at 15 GP for 1 Hrs.		Capped ?					
										Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method												Filled & Sealed Well(s) as needed?					
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 06-30-2022

Review Status: