Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8BL411

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TYLENDA - GALKIN REALTY			Phone #
Mailing Address: P.O. BOX 135			
City: GLEASON	State: WI	Zip Code	
County: Lincoln	Co. Permit #	Notification #	Completed: 08-13-1981

Well Constructor (Business Name): ALAN F. LANG - ALAN LANG WELL & PUMP, INC.	Lic. #	Facility ID # (Public Wells)	
Address		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0	

3. Well serves # of Home
Private,potable
Heat Exchange____# of drillholes

Hicap Well ?
Hicap Property ?
Hicap Potable ?

1. Well Location
Town of MERRILL

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name		Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code

SE or Govt Lot #	Section: 5	Township: 32 N	Range: 7 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	182

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y	Z	Sand & Gravel & Boulders	Surface	25
		Z		Clay & Gravel	25	79.5
		Y		Sand & Gravel	79.5	85
		Z		Clay & Gravel	85	102
		Y	C	Sand & Gravel & Clay	102	172
	D	Q		Decomposed Granite	172	182
G		Q		Grey Granite	182	192

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	New Black Standard Steel 19.45# ASTM A53 Grade B Mfg. LaBarge, Inc.	Surface	182
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

9. Static Water Level
60 ft. _____ ground surface

10. Pump Test
Pumping level 192 ft. below surface
Pumping at 4 GP for 1 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ?
Disinfected ?
Capped ?

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: