

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BL438		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner RICHARD KRAUSE						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address RFD 5								Town of MERRILL					
City MERRILL						State WI		Zip Code					
County Lincoln		Co. Permit #		Notification #		Completed 07-16-1980		Subdivision Name				Lot #	
												Block #	
Well Constructor (Business Name) ALAN F. LANG - ALAN LANG WELL & PUMP, INC.				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code	
								°N		°W			
						Well Plan Approval #		E SW		Section 34		Township 32 N	
Address						Approval Date (mm-dd-yyyy)		or Govt Lot #				Range 7 E	
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type					
								of previous unique well #					
								Reason for replaced or reconstructed well ?					
3. Well serves # of Home				Hicap Well ?				Construction Type					
Private, potable				Hicap Property ?									
Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
10 Surface 20			Rotary - Mud Circulation										
8 20 43			Rotary - Air										
6 43 102			Rotary - Air & Foam										
			Drill-Through Casing Hammer										
			Reverse Rotary										
			Cable-tool Bit ___ in. dia...										
			Dual Rotary										
			Temp. Outer Casing ___ in. dia										
			Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)				
X G			Sandy Clay & Gravel						Surface 25				
D Q			Decomposed Granite						25 43				
G Q			Gray Granite						43 102				
6. Casing, Liner, Screen													
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)						
6			Plain End New Black Steel 18.97# ASTM A53 Grade B Mfg. LaBarge, Inc.				Surface 43						
Dia. (in.)			Screen type, material & slot size				From (ft.) To (ft.)						
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material			From (ft.) To (ft.)		# Sacks Cement								
Neat Cement			Surface 43										
9. Static Water Level													
35 ft. _____ ground surface													
10. Pump Test													
Pumping level 102 ft. below surface													
Pumping at 8 GP for 1 Hrs.													
Pumping Method ?													
11. Well Is													
30 in. above grade													
Developed ?													
Disinfected ?													
Capped ?													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller													
Lic #			Date Signed										
Drill Rig Operator			Lic or Reg #						Date Signed				

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 06-30-2022

Review Status: