Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8BL444

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DUANE CORDER C/O TYLENDA-GALKIN REALTY		Phone #	
Mailing Address: P. O. BOX 87			
City: GLEASON	State: WI	Zip Code	
County: Lincoln	Co. Permit #	Notification #	Completed: 05-06-1985

Well Constructor (Business Name): ROGER D. LANG - LANG WELL DRILLING COMPANY	Lic. #	Facility ID # (Public Wells)	
Address		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.3	

3. Well serves # of Home
Private,potable
Heat Exchange____# of drillholes

Hicap Well ?
Hicap Property ?
Hicap Potable ?

1. Well Location
Town of SCHLEY

Fire # (if avail.)

Street Address or Road Name and Number: STH 17

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code
SW SW or Govt Lot #	Section: 7	Township: 32 N	Range: 8 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	83

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	A	Y	Z	Sand, Coarse Gravel, Boulders	Surface	25
	A	Z		Coarse Gravel & Clay	25	37
	A	G	Z	Coarse Gravel & Boulders	37	41
G		Q		Gray Granite	41	55
R		Q		Red & Gray Granite Mix	55	83

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	Steel Pipe 6.625 x .280 19.45#/ft. ASTM A120 Hydro-Tested 1200 psi Threaded & Coupled	Surface	41
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
6 ft. _____ ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 20 GP for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ?
Disinfected ?
Capped ?

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: