

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BL450		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner JERALD DULEY					Phone #			1. Well Location				Fire # (if avail.)					
Mailing Address W2281 CTH C					Town of SCHLEY					W2281							
City MERRILL					State WI		Zip Code					Street Address or Road Name and Number CTH C					
County Lincoln		Co. Permit #		Notification #			Completed 08-06-1985			Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) D. R. MYTTON - TORK WELL DRILLING					Lic. #		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code				
Address					Well Plan Approval #			NE		NE		Section 30		Township 32 N		Range 8 E	
Approval Date (mm-dd-yyyy)					or Govt Lot #			30		32 N		8 E		2. Well Type New Well			
Hicap Permanent Well #					Common Well #			Specific Capacity			Reason for replaced or reconstructed well ?						
3. Well serves # of Home					Hicap Well ?			Construction Type									
Private, potable					Hicap Property ?												
Heat Exchange ___ # of drillholes					Hicap Potable ?												
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
8		Surface		40		Rotary - Mud Circulation											
6		40		120		<u>Yes</u> Rotary - Air											
						Rotary - Air & Foam											
						Drill-Through Casing Hammer											
						Reverse Rotary											
						Cable-tool Bit ___ in. dia...											
						Dual Rotary											
						Temp. Outer Casing ___ in. dia											
						Removed? ___ depth ft. (If NO explain on back side)											
8. Geology																	
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
R		C		Z		Clay & Boulders				Surface		35					
K		Q		Q		Red Granite				35		40					
		Q		Q		Red & Black Granite				40		120					
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
6		New Steel 18.97#/ft. ASTM A53 GR B J&L Welded				Surface		40									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material																	
Method																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
Drilling Mud and Cuttings				Surface		7											
Neat Cement				7		40											
9. Static Water Level																	
20 ft. _____ ground surface																	
10. Pump Test																	
Pumping level 120 ft. below surface																	
Pumping at 4 GP for 0.5 Hrs.																	
Pumping Method ?																	
11. Well Is																	
18 in. above grade																	
Developed ?																	
Disinfected ?																	
Capped ?																	
12. Notified Owner of need to fill & seal ?																	
Filled & Sealed Well(s) as needed?																	
13. Constructor / Supervisory Driller																	
				Lic #				Date Signed									
Drill Rig Operator																	
				Lic or Reg #				Date Signed									

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: