Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8BL450

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JERALD DULEY	Phone #
Mailing Address: W2281 CTH C	
City: MERRILL	State: WI / Zip Code
County: Lincoln	Co. Permit # / Notification # / Completed: 08-06-1985
Well Constructor (Business Name): D. R. MYTTON - TORK WELL DRILLING	Lic # / Facility ID # (Public Wells)
Address	Well Plan Approval # / Approval Date (mm-dd-yyyy)
Hicap Permanent Well # / Common Well #	Specific Capacity: 0

1. Well Location

Town of SCHLEY				Fire # (if avail.): W2281
Street Address or Road Name and Number: CTH C				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): °N °W				Method Code
NE or Govt Lot #	NE	Section: 30	Township: 32 N	Range: 8 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type

3. Well serves # of Home
Private,potable
Heat Exchange____# of drillholes
Hicap Well ?
Hicap Property ?
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	40
6	40	120

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Air .....
Rotary - Mud Circulation .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	Z	Clay & Boulders	Surface	35
R		Q		Red Granite	35	40
K		Q		Red & Black Granite	40	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	New Steel 18.97#/ft. ASTM A53 GR B J&L Welded	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
20 ft. _____ ground surface

10. Pump Test
Pumping level 120 ft. below surface
Pumping at 4 GP for 0.5 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ?
Disinfected ?
Capped ?

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Drilling Mud and Cuttings	Surface	7	
Neat Cement	7	40	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: