

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BL467		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner LARRY BRIGGS						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address R #1						Town of ROCK FALLS						Street Address or Road Name and Number							
City IRMA				State WI		Zip Code													
County Lincoln		Co. Permit #		Notification #		Completed 06-25-1980		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) DON BALTZ				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code								
Address				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N		°W		Range							
								SW		Section 24				Township 33 N					
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well													
3. Well serves # of Farm						Hicap Well ?		of previous unique well #						constructed in					
								Reason for replaced or reconstructed well ?											
Private, potable						Hicap Property ?		Construction Type											
Heat Exchange ___ # of drillholes						Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)			From (ft.)			To (ft.)			Upper Enlarged Drillhole					Lower Open Bedrock					
10			Surface			20			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)					6		20		91	
6			20			91													
6			20			91													
6			20			91													
6			20			91													
8. Geology																			
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)			To (ft.)								
M				Silt				Surface			1								
Y				Sand & Gravel				1			8								
P C				Clay & Hardpan				8			88								
Y				Sand & Gravel				88			91								
6. Casing, Liner, Screen																			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 30 ft. _____ ground surface				11. Well Is 8 in. above grade					
6		Inner Diameter New Steel Pipe 19.50 lbs. per ft. ASTM A53 Sumitomo Metal Threaded & Coupled				Surface		88											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test Pumping level 70 ft. below surface Pumping at 6 GP for 4 Hrs. Pumping Method ?				Developed ? Disinfected ? Capped ?					
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?					
Method																			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #				Date Signed			
Drilling Mud and Cuttings		Surface		20		20						Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: