

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BL473		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner SCHOONE CONSTRUCTION CO.					Phone #		1. Well Location				Fire # (if avail.)								
Mailing Address 316 CHANDLER ST.							Town of ROCK FALLS												
City TOMAHAWK					State WI		Zip Code												
County Lincoln		Co. Permit #		Notification #		Completed 02-23-1987		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) RENE STIMART - RHINELANDER WELL DRILLING, INC.				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code								
Address						Well Plan Approval #		NW NE Section Township Range or Govt Lot # 35 33 N 6 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ?									
						Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity															
3. Well serves # of Home				Hicap Well ?															
Private, potable				Hicap Property ?															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		71								Q Z		Caving Gravel & Clay		Surface		45	
						Yes Rotary - Air						C		Clay		45		68	
						Rotary - Air & Foam						Y		Sand & Gravel		68		71	
						Drill-Through Casing Hammer													
						Reverse Rotary													
						Cable-tool Bit ___ in. dia...													
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		12 ft. _____ ground surface				12 in. above grade					
6		Plain End New Black Steel 18.97 lbs. A120 US Steel Welded				Surface		68		10. Pump Test				Developed ?					
										Pumping level 60 ft. below surface				Disinfected ?					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 15 GP for 1 Hrs.				Capped ?					
										Pumping Method ?									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method														Filled & Sealed Well(s) as needed?					
														13. Constructor / Supervisory Driller		Lic #		Date Signed	
Drill Rig Operator														Lic or Reg #		Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: