

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BL494		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner DAVID WEDLER					Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address ROUTE 1					Town of BIRCH									
City GLEASON					State WI		Zip Code					Street Address or Road Name and Number CTH J		
County Lincoln		Co. Permit #		Notification #		Completed 06-03-1981		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) WILLIAM L. WEBSTER				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code			
Address				Well Plan Approval #		NE NE		Section 25		Township 33 N		Range 7 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #		Township 33 N		Range 7 E				
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well								
3. Well serves # of Home Private, potable Heat Exchange ___ # of drillholes							Hicap Well ?		of previous unique well # constructed in					
							Hicap Property ?		Reason for replaced or reconstructed well ?					
Heat Exchange ___ # of drillholes							Hicap Potable ?		Construction Type					
							Hicap Potable ?		Construction Type					
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		45		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
Y				Sand & Gravel				Surface		30				
Y C				Sand & Gravel & Clay				30		38				
N S				Fine Sand				38		45				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		New Steel 19.45 lbs. ASTM A53 Interlake Threaded & Coupled				Surface		42						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
6		New Steel 19.45 lbs. ASTM A53 Interlake Threaded & Coupled				Surface		42						
7. Grout or Other Sealing Material Method														
9. Static Water Level 24 ft. _____ ground surface														
10. Pump Test Pumping level 35 ft. below surface Pumping at 20 GP for 1 Hrs. Pumping Method ?														
11. Well Is 8 in. above grade Developed ? Disinfected ? Capped ?														
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller														
Lic #				Date Signed										
Drill Rig Operator				Lic or Reg #				Date Signed						

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: