Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8BL518

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHN LANGE			Phone #
Mailing Address: 6960 DORN RD.			
City: HARTLAND	State: WI	Zip Code	
County: Lincoln	Co. Permit #	Notification #	Completed: 09-09-1987

Well Constructor (Business Name): RON KOMAREK - KOMAREK WELL DRILLING	Lic. #	Facility ID # (Public Wells)	
Address		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.7	
3. Well serves # of Home		Hicap Well ?	
Private,potable		Hicap Property ?	
Heat Exchange____# of drillholes		Hicap Potable ?	

1. Well Location

Town of TOMAHAWK

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name		Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

NW or Govt Lot #	Section: 7	Township: 34 N	Range: 4 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	55

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		P	C	Clay & Hardpan	Surface	50
		Y		sand - gravel	50	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A120 19.45# 1200# psi VSP Threaded & Coupled	Surface	55
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

28 ft. _____ ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 12 GP for 1 Hrs.

Pumping Method ?

11. Well Is

10 in. above grade

Developed ?

Disinfected ?

Capped ?

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Drilling Mud and Cuttings	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: