Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8BL586

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: E. ZOROMSKI			Phone #
Mailing Address: 6908 BITTERSWEET RD.			
City: WAUSAU	State: WI	Zip Code	
County: Lincoln	Co. Permit #	Notification #	Completed: 11-12-1987

Well Constructor (Business Name): RON KOMAREK - KOMAREK WELL	Lic. #	Facility ID # (Public Wells)	
Address		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 2.5	

3. Well serves # of Home
Private,potable
Heat Exchange____# of drillholes
Hicap Well ?
Hicap Property ?
Hicap Potable ?

1. Well Location
Town of SKANAWAN
Fire # (if avail.)
Street Address or Road Name and Number
Subdivision Name | Lot # | Block #
Latitude / Longitude in Decimal Degree (DD) °N °W
Method Code
or Govt Lot # | NW | Section: 5 | Township: 34 N | Range: 7 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	79

Upper Enlarged Drillhole / Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
P	Hardpan	Surface	42
S	Sand	42	50
C	Clay	50	60
S	Sand	60	79

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	Steel ASTM A120 Taiwan YH .280 Welded Joints	Surface	79
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
17 ft. _____ ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 20 GP for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ?
Disinfected ?
Capped ?

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Drilling Mud and Cuttings	Surface	20	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: