

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BL663		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner JAMES FOSTER						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address N11730 ACORN RD.						Town of BRADLEY											
City TOMAHAWK						State WI		Zip Code									
County Lincoln		Co. Permit #		Notification #		Completed 10-08-1986		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) BRAD WEBSTER - RHINELANDER WELL DRILLING				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 4 2 35 N 6 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type									
						Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity													
3. Well serves # of Home				Hicap Well ?													
Private, potable				Hicap Property ?													
Heat Exchange ___ # of drillholes				Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		50		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Q S		Caving Sand		Surface		50	
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		34 ft. _____ ground surface		12 in. above grade					
6		Black Iron Pipe ASTM A120 Plain End US Steel 18.97 lbs/ft. Welded				Surface		47		10. Pump Test		Developed ?					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 42 ft. below surface Pumping at 15 GP for 1 Hrs. Pumping Method ?		Disinfected ?					
												Capped ?					
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?					
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: