Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8BL664

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CARL DINGEL | Phone #:

Mailing Address: ROUTE 3, BOX 53

City: TOMAHAWK | State: WI | Zip Code:

County: Lincoln | Co. Permit # | Notification # | Completed: 05-29-1986

Well Constructor (Business Name): ROBERT WEBSTER - RHINELANDER WELL DRILLING | Lic. # | Facility ID # (Public Wells)

Address | Well Plan Approval # | Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity: 0.4

3. Well serves # of Home

Private,potable

Heat Exchange____# of drillholes

Hicap Well ?

Hicap Property ?

Hicap Potable ?

1. Well Location | Fire # (if avail.)

Town of BRADLEY

Street Address or Road Name and Number

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD) °N °W | Method Code

NW NW or Govt Lot # | Section: 2 | Township: 35 N | Range: 6 E

2. Well Type New Well

of previous unique well # | constructed in

Reason for replaced or reconstructed well ?

Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	75

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	S		Caving Sand	Surface	30
		X		Sand & Clay	30	45
		C	G	Clay & Rocks	45	70
		Y		Sand & Gravel	70	75

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	Black Iron Pipe ASTM A120 US Steel 18.97 lbs/ft.	Surface	72
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

9. Static Water Level

26 ft. _____ ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 15 GP for 1 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ?

Disinfected ?

Capped ?

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: