

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BL667		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner MARY J. FREY					Phone #			1. Well Location				Fire # (if avail.)											
Mailing Address N11939 HEAFFORD RD.					Town of BRADLEY			Street Address or Road Name and Number															
City TOMAHAWK				State WI		Zip Code																	
County Lincoln		Co. Permit #		Notification #		Completed 02-20-1987		Subdivision Name				Lot #		Block #									
Well Constructor (Business Name) RENE STIMART - RHINELANDER WELL DRILLING				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code											
Address				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE NE Section Township Range or Govt Lot # 3 35 N 6 E		2. Well Type New Well													
Hicap Permanent Well #		Common Well #		Specific Capacity				Reason for replaced or reconstructed well ?															
3. Well serves # of Home				Hicap Well ?		Hicap Property ?		Construction Type															
Private, potable																							
Heat Exchange ___ # of drillholes				Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock											Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)					
6 Surface 71			Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)											Q X		Caving Sand & Clay		Surface		40			
														C		Clay		40		70			
														G		Gravel		70		71			
6. Casing, Liner, Screen														9. Static Water Level						11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		12 ft. _____ ground surface						18 in. above grade							
6		New Black Steel A120 PE 18.97 lbs Welded Open Bottom				Surface		71		10. Pump Test						Developed ?							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 60 ft. below surface						Disinfected ?							
										Pumping at 10 GP for 1 Hrs.						Capped ?							
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method														Filled & Sealed Well(s) as needed?									
														13. Constructor / Supervisory Driller				Lic #		Date Signed			
														Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: