

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BL706		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner NORTHERN VIEW MINK RANCH Phone #						1. Well Location				Fire # (if avail.)	
Mailing Address N11486 CTY A						Town of BRADLEY					
City TOMAHAWK State WI Zip Code						Street Address or Road Name and Number					
County Lincoln		Co. Permit #		Notification #		Completed 11-07-1987		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) TERRENCE BECKLEY - NOKOMIS WELL & PUMP				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W		Method Code	
Address				Well Plan Approval #		NE SW Section Township Range or Govt Lot # 11 35 N 6 E		2. Well Type New Well of previous unique well # constructed in			
						Approval Date (mm-dd-yyyy)					
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ?					
3. Well serves # of Other Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? Hicap Property ? Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) From (ft.) To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock									
6 Surface 68		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)									
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)			
S		Sand						Surface 68			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		9. Static Water Level 36 ft. ____ ground surface 10. Pump Test Pumping level 47 ft. below surface Pumping at 50 GP for 1 Hrs. Pumping Method ?			
6		New Steel Pipe ASTM A120 Taiwan W. H. Yaishing Ent. 18.97 lbs. per foot				Surface 53					
6		Nominal Stainless Steel Screen #10				53 68					
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		11. Well Is 12 in. above grade Developed ? Disinfected ? Capped ?			
7. Grout or Other Sealing Material Method											
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?											
13. Constructor / Supervisory Driller								Lic #		Date Signed	
Drill Rig Operator								Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: